

# TECHNICAL SPECIFICATIONS

FOR

## HERITAGE ELEMENTARY ACCESS

OGDEN SCHOOL DISTRICT

PREPARED BY  
GREAT BASIN ENGINEERING, INC.  
OGDEN, UTAH  
17N218

March 13, 2019

# Table of Contents

## HERITAGE ELEMENTARY ACCESS

260001	Electrical General Provisions
260070	Electrical Connections for Equipment
260110	Conduit Raceways
260120	Conductors and Cables
260452	Grounding
265200	Exterior Area Lighting
310700	General Site Construction Requirements
311000	Site Clearing
312000	Earth Moving
315000	Excavation Support and Protection
321313	Concrete Paving
321373	Concrete Paving Joint Sealants
328400	Irrigation System
329000	Landscape Planting
330500	Common Work Results for Utilities
334100	Stormwater
	Geotechnical Report

## **SECTION 260001 ELECTRICAL GENERAL PROVISIONS**

### **PART 1 – GENERAL**

#### **1.1 RELATED DOCUMENTS:**

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.
- B. Architectural, Structural, Mechanical and other applicable documents also apply to work of this section.

#### **1.2 DESCRIPTION OF WORK:**

- A. The contract documents indicate the extent of electrical work. Provide all labor, materials, equipment, supervision and service necessary for a complete electrical system as described in divisions 26, 27, and 28.

#### **1.3 RELATED SECTIONS:**

- A. Other Divisions relating to electrical work apply to the work of this section. See other applicable Divisions including, but not necessarily limited to:
  - 1. Division 1 – General and Supplementary Conditions
  - 2. Division 2 – Existing Conditions
  - 3. Division 3 – Concrete
  - 4. Division 5 – Metals
  - 5. Division 6 – Wood, Plastics, and Composites
  - 6. Division 7 – Thermal and Moisture Protection
  - 7. Division 8 – Openings
  - 8. Division 9 – Finishes
  - 9. Division 21 – Fire Suppression
  - 10. Division 22 – Plumbing
  - 11. Division 23 – Heating Ventilating and Air Conditioning
  - 12. Division 27 – Communications
  - 13. Division 28 – Electronic Safety and Security

#### **1.4 INTERPRETATIONS OF DRAWINGS AND SPECIFICATIONS:**

- A. Prior to bidding the job, submit requests for clarification in writing to the Architect/Engineer prior to issuance of the final addendum.
- B. After signing the contract, provide all materials, labor, and equipment to meet the intent, purpose, and function of the contract documents.
- C. The following terms used in Division 26, 27, and 28 documents are defined as follows:
  - 1. "Provide" - Means furnish, install, and connect, unless otherwise indicated.
  - 2. "Furnish" - Means purchase new and deliver in operating order to project site.

3. "Install" - Means to physically install the items in-place.
4. "Connect" - Means make final electrical connections for a complete operating piece of equipment. This includes providing conduit, wire, terminations, etc. as applicable.
5. "Or Equivalent" - Means to provide equivalent equipment. Such equipment must be approved by the Engineer prior to bidding.

1.5 EXAMINATION OF SITE:

- A. Visit the site and verify existing field conditions prior to submitting bid.
- B. All costs arising from site conditions and/or preparation shall be included in the base bid. No additional charges will be allowed due to inadequate site inspection.

1.6 QUALITY ASSURANCE:

- A. Perform work in accordance with all governing codes, rules, and regulations including the following minimum codes (latest editions or as otherwise accepted by the Authorities Having Jurisdiction):
  1. National Electric Code (NEC)
  2. International Building Code (IBC)
  3. International Fire Code (IFC)
  4. International Mechanical Code (IMC)
  5. International Plumbing Code (IPC)
  6. American Disability Act (ADA)
  7. National Electrical Safety Code (NESC)
  8. Local Codes and Ordinances
- B. Comply with all standards where applicable for equipment and materials including the following minimum standards:
  1. Underwriter's Laboratories (UL)
  2. American Society for testing Materials (ASTM)
  3. Certified Ballast Manufacturers (CBM)
  4. Insulated Cable Engineers Association (ICEA)
  5. National Electrical Manufacturer's Institute (NEMA)
  6. American National Standards Institute (ANSI)
  7. Electrical Testing Laboratories (ETL)
  8. National Fire Protection Association (NFPA)
  9. Institute of Electrical and Electronics Engineers (IEEE)
  10. American Institute of Electrical Engineer's Electrical Power
  11. Systems and Grounding in Commercial Construction
  12. Illuminating Engineers Society (IES)
- C. Provide new electrical equipment conforming to all requirements as set forth in the above standards. Provide UL labeled equipment where such label is applicable.
- D. Comply with all state and local codes and ordinances. When conflicts occur among codes, standards, drawings, and/or specifications, the most stringent requirements shall govern.
- E. Obtain all permits, inspections, etc. required by authority having jurisdiction. Include all fees in

bid. Provide a certificate of approval to the owner's representative from the inspection authority at completion of the work.

- F. Provide only first-class workmanship from competent workers, conforming to the best electrical construction practices.
- G. The contractor shall have a current state contracting license applicable to type of work to be performed under this contract.

1.7 SUBMITTALS:

- A. The contractor shall submit complete shop drawings and other required submittals. Incomplete submittals will be returned to the contractor unreviewed. No time extensions or cost increases will be allowed for delays caused by the return of incomplete submittals.
- B. Shop Drawings: After the contract is awarded, but prior to manufacture or installation of any equipment, submit eight (8) complete sets of shop drawings. Partially complete sets of shop drawings are not acceptable. Submit all shop drawings in one complete submittal package. Prior to submitting shop drawings, review and certify that they are in compliance with the contract documents; Sign all approved shop drawings. Allow a minimum of two weeks for architect/engineer to review shop drawings. Refer to architectural general provision section for additional requirements.
- C. Provide equipment catalog "cut sheets", brochures and/or drawings which clearly describe the proposed equipment. Include plans, elevations, sections, isometrics, and detailed engineering and dimensional information as applicable including equipment room layouts. Electrical room layouts are required to show all electrical equipment locations for all projects that include electrical rooms. Do not submit catalog sheets which describe several different items in addition to those items to be used, unless all relevant information is clearly identified. Bind each information set in three ring binder or binders of sufficient size or sizes to enclose all information. Organize all information by section. Provide separate tabbed covers for each section of Divisions 26, 27, and 28, indicating section number for each section requiring submittals.
- D. Include on front cover of binder or binders the name and location of the project, architect, electrical engineer, general contractor, electrical contractor, subcontractors, supplier/vendor, order number, volume, date, and any other applicable information. Certify that shop drawings are submitted in accordance with the contract documents with a written statement indicating compliance. Submittals will be reviewed and comments produced two times maximum. Additional reviews will be billed at current rates.

1.8 OPERATION AND MAINTENANCE MANUALS:

- A. Submit four (4) complete sets of operating instruction and maintenance manuals for all equipment and materials provided under Divisions 26, 27, and 28.
- B. Provide manufacturer's recommended operating and maintenance instructions, cleaning and servicing requirements, serial and model number of each piece of equipment, complete list of replacement parts, performance curves and data, wiring diagrams, warranties, and vendor's name, address, and phone numbers. Do not submit information which describes several different items in addition to those items to be used, unless all relevant information is clearly

identified. Assemble all data in completely indexed volume or volumes. Engrave the job title, and name, address, and phone numbers of the contractor on the front cover and on the spine. Incomplete O&M manuals will be returned to the contractor for corrections / additions.

1.9 RECORD DRAWINGS:

- A. Maintain on a daily basis a complete set of "Red-Lined Drawings", reflecting an accurate record of all work including addendums, revisions, and changes. Indicate precise dimensioned locations of all concealed work and equipment, including concealed or embedded conduit, junction boxes, etc. Record all "Red-Lined Drawing" information on a set of full sized prints of the contract drawings.
- B. Certify the "Red Lined Drawings" for correctness. Indicate on each drawing the name of the general and electrical contractors with signatures of each representative responsible for the work.
- C. The electrical engineering design firm will create record (as-built) drawings from the certified red-lined drawings; however, the general and electrical contractors retain the responsibility for the accuracy of the record drawings.

1.10 WARRANTY:

- A. Ensure that the electrical system installed under this contract is in proper working order and in compliance with drawings, specifications, and/or authorized changes and is free from electrical defects. Without additional charge, replace or repair, to satisfaction of the owner's representative, except from ordinary wear and tear, any part of the installation which may fail or be determined unacceptable within a period of one (1) year after final acceptance or as otherwise indicated in individual sections, but in no case less than one year. Warranty incandescent and fluorescent lamps only for a period of two months from the date of substantial completion.
- B. Provide complete warranty information for each item including beginning of warranty period, duration of warranty, names, addresses, and telephone numbers and procedures for filling a claim and obtaining warranty services. Written warranties and guarantees are to be submitted separately as:
  - 1. Originals bound in a binder clearly identified with the title, "WARRANTIES AND GUARANTEES," the project name, the project number, and the Contractor's business name.
  - 2. Electronic documents in \*.pdf format.

PART 2 – PRODUCTS

2.1 GENERAL:

- A. All materials shall be new and shall bear the manufacturer's name, trade name, and the approved testing laboratory such as the UL label in every case where a standard has been established for that particular material. Used materials are acceptable only if specifically indicated on drawings.

## 2.2 SUBSTITUTION OF MATERIALS:

- A. Provide only specified products or products approved by addendum. Substitutions will be considered if two copies of the proposal is received at the architect's/engineer's office eight (8) working days prior to the bid day. Include in the proposal the specified and proposed catalog numbers of the equipment under consideration and a catalog cut sheet(s) with pictorial and descriptive information. Certify that the equipment proposed is equal to that specified, that it has the same electrical and physical characteristics, compatible dimensions, and meets the functional intent of the contract documents.
- B. It is the responsibility of the contractor to make all substituted equipment comply with the intent of the contract documents and bear all cost associated with conflicts arising from the use of substituted equipment.
- C. Provide samples if so required by the architect or engineer before or after bid day.

## 2.3 SPARE PARTS:

- A. Provide spare parts as specified in Divisions 26, 27, and 28 sections. Deliver all spare parts to owner's representative prior to substantial completion.

## PART 3 – EXECUTION

### 3.1 GENERAL:

- A. Workmanship: Provide only first class workmanship from competent workers. Defective materials or workmanship will not be allowed on the project. Provide competent supervision for the work to be accomplished. Keep same foreman on the job, unless a change is authorized by the engineer.
- B. Coordination: Prior to construction, layout electrical work and coordinate work with other trades. Sequence, coordinate, and integrate installation of materials and equipment for efficient flow of the work. Coordinate the installation of required supporting devices and sleeves to be set in poured-in-place concrete and other structural components, as they are constructed. Install electrical equipment to facilitate maintenance and repair or replacement of equipment components. Coordinate the installation of electrical materials and equipment above ceilings with suspension system, mechanical equipment and systems, and structural components. Coordinate with all utilities including power, communication, and data installations.
- C. Provide cutting, drilling, channeling, etc. only as necessary for proper completion of the work. Do not cut structural members unless authorization is issued in writing by the architect/engineer.
- D. Repairs: Repair damage to building, grounds, or utilities as a result of work under this contract at no additional cost to the owner.
- E. Dimensioning: Electrical drawings indicate locations for electrical equipment only in their approximate location, unless specifically dimensioned. Do not scale electrical drawings for dimensional information. Refer to architectural drawings and shop drawings where applicable

for locations of all electrical equipment. Field verify all dimension on the job site.

- F. Provide block-outs, sleeves, demolition work, etc., required for installation of work specified in this division.
- G. Standards: Provide electrical installation in accordance with manufacturer's written instructions, applicable requirements of NEC, NEMA standards, and NECA's "Standards of Installation", and in compliance with recognized industry practices to ensure that products fulfill requirements.
- H. All workmen doing work of any nature on State of Utah projects must at all times carry their electrician's license with them and show it upon request. The acceptable ratio of apprentice to journeyman electricians on the job is 1:1.

### 3.2 REQUESTS FOR INFORMATION:

- A. When it is clearly apparent that information is not adequately described in the construction documents or when a coordination problem exists, submit a request for information (RFI) through proper contractual channels. The electrical engineering design firm will provide a response through its contractual channel. Although verbal direction may be given to expedite changes, responses are not considered part of the contract documents until a change order has been issued and signed by the Owner or his designated representative. The Contractor shall bear all costs associated with proceeding on any change order that has not been approved by the Owner or his designated representative.

### 3.3 SAFETY PRECAUTIONS:

- A. Provide all necessary guards or construction barriers and take all necessary precautions to insure the safety of life and property.

### 3.4 CLEAN:

- A. Clean up all equipment, conduit, fittings, wire, packing cartons, plastic, and other debris that is a direct result of the installation of the work of this division, both during the execution, and at the conclusion, of the project. Keep the site clean and safe during the progress of the work. Clean fixtures, interior and exterior of all equipment, and raceways prior to final acceptance. Vacuum interior of all electrical panels and equipment. Correct any damaged equipment. Touch-up or repaint if necessary.

### 3.5 TEMPORARY POWER:

- A. Make arrangements with the proper institution authority for all temporary electricity.
- B. Provide temporary power, complete with metering and wiring for lighting and power outlets for construction tools and equipment. Report the initial meter reading to the owner/institution, or otherwise as may be directed.
- C. Service shall be provided with a main disconnect and all 20 ampere receptacles protected by 20 amp GFI, single-pole breakers. No attempt is made herein to specify construction power requirements for equipment in detail. Provide all electrical equipment and wiring as required.



- D. As soon as permanent power and metering is available, the temporary power supply shall be disconnected and removed from the project site.
- E. All temporary wiring shall meet the requirements of NEC Article 305 and the State Industrial Commission.

3.6 POWER OUTAGES:

- A. All power outages required for execution of this work shall occur during non-standard working hours and at the convenience of the owner. Any electrical service interruption will be coordinated at least 7 days in advance of the power shut-off. Include all costs for overtime work in bid. Coordinate all outages and proceed only after receiving authorization from the owner's representative. Keep all outages to an absolute minimum.

3.7 STORAGE AND PROTECTION OF MATERIALS:

- A. Provide storage space for storage of materials and apparatus and assume complete responsibility for all losses due to any cause whatsoever. Lost or damaged materials will be replaced at no additional cost to owner. Do not store materials and apparatus in any public thoroughfare or in any area on the site where such storage would constitute a hazard to persons in the vicinity. Protect completed work, work underway, and apparatus against loss or damage.

3.8 EXCAVATING FOR ELECTRICAL WORK:

- A. Verification: Prior to excavating, locate and protect existing utilities and other underground work in a manner which will ensure that no damage or service interruption will result from excavating and backfilling. Observe all State and Local codes prior to excavating. Do not disturb walls, footings, and other structural members in any way.
- B. Protection: Provide barricades, warning signs, and illumination to protect persons from injury at excavations. Provide temporary coverings and heat as necessary to protect bottoms of excavations from freezing and frost action. Do not install electrical work on frozen excavation bases or subbases.
- C. Coordination: Do not excavate for electrical work until the work is ready to proceed without delay.
- D. Excavated Materials: Temporarily store excavated materials near excavation in manner which will not interfere with or damage excavation or other work. Dispose of and remove excavated materials which are either in excess of quantity needed for backfilling or do not comply with the requirements for backfill material.
- E. Burial Depths: Burial depths must comply with NEC Section 300-5 (or State of Utah requirements, whichever is more stringent), unless noted otherwise on drawings.
- F. Excavation Permits: Obtain all shut-down and excavation permits as may be required for proper completion of the work.

3.9 BACKFILL MATERIALS:

- A. For buried conduits or cables (other than below slab-on-grade, or concrete-encased), provide 2"

thickness of well-graded sand on all sides of conduits or cables.

- B. For trench backfill to within 6" of final grade, provide soil material suitable for compacting to required densities.
- C. For top 6" of excavation, provide top soil.
- D. Backfill excavations in 8" high courses of backfill material, uniformly compacted to the following densities (percent of maximum density, ASTM D 1557), using power-driven hand-operated compaction equipment:
  - 1. Lawn/Landscaped Areas: 85 percent for cohesive soils, 95 percent for cohesionless soils.
  - 2. Paved Areas, other than roadways: 90 percent for cohesive soils, 95 percent for cohesionless soils.
- E. Where subsidence is observable at electrical work excavations during project warranty period, remove surface, add backfill material, compact, and replace surface treatment. Restore surface to original condition.

### 3.10 ROOF PENETRATIONS:

- A. Where raceways and/or cables penetrate roofing, provide 26 gauge galvanized iron roof jack, sized to fit tightly to raceway and/or cable for weather-tight seal, and with flange extending a minimum of 9" under roofing on all sides. Seal opening between raceway and roof jack with approved sealant. Coordinate all work with division 7.

### 3.11 FIRE PENETRATION SEALS:

- A. Seal all raceway and/or cable penetrations through fire-rated floors, wall, and ceilings to prevent the spread of smoke, fire, toxic gas or water through the penetration either before, during or after fire. Provide penetration sealants and fittings of ratings to match the rating of the penetrated materials so that the original fire rating of the floor or wall is maintained as required by Article 300-21 of the NEC.
- B. Sealant Systems: Provide sealants, wall wraps, partitions, caps, and other accessories complying with UL 1479 (ASTM E-814) from the following where applicable:
  - 1. 3M Fire Barrier Sealing Penetration System
  - 2. Chase Foam Fire Stop System
  - 3. Thomas and Betts Flame Safe Fire Stop System
  - 4. Nelson Fire Stop Products
- C. Fittings: Where applicable, provide OZ Type CFSF/I and CAFSF/I fire seal fittings for conduit and cable penetrations through concrete and masonry wall, floor, slabs, and similar structures.
- D. Install sealants and fittings in accordance with all manufacturer's written instructions.

### 3.12 LABELING:

- A. Engraved black plastic laminated, with white-core labels, 1/16" thick, shall be permanently attached on both the interior and exterior the following electrical equipment:

1. Branch panels
2. Switchgear
3. Disconnect switches
4. Motor starter and controls junction boxes (power and auxiliary)
5. Push buttons
6. Thermal switches
7. Time switches
8. Motor control centers
9. Transformer
10. Similar equipment.
11. Lighting control panels
12. Lighting contactors and associated switches
13. Junction boxes larger than 4x4x1/2.

- B. The labels shall have 1/4" high, engraved letters, such as EF-1, AC-1, Panel A, etc.

3.13 CONCRETE BASES:

- A. Housekeeping Pads: Unless otherwise noted, provide 4" high reinforced concrete bases for all floor-mounted or floor-standing electrical equipment, including but not necessarily limited to the following:
1. Transformers
  2. Switchgear
  3. Motor control centers
  4. Generators – provide 12" high base
  5. Battery racks
  6. Similar Equipment
- B. Extend bases 6" beyond equipment or mounting rails on all sides or as shown on the drawings. Notwithstanding this requirement, coordinate with equipment manufacturer, shop drawings, and height of base to ensure compliance with NEC 380-82.
- C. Concrete bases: Refer to Section [260551 – Exterior Area Lighting](#).
- D. Transformer Pads: Provide and locate properly sized concrete pads for power company furnished pad mounted transformers in accordance with power company clearance requirements.

3.14 TESTS:

- A. Notify engineer prior to all testing specified herein at least three business days prior to testing. Engineer shall observe all tests to insure the proper operation of the electrical system.

3.15 PROJECT FINALIZATION AND START-UP:

- A. Upon completion of the work, have each factory representative and/or subcontractor assist in start-up and testing of their respective systems.
- B. Have each representative give personal instructions on operating and maintenance of their equipment to the owner's maintenance and/or operation personnel.

- C. Have representatives certify each system with a written statement indicating that they have performed start-up and final check out of their respective systems.

3.16 FINAL REVIEW:

- A. Have the project foreman accompany their reviewing parties and remove coverplates, panel covers, access panels, etc. as requested, to allow review of the entire electrical system.

END OF SECTION 260001

## **SECTION 260070 ELECTRICAL CONNECTIONS FOR EQUIPMENT**

### **PART 1 – GENERAL**

#### **1.1 RELATED DOCUMENTS:**

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification Sections, apply to work of this section.
- B. This section is a Division 26 General Provisions section, and is part of each Division 26, 27, and 28 sections making reference to electrical connections.

#### **1.2 DESCRIPTION OF WORK:**

- A. Extent of electrical connections for equipment include all final electrical connections for all equipment having electrical requirements including, but not necessarily limited to the following:
  - 1. Equipment specified under all divisions of the contract. Refer to other divisions for specific electrical requirements.
  - 2. Owner-furnished equipment
  - 3. Kitchen Equipment

#### **1.3 QUALITY ASSURANCE:**

- A. STANDARDS: Refer to [Section 260001 – Electrical General Provisions](#) as applicable.
- B. SHOP DRAWINGS: Not required.

### **PART 2 – PRODUCTS**

#### **2.1 GENERAL:**

- A. Provide all materials for electrical connections including, but not necessarily limited to the following:
  - 1. Raceways
  - 2. Fittings
  - 3. Conductors
  - 4. Cords
  - 5. Cord caps
  - 6. Wiring devices
  - 7. Pressure connectors
  - 8. Lugs (CU-AL)
  - 9. Electrical insulating tape
  - 10. Heat-shrinkable tubing
  - 11. Cable ties
  - 12. Wire nuts

- 13. Other items and accessories as required.
- B. Crimp on or slip-on type splicing materials designed to be used without wire stripping are not acceptable.
- C. Power Distribution Blocks: Provide Square D Type LB or Equivalent.
- D. Refer to other Division 26, 27, and 28 Sections for specification of electrical materials as applicable.

### PART 3 – EXECUTION

#### 3.1 GENERAL:

- A. Make electrical connections in accordance with manufacturer's written instructions, applicable requirements of NEC, NEMA Standards, and NECA's "Standards of Installation", and in compliance with recognized industry practices to ensure that products fulfill requirements.

#### 3.2 CONNECTIONS:

- A. Permanently Installed Fixed Equipment:
  - 1. Install conductors in flexible conduit from junction box to equipment control panel or connection point.
  - 2. Where such installations are subject to moisture, install in liquid-tight flexible conduit.
- B. Movable equipment:
  - 1. Provide wiring devices, cord caps, and multi-conductor cables as required.
- C. Other methods as required by the NEC and/or as required by special equipment or field conditions.
- D. Power Distribution Blocks: Unless noted otherwise on drawings, provide power distribution blocks only for tapping of feeders and branch circuits. Locate in junction box or gutter in NEMA ratings to suit application.

#### 3.3 MANUFACTURER'S INSTRUCTIONS:

- A. Obtain manufacturer's instruction and wiring diagram regarding electrical connections of each piece of equipment and provide connections in accordance therewith.

#### 3.4 VERIFICATION OF LOAD CHARACTERISTICS:

- A. Verify electrical load characteristics of all equipment prior to rough-in. Review respective shop drawings of all other Divisions and Owner's equipment manuals. Report any variances from electrical characteristics noted in the contract documents to the Architect/Engineer prior to rough-in.

END OF SECTION 260070

## **SECTION 260110 CONDUIT RACEWAYS**

### **PART 1 – GENERAL**

#### **1.1 RELATED DOCUMENTS:**

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification Sections, apply to work of this section.
- B. This section is a Division 26 General Provisions section, and is part of each Division 26, 27, and 28 sections making reference to conduit raceways.

#### **1.2 DESCRIPTION OF WORK:**

- A. Extent of raceways is indicated by drawings and schedules.
- B. Types of raceways in this section include the followings:
  - 1. Rigid Metal Conduit
  - 2. PVC Externally Coated Rigid Steel Conduit
  - 3. Intermediate Metal Conduit
  - 4. Electrical Metallic Tubing
  - 5. Flexible Metal Conduit
  - 6. Liquid-tight Flexible Metal Conduit
  - 7. Rigid Non-metallic Conduit
  - 8. Electrical Non-metallic Tubing

#### **1.3 QUALITY ASSURANCE:**

- A. Standards: Refer to [Section 260001 – Electrical General Provisions](#) as applicable. Provide conduit raceway installation in accordance with recommendations of the American Iron and Steel Institute "Design Manual on Steel Electrical Raceways", latest edition.
- B. Manufacturers: Firms regularly engaged in the manufacture of raceway of types and sizes required, whose products have been in satisfactory service for not less than three (3) years.
- C. Shop Drawings: Not required.

### **PART 2 – PRODUCTS**

#### **2.1 CONDUITS:**

- A. Rigid Metal Conduit (RMC): Provide zinc-coated, hot-dipped galvanized, rigid metallic conduit in accordance with Federal Specification WW-C-0581 and ANSI C80.1.
- B. PVC Externally Coated Rigid Metal Conduit: Provide hot-dipped galvanized, rigid metallic conduit externally coated with Polyvinyl Chloride (PVC) in accordance with ANSI C80.1 and

NEMA Std. Pub. No. RN 1.

- C. Intermediate Metal Conduit (IMC): Provide hot-dipped galvanized, intermediate metal conduit in accordance with Federal Specification WW-C-581.
- D. Electric Metallic Tubing (EMT): Provide electric metal tubing in accordance with Federal Specification WW-C-563 and ANSI C80.3.
- E. Flexible Metal Conduit: Provide zinc-coated, flexible metal conduit in accordance with Federal Specification WW-C-566.
- F. Liquid-Tight Flexible Metal Conduit: Provide liquid-tight, flexible metal conduit, constructed of single strip, flexible continuous, interlocked, and double-wrapped steel, galvanized inside and outside, coated with liquid-tight jacket of flexible Polyvinyl Chloride (PVC).
- G. Rigid Non-Metallic Conduit: Provide rigid non-metallic conduit (PVC) in accordance with ANSI/NEMA TC 2, Type 1 for concrete encasement, Type 2 for direct burial.

## 2.2 FITTINGS:

- A. Rigid Metal Conduit, Intermediate Metal Conduit, and PVC Externally Coated Rigid Metal Conduit: Provide fully-threaded, malleable steel fittings, rain-tight and concrete-tight as applicable. Provide double locknuts and metal bushings at all conduit terminations. Install OZ Type B bushings on conduits 1-1/4" and larger.
- B. Electric Metallic Tubing: Provide insulated throat, non-indenter, set screw, malleable steel fittings. Screws must have a full set. Provide concrete-tight compression-type fittings in suspended slabs. All EMT fittings shall be fabricated from steel. Die-cast fittings or fittings made from pot metal shall not be allowed. Indenter type fittings are not acceptable. Install OZ Type B bushings on conduits 1" and larger.
- C. Flexible Metal Conduit: Provide flexible metal conduit fittings in accordance with Federal Specification W-F-406, Type 1, Class 1, and Style A. Commercial "greenfield" not less than 1/2" diameter or as otherwise specified on drawings is acceptable.
- D. Liquid-Tight Flexible Metal Conduit: Provide liquid-tight flexible metal conduit fittings in accordance with Federal Specification W-F-406, Type 1, Class 3, Style G.
- E. Non-Metallic Conduit: Provide non-metallic conduit fittings (PVC) in accordance with ANSI/NEMA TC 3 to match conduit types and materials.
- F. Expansion Fittings: OZ Type AX, or equivalent to suit application.
- G. Sealing Bushings: Provide OZ Type FSK, WSK, or CSMI as required by application. Provide OZ Type CSB internal sealing bushings.
- H. Cable Supports: Provide OZ cable supports for vertical risers, type as required by application.

## 2.3 SIZES:

- A. Provide conduits in sizes as indicated in contract documents or as otherwise specified herein, but not less than 3/4". Minimum sizes for data conduits is 1".



2.4 FIRE ALARM RACEWAY:

- A. All fire alarm conduits, connections, etc. shall be red.

PART 3 – EXECUTION

3.1 GENERAL:

- A. Install raceway and accessories in accordance with manufacturer's written instructions, applicable requirements of NEC, NEMA Standards, and NECA's "Standards of Installation", and in compliance with recognized industry practices to ensure that products fulfill requirements.

3.2 LOCATIONS:

- A. Rigid Metal Conduit and Fittings: Use for conduit bends greater than 22 degrees where buried below grade or slab on grade. Install RMC where raceway passes vertically through slab-on-grade. Where raceways penetrate building, manholes, or vault walls and floors below grade, provide RMC for a minimum distance of 10' on the exterior side of the floor or wall. Use RMC for exposed runs where conduit is subject to moisture, weather, or mechanical injury. Use in hazardous locations in accordance with all NEC requirements.
- B. Intermediate Metal Conduit and Fittings: Use for exposed runs where conduit is subject to moisture, weather, or mechanical injury. Use in hazardous locations in accordance with all NEC requirements.
- C. Electric Metal Tubing and Fittings: Use for above-grade feeders, branch circuits, and signal and control circuit, unless specifically noted otherwise on drawings. Install in suspended slabs subject to local code requirements and fire rating considerations.
- D. Flexible Metal Conduit and Fittings: Use as whips for lighting fixtures, fixed equipment where not exposed to weather or moisture, other devices where required by NEC, and as requested by the Engineer. Maximum length not to exceed 6', unless specifically approved by the Electrical Engineer.
- E. Liquid-Tight Flexible Metal Conduit and Fittings: Use for connection to motor terminal boxes, fixed equipment where subject to moisture or weather, and other equipment subject to movement or vibration. Maximum length not to exceed 6', unless specified otherwise.
- F. Rigid Non-Metallic Conduit and Fittings: Use for below-grade service entrances, feeders, branch circuits, and signal and control circuit, unless specifically noted otherwise on drawings. Do not use above grade.

3.3 METHODS:

- A. Maintain a minimum of 12" clearance between steam or hot water lines or other hot surfaces. Where such clearance is impractical, insulate conduit with approved materials.
- B. Install conduits parallel with or at right angles to lines of the structure. Route conduits symmetrically where possible.

- C. Field bends and offsets shall be made without flattening, kinking, rippling or destroying the smooth internal bore or surface of the conduit and to not less than NEC minimum radius. Conduit that shows signs of rippling or kinking shall not be installed. Conduits installed with wrinkles or kinks or otherwise in an unworkmanlike manner shall be replaced at no additional cost to owner.
- D. Precaution shall be exercised to prevent accumulation of water, dirt or concrete in the conduits during the execution of the project. Conduits in which water or foreign matter has been permitted to accumulate shall be thoroughly cleaned or the conduits runs replaced where such accumulation cannot be removed by methods approved the engineer.
- E. Any conduit which pierces airtight spaces or plenums shall be sealed to prevent air leakage with mastic acceptable to the Architect.

#### 3.4 CONCEALING:

- A. All raceways shall be concealed within the ceilings, walls, and floors, except in locations where exposed raceways are specifically permitted, such as equipment rooms and unfinished storage areas. In equipment rooms, if lighting raceways are run exposed, installation shall not be done until piping and duct work layout has been determined in order that lighting boxes may be located so as to avoid being covered by overhead ducts and piping. If lighting raceways in equipment rooms are concealed in the structural ceiling slab, after mechanical work is complete, exposed conduit extensions shall be run to locate lighting fixtures where they are not obscured by work of other trades.

#### 3.5 BURIED CONDUITS:

- A. Comply with all burial depths as defined in NEC Section 300-5. Bury all conduits at least 24" below grade, unless specifically indicated otherwise on drawings. Provide magnetic 6" wide "Yellow Warning" ribbon 12" directly above conduit and 6" below finished grade measured from the top of the conduit or duct bank. Where multiple small lines are buried in a common trench and do not exceed an overall width of 16", install a single marker.
- B. Slope all conduits toward manholes or pull boxes for proper drainage. Use weep holes. Gravel drainage pockets are not permitted.
- C. Coat all metal conduits with an approved asphaltic compound or wrap with two layers of PVC tape.
- D. Under Concrete Slab on Grade: Horizontal conduit must be installed a minimum of 8" below the bottom of the concrete slab. Conduits should not be installed in concrete slabs.
- E. Concrete Encasement: Where concrete-encasement is indicated on drawings, provide duct bank construction using red 3000 psi at 28 day strength concrete. Provide minimum 4" cover on all sides of exterior conduits. Provide conduit spacers where applicable. Coat all metal conduits with an approved asphaltic compound or wrap with two layers of PVC tape.
- F. Where conduits are extended for future use, cap and clearly mark.

#### 3.6 ELECTRICAL CONTINUITY:

- A. Provide electrically continuous conduit systems throughout.

3.7 FIELD CUTS AND THREADS:

- A. Cut all conduits square. Remove all sharp or rough edges and ream all burrs, inside and outside. Provide clean sharp threads on RMC and IMC.
- B. Engage at least five full threads on all RMC and IMC fittings. Before couplings or fittings are attached, apply one coat of red lead or zinc chromate to male threads of RMC or IMC. Apply coat of red lead, zinc chromate or special compound recommended by manufacture to conduit where conduit protective coating is damaged.

3.8 SUSPENDED SLABS:

- A. When conduit is installed in the suspended slab, it shall be limited to conduits having a diameter of 1" (25 mm) or less, or less than 1/3 the concrete cover, and no crossovers occur, and conduit spaced at least 18" (450 mm) apart with a 3/4" (20 mm) cover.

3.9 CONDUIT ENDS:

- A. Cap all spare conduits. Cap or plug conduit ends during construction to prevent entrance of foreign material.

3.10 SPARE CONDUITS:

- A. Provide five (5) 3/4" empty conduits from recessed branch panelboards to accessible ceiling spaces and five (5) 3/4" conduits into accessible floor space. When floor is not accessible, provide six (6) 3/4" empty conduits from panelboard to accessible ceiling space. Cap and label all conduits.
- B. Install a 200 lb. polypropylene pull cord in each empty conduit run.

3.11 POWER COMPANY RACEWAY METHODS:

- A. Comply with all Power Company Requirements.
- B. The contractor shall provide all conduit systems for the required electrical utility work; raceway shall be PVC or RMC. All elbows shall be long-radius PVC, RMC, or fiberglass elbows complying with all ESR requirements. Sleeve conduits when conduit extends vertically through a paved surface. Provide 500 lb flat pull line or poly rope within each conduit. Proof all conduits with an 80% diameter mandrel witnessed by the Utility representative.
- C. The contractor shall provide trenching, boring, backfill, compactions, and surface repair.
- D. The contractor shall provide pre-case concrete pad/vaults for utility provided transformers as required.
- E. The contractor shall provide concrete pads for utility provided transformers as required.
- F. Install RMC and IMC in all hazardous locations as defined by the NEC. Provide suitable fittings, seal-offs, boxes, etc. to comply with all NEC requirements and/or as shown on the drawings. Provide inspection fittings with hazardous location rated drains to prevent water

from accumulating in conduit runs.

3.12 HAZARDOUS LOCATIONS:

- A. Install RMC and IMC in all hazardous locations as defined by the NEC. Provide suitable fittings, seal-offs, boxes, etc. to comply with all NEC requirements and/or as shown on the drawings. Provide inspection fittings with hazardous location rated drains to prevent water from accumulating in conduit runs.

3.13 BUILDING AUTOMATION SYSTEM (BAS) CONDUITS:

- A. Division 26 Contractor shall provide raceways and boxes for the following Building Automation System components:
  - 1. All BAS Box and raceway rough-in for all walls, regardless of construction, from the electrical box to above the ceilings as shown on the Mechanical and/or Plumbing drawings. This includes but is not limited to: thermostats, push button mushroom switches, kitchen panels, etc.
  - 2. Any underground raceway required for Network or BAS communications from the Structure containing the Head end equipment to any outlying structures, equipment and/or locations that require BMS communication. This includes but is not limited to: outbuildings, concessions, generators, cooling towers etc.

3.14 CLEANING:

- A. Pull mandrel and swab through all conduits before installing conductors.

END OF SECTION 260110

## SECTION 260120 CONDUCTORS AND CABLES

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS:

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification Sections, apply to work of this section.
- B. This section is a Division 26 General Provisions section, and is part of each Division 26, 27, and 28 sections making reference to conductors and cables.

#### 1.2 DESCRIPTION OF WORK:

- A. This section includes building wires and cables and associated connectors, splices, and terminations for wiring systems rated 600 V and less.
- B. Types of conductors and cables in this section include the following:
  - 1. Copper Conductors.
  - 2. Aluminum Conductors.
  - 3. Flexible Cords.
- C. Applications for conductors and cables required for project include:
  - 1. Electrical service.
  - 2. Feeders.
  - 3. Branch Circuits.

#### 1.3 SUBMITTALS:

- A. Product Data: For each type of conductor and/or cable indicated.
- B. Field Quality-Control Test Reports: From Contractor. Refer to [Section 260001 – General Electrical Provisions](#).

#### 1.4 QUALITY ASSURANCE:

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with NFPA 70.

### PART 2 – PRODUCTS

#### 2.1 GENERAL:

- A. Manufacturers: In other Part 2 articles where subparagraph titles below introduce lists, provide products by the manufacturer specified, subject to compliance with requirements.
- B. Ambient Conditions: Conductors used for branch circuits in areas where the ambient conditions exceed 30 degree C. shall be provided with insulation approved for that temperature.
- C. Wire Sizes: As indicated on electrical drawings or as specified herein, but in no case less than No. 12 AWG.

## 2.2 COPPER CONDUCTORS:

- A. Manufacturers:
  - 1. Cerro Wire & Cable Company.
  - 2. General Cable Technologies Corporation.
  - 3. Encore Wire Corporation.
  - 4. Southwire Incorporated.
- B. Refer to Part 3 "Conductor and Cable Applications" Article for application requirements.
- C. References and Ratings:
  - 1. ICEA S-95-658 / NEMA WC70.
  - 2. ASTM.
  - 3. UL Standard 83.
  - 4. UL Standard 1063 (MTW).
  - 5. Federal Specification J-C-30B.
  - 6. NEC.
- D. Conductor Material: Copper.
- E. Stranding: Solid conductor for No. 12 AWG, stranded for No. 10 AWG and larger.
- F. Conductor Insulation Types: Thermoplastic-insulated, Type THHN / THWN-2.

## 2.3 ALUMINUM CONDUCTORS:

- A. Manufacturers:
  - 1. Alcan Aluminum Corporation; Alcan Cable Div.
- B. Refer to Part 3 "Conductor and Cable Applications" Article for application requirements.
- C. References and Ratings:
  - 1. ICEA S-95-658 / NEMA WC70.
  - 2. Federal Specification J-C-30B.
  - 3. ASTM Standards B 800 and B 801.
- D. Conductor Material: Aluminum.
- E. Stranding: STABILOY compact stranded conductor (AA-8000 Series aluminum alloy).

- F. Conductor Insulation Types: Black cross-linked polyethylene (XLPE), Type XHHW-2.

## 2.4 FLEXIBLE CORDS:

- A. Manufacturers:
  - 1. Cerro Wire & Cable Company.
  - 2. General Cable Technologies Corporation.
  - 3. Encore Wire Corporation.
  - 4. Southwire Incorporated.
- B. Refer to Part 3 "Conductor and Cable Applications" Article for application requirements.
- C. References and Ratings:
  - 1. ASTM.
  - 2. ICEA.
  - 3. UL 62.
  - 4. Pendant or portable.
  - 5. Damp locations.
  - 6. 600 Volts.
  - 7. NEC Article 400.
- D. Conductor Material: Copper.
- E. Stranding: Class K, flexible stranded conductor.
- F. Conductor Insulation Types: Heat- and moisture-resistant TPE insulation.
- G. Fillers and Wrapping: Non-wicking polypropylene fillers, with tissue-paper separator wrapped around the assembly.
- H. Outer Jacket: Black-colored, heat-, moisture-, and oil-resistant TPE jacket.
- I. Grounding: Insulated green grounding conductor.
- J. Cord Type: SO, hard-usage.

## 2.5 CONNECTORS AND SPLICES:

- A. Manufacturers:
  - 1. AFC Cable Systems, Inc.
  - 2. AMP Incorporated/Tyco International.
  - 3. Hubbell/Anderson.
  - 4. O-Z/Gedney; EGS Electrical Group LLC.
  - 5. 3M Company; Electrical Products Division.
- B. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.
- C. Splices for wire sizes #10 and smaller shall be screw-on type similar to scotch or ideal wing nut

connectors. Crimp-on splices designed to be used without wire stripping are not acceptable.

### PART 3 – EXECUTION

#### 3.1 GENERAL:

- A. Install conductors, cables, and accessories as indicated, in compliance with manufacturer's written instruction, applicable requirements of NEC, NECA's "Standards of Installation", and in accordance with recognized industry practices to ensure that products fulfill requirements.

#### 3.2 CONDUCTOR AND CABLE APPLICATIONS:

- A. Service Entrance: As indicated on the electrical drawings.
- B. Feeders: As indicated on the electrical drawings.
- C. Branch Circuits:
  - 1. Exposed, including in crawlspace: Copper conductors in raceway. In finished ceiling areas, conduits shall be painted to match the surrounding surface.
  - 2. Concealed in gypsum board ceilings, walls, and partitions: Copper conductors in raceway.
- D. Cord Drops, Reels, and Portable Appliance Connections: Flexible cord.
- E. Class 1 Control Circuits: Copper conductors in raceway.

#### 3.3 INSTALLATION:

- A. Conceal cables in finished walls, ceilings, and floors, unless otherwise indicated.
- B. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- C. Use pulling means; including fish tape, cable, rope, and basket-weave wire/cable grips that will not damage cables or raceway.
- D. When raceway is not required, install concealed cables parallel and perpendicular to surfaces of structural members, and follow surface contours where possible.
- E. Support cables according to other applicable specification sections.
- F. Seal around cables penetrating fire-rated elements to comply with applicable fire stop specification sections.
- G. Color Coding: Color code secondary service, feeder, and branch circuit conductors. Colors shall remain consistent throughout the project and shall match existing coding system where applicable.



1. Conductor sizes No. 6 AWG and smaller: Colored insulation.
2. Conductors sizes No. 4 AWG and larger: 2 inch (51 mm) band of Colored adhesive marking tape applied at all terminations, junction boxes, and pull boxes.
3. Branch circuit switched-legs and travelers: Colored insulation (in colors other than those indicated below).
4. Color-code 120/208V system conductors:
  - a. Phase A: Black.
  - b. Phase B: Red.
  - c. Phase C: Blue.
  - d. Neutral A: White with Black stripe.
  - e. Neutral B: White with Red stripe.
  - f. Neutral C: White with Blue stripe.
  - g. Neutral (Shared when allowed): White
  - h. Ground: Green.
  - i. Isolated Ground: Green with yellow tracer.
5. Color-code 277/480V system conductors:
  - a. Phase A: Brown.
  - b. Phase B: Orange.
  - c. Phase C: Yellow.
  - d. Neutral A: Gray with Brown stripe.
  - e. Neutral B: Gray with Orange stripe.
  - f. Neutral C: Gray with Yellow stripe.
  - g. Neutral (Shared when allowed): Gray.
  - h. Ground: Green.

### 3.4 HOMERUN CIRCUITS:

- A. Homerun circuits may be combined in common conduits at the option of the contractor in compliance with the following:
  1. Three-Phase Installations: Not more than three single-phase circuits in one conduit, unless specifically noted otherwise, if each circuit is from a different phase (a, b, or c).

### 3.5 NEUTRAL CONDUCTORS:

- A. LINE-TO-NEUTRAL BRANCH CIRCUITS: For multi-phase branch circuits, provide an oversized common neutral conductor sized one size (AWG) larger than the largest phase conductor; for 120/208V, 3-Phase systems, provide UL-Listed common handles on circuit breakers; for 277/480V, 3-Phase systems, provide multi-pole circuit breakers. For 277V branch circuits only, a dedicated neutral may be provided for each circuit in conjunction with 20A-1P breakers in lieu of shared neutrals with multi-pole breakers.

### 3.6 VOLTAGE DROP:

- A. Provide branch circuit conductors in sizes such that voltage drop for branch circuits do not exceed 3 percent at the farthest outlet. Provide service, feeder, and branch circuit conductors so that the voltage drop on the entire electrical system does not exceed 5 percent at the farthest outlet. This shall be strictly followed regardless of the conductor sizes indicated on the electrical drawings. Increase conductor sizes (and conduits where necessary to comply with NEC conduit fill requirements) as necessary to accommodate this requirement. Calculations shall be based on the following:

1. Lighting Branch Circuits: Connected load plus 25% spare.
2. Appliance and Equipment Branch Circuits: Nameplate or NEC required load.
3. 120V Convenience Outlet Branch Circuits: 12 amps minimum, but in no case less than NEC loading requirements. Use the following schedule:

<u>Distance (feet)</u>	<u>Wire Size (AWG)</u>
0-80	#12
81-125	#10
126-200	#8
201-320	#6

4. Use the NEC method to calculate voltage drop.

### 3.7 CONNECTIONS:

- A. All connections shall be made using a torque wrench. Tighten electrical connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A and UL 486B. Provide a report indicating the actual torque values utilized on all feeders 100 amp and greater.
- B. Make splices and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.
- C. Use oxide inhibitor in each splice and tap conductor for aluminum conductors.
- D. Wiring at Outlets: Install conductor at each outlet, with at least 6 inches (150 mm) of slack. Use pig tails when wiring outlets.

### 3.8 FIELD QUALITY CONTROL:

- A. Testing: Perform the following field quality-control testing:
  1. Visual and Mechanical Inspection:
    - a. Inspect cables for physical damage and proper connection in accordance with the electrical construction documents.
    - b. Test cable mechanical connections to manufacturer's recommended values with a calibrated torque wrench.
    - c. Check cable color coding for compliance with electrical specifications.
  2. Electrical Tests:
    - a. Perform insulation resistance test on each conductor for feeders 100 amps and greater with respect to ground and adjacent conductors. Applied potential shall be 1000 volts dc for 1 minute.
      - i. Follow-up insulation resistance test: Perform an additional follow-up insulation test for each conductor for feeder 100 amps and greater with respect to ground and adjacent conductor. Applied potential shall be 1000 volts dc for 1 minute.
      - ii. An Owner's representative shall witness the tests. Coordinate schedule of testing and power outages with the Owner at least two weeks prior to testing.
    - b. Perform continuity test to insure proper cable connection.

3. Test Values:
    - a. Minimum insulation resistance values shall not be less than two megaohms.
  4. Infrared Scanning: After Substantial Completion, but not more than 60 days after Final Acceptance, perform an infrared scan of each splice in conductors No. 3 AWG and larger. Remove box and equipment covers so splices are accessible to portable scanner. Correct deficiencies determined during the scan.
    - a. Follow-up Infrared Scanning: Perform an additional follow-up infrared scan of each splice 11 months after date of Substantial Completion.
    - b. Instrument: Use an infrared scanning device designed to measure temperature or to detect significant deviations from normal values. Provide calibration record for device.
    - c. Record of Infrared Scanning: Prepare a certified report that identifies splices checked and that describes scanning results. Include notation of deficiencies detected, remedial action taken, and observations after remedial action.
    - d. An Owner's representative shall witness the tests. Coordinate schedule with Owner at least two weeks prior to testing.
- B. Test Reports: Prepare a written report and submit to the Electrical Engineer at the completion of the project. The report shall include the following:
1. Test procedures used.
  2. Test results that comply with requirements.
  3. Test results that do not comply with requirements and corrective action taken to achieve compliance with requirements.

END OF SECTION 260120

## **SECTION 260452 GROUNDING**

### **PART 1 – GENERAL**

#### **1.1 RELATED DOCUMENTS:**

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification Sections, apply to work of this section.
- B. This section is a Division 26 General Provisions section, and is part of each Division 26, 27, and 28 sections making reference to grounding.

#### **1.2 DESCRIPTION OF WORK:**

- A. Extent of grounding work is indicated by drawings and schedules and is specified herein.
- B. Ground the complete electrical installation including the system neutral, metallic conduits and raceways, boxes, fittings, devices, cabinets, equipment, and separately derived systems in accordance with the NEC and all other applicable codes to provide a permanent, continuous, low impedance, grounding system.
- C. Provide grounding system such that the resistance from the service entrance ground bus, through the grounding electrode to earth is not greater than 5 ohms.

#### **1.3 QUALITY ASSURANCE:**

- A. STANDARDS: Refer to [Section 260001 – Electrical General Provisions](#) as applicable.
- B. TESTING: Submit results of ground resistance testing as specified in this section. Include name of testing agency with report. Include test results in operation and maintenance manuals.

### **PART 2 – PRODUCTS**

#### **2.1 GENERAL:**

- A. Provide grounding equipment and accessories of types, sizes, ratings, and electrical characteristics indicated or as otherwise required to provide a complete system.

#### **2.2 GROUNDING CONDUCTORS:**

- A. Unless noted otherwise, provide grounding conductors with stranding and insulation types to match phase conductors. Provide conductors with green insulation if possible; otherwise wrap with green tape. Size ground conductors as indicated on drawings. Do not size ground conductors smaller than that allowable by NEC.

#### **2.3 GROUND RODS:**

- A. Provide copper clad, steel, 3/4" diameter by 10' long, ground rods (Weaver, Cadweld, or equivalent).

2.4 INSULATED GROUNDING BUSHINGS:

- A. Provide plated malleable iron body with 150 degree Centigrade molded plastic insulating throat, lay-in grounding lug with hardened stainless steel fasteners (OZ Gedney BLG or equivalent).

2.5 CONNECTIONS TO STRUCTURAL STEEL, GROUND RODS, OR SPLICES:

- A. Provide exothermic welds. (Cadweld or equivalent)

2.6 BONDING JUMPERS:

- A. Provide bonding jumpers with hot dip galvanized malleable or ductile iron clamps, hot dip galvanized steel U-bolts, and tinned copper braids (OZ Gedney BJ Series or equivalent).

PART 3 – EXECUTION

3.1 GENERAL:

- A. Install grounding systems in accordance with manufacturer's written instructions, applicable requirements of NEC, NEMA standards, and NECA's "Standards of Installation", and in compliance with recognized industry practices to ensure that products fulfill requirements.

3.2 CLEANING:

- A. Thoroughly clean all metal contact surfaces prior to installation of clamp-on connectors.

3.3 EQUIPMENT BONDING AND GROUNDING:

- A. Provide an NEC sized copper conductor, whether indicated or not on the drawings, in raceways as follows:
  - 1. Non-metallic conduits and ducts.
  - 2. Distribution feeders.
  - 3. Motor and equipment branch circuits.
  - 4. Device and lighting branch circuits.
  - 5. Full length of all multi-outlet assemblies and other surface wireways.

3.4 ADDITIONAL GROUNDING INSTALLATION REQUIREMENTS:

- A. Provide grounding bushings on all service conduit and conduits installed in concentric/eccentric knock-outs or reducing washer at panelboards, cabinets, and gutters.
- B. Provide bonding jumpers across expansion and deflection couplings in conduit runs, across pipe connections at water meters, and across dielectric couplings in metallic cold water piping system. Connection to water piping system shall be made electrically continuous by connecting to the street side of the water main valve and/or installing additional bonding jumpers across the meter, valves or service unions that might be disconnected.

- C. Provide bonding wire in all flexible conduits.
- D. Isolated Ground Circuits: Circuits used for isolated ground outlets shall be run in separate raceways or shall have a separate green insulated ground conductor installed and tagged for identification at all outlet and junction boxes.

3.5 TESTING:

- A. Obtain and record ground resistance measurements both from service entrance ground bus to the ground electrode and from the ground electrode to earth. Install additional bonding and grounding electrodes as required to comply with resistance limits specified under this Section. Use independent testing agency for all testing.

END OF SECTION 260452

## **SECTION 265200 EXTERIOR AREA LIGHTING**

### **PART 1 – GENERAL**

#### **1.1 RELATED DOCUMENTS:**

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification Sections, apply to work of this section.
- B. This section is a Division 26 General Provisions section, and is part of each Division 26, 27, and 28 sections making reference to exterior area lighting.

#### **1.2 DESCRIPTION OF WORK:**

- A. Extent of exterior area lighting work is indicated by drawings and schedules and is specified herein.

#### **1.3 QUALITY ASSURANCE:**

- A. **STANDARDS:** Refer to [Section 260001 - Electrical General Provisions](#) and other sections as applicable.
- B. **SHOP DRAWINGS:** Submit manufacturer's data on exterior area lighting items including but not necessarily limited to poles, brackets, light fixtures, fuse, fuseblocks, etc. Submit dimensioned drawings of all pole and lighting fixtures.

#### **1.4 WARRANTY**

- A. **General Warranty:** Special warranty specified in this Article shall not deprive the Owner of other rights the Owner may have under the provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by the Contractor under requirements of the Contract Documents.
- B. **Special Warranty for LED Lighting Fixtures:** A warranty must be provided by the manufacturer made out to Owner for luminaires, covering repair or replacement of defective electrical parts (including light source and power supplies) within specified warranty period indicated below.
  - 1. **Warranty Period:** Five (5) years from date of Substantial Completion.

### **PART 2 – PRODUCTS**

#### **2.1 GENERAL:**

- A. Provide exterior lighting fixtures of types as indicated on drawings or as approved by addenda.

#### **2.2 LIGHT FIXTURES:**

A. All Luminaires

1. Comply with IES LM79 and IES LM80 LED product testing procedures, and DOH energy Star requirements.
2. Luminaires shall not draw power in the off state. Luminaires with integral occupancy, motion, photo-controls, or individually addressable fixtures with external control and intelligence are exempt from this requirement. The power draw from such luminaires shall not exceed 0.5 watts when in the off state.
3. Color spatial uniformity shall be within .004 of CIE 1976 diagram.
4. Color maintenance over rated life shall be within .007 of CIE 1976.
5. Luminaires shall have a minimum CRI of 80.
6. Color shall fall within 200K of specified range.
7. LED modules shall be fully replaceable without replacing the fixture.
8. Luminaire manufacturers shall adhere to device manufacturer guidelines, certification programs, and test procedures for thermal management.
9. LED package(s)/module(s)/array(s) used in qualified luminaires shall deliver at least 70% of initial lumens, when installed in-situ, for minimum of 35,000 hours.

B. Power Supplies and Drivers

1. Power Factor 0.90 or higher
2. Operating temperature: minimum or -20°F (129°C) or below when used in luminaires intended for outdoor use.
3. Maximum driver case temperature not to exceed driver manufacturer recommended in-situ operation.
4. Output operating frequency: 120Hz.
5. Interference: EMI and RFI compliant with FCC 47 CFR Part 15.
6. Total Harmonic Distortion Rating: Less than 3 percent.
7. Meet electrical and thermal conditions as described in LM-80 Section 5.0.
8. Primary Current: confirm primary current with Electrical Drawings.
9. Secondary Current: Confirm secondary current specified by individual luminaire manufacturers.
10. Compatibility: Certified by manufacturer for use with individually specified luminaire and individually specified control components.
11. Solid-state control components to be integral or external per each specified luminaire. Remote control gear to be enclosed in Class 1, Class 2, or NEMA 3R enclosures as required.

2.3 POLES:

- A. Provide poles and all accessories including but not necessarily limited to anchor bolts, templates for anchor bolt pattern, brackets, bolts, etc. Provide handhole and cover at base of each pole. Provide poles which have been primed and painted at the factory. Provide poles, anchor bolts, etc. in sizes as recommended by manufacturer to withstand wind loadings.

2.4 CONCRETE BASES:

- A. Provide 3000 psi class concrete, forms, steel reinforcement, tie wires, etc. as required. See drawings for details.

2.5 GROUND RODS:



- A. See [Section 260452 – Grounding](#) for ground rod requirements.

2.6 FUSEHOLDER, FUSES, AND BREAK-A-WAY RECEPTACLES:

- A. Provide fuseholders with break-a-way receptacles equivalent to Bussmann Tron Waterproof Fuseholders and Break-A-Way Receptacles in the base for all phase conductors and materials. Neutral fuse holder will use a shorting fuse insert. Provide Bussmann KTK-R fuses in ratings to suit respective applications and sized in accordance with all manufacturer's recommendations.

PART 3 – EXECUTION

3.1 GENERAL:

- A. Install exterior area lighting in accordance with manufacturer's written instructions, applicable requirements of NEC, NEMA standards, and NECA's "Standards of Installation", and in compliance with recognized industry practices to ensure that products fulfill requirements.

3.2 INSTALLATION METHODS:

- A. Set all poles plumb. Use belt slings or ropes to raise and set poles to protect finish. Repair nicks and scratches to match original surface.
- B. Locate fuseholder at handhole. Provide fuse blanks in all neutral conductors.
- C. Grounding: Provide one ground rod for each light pole. Connect ground rod to pole by means of an NEC-sized grounding conductor and all additional grounding as required.

3.3 CONCRETE BASES:

- A. Provide concrete bases for light poles in accordance with details on drawings. Grout and hand-rub all concrete to a uniform smooth finish.

3.4 SPARE PARTS:

- A. FUSES: Provide three spare fuses for each type and size used.

3.5 WIRING METHODS:

- A. No common neutral multi-wire circuits will be used to feed area lighting. Provide dedicated neutral wire for each circuit indicated.

END OF SECTION 265200

## **SECTION 310700 GENERAL SITE CONSTRUCTION REQUIREMENTS**

### **PART 1 GENERAL**

#### **1.1 SUMMARY**

- A. Includes But Not Limited to
  - 1. General procedures and requirements for Site Work.

### **PART 2 PRODUCTS - Not Used**

### **PART 3 EXECUTION**

#### **3.1 PREPARATION**

- A. Site Verification Of Conditions
  - 1. 48 hours minimum prior to performing any work on site, contact Blue Stakes to arrange for utility location services.
  - 2. Perform minor, investigative excavations to verify location of various existing underground facilities at sufficient locations to assure that no conflict with the proposed work exists and sufficient clearance is available to avoid damage to existing facilities.
  - 3. Perform investigative excavating 5 days minimum in advance of performing any excavation or underground work.
  - 4. Upon discovery of conflicts or problems with existing facilities, notify Architect by phone or fax within 24 hours. Follow telephone or fax notification with letter and diagrams indicating conflict or problem and sufficient measurements and details to evaluate problem.
  - 5. Notify Owner of utilities a minimum of 48 hours prior to an work taking place.

#### **3.2 PREPARATION**

- A. Protection
  - 1. Spillage -
    - a. Avoid spillage by covering and securing loads when hauling on or adjacent to public streets or highways.
    - b. Remove spillage and sweep, wash, or otherwise clean project, streets, and highways.
  - 2. Dust Control -
    - a. Take precautions necessary to prevent dust nuisance, both on-site and adjacent to public and private properties.
    - b. Correct or repair damage caused by dust.
  - 3. Erosion Control -
    - a. Take precautions necessary to prevent erosion and transportation of soil downstream, to adjacent properties, and into on-site or off-site drainage systems.

- b. Develop, install, and maintain an erosion control plan if required by law.
  - c. Repair and correct damage caused by erosion.
- 4. Protect site from fire caused by welding, cutting, smoking, or other sources of ignition.
- B. If specified precautions are not taken or corrections and repairs made promptly, Owner may take such steps as may be deemed necessary and deduct costs of such from monies due to Contractor. Such action or lack of action on Owner's part does not relieve Contractor from responsibility for proper protection of the Work.
- C. Fees
  - 1. Contractor shall be responsible for all off site street cut fees, encroachment permit fees, and bonding associated with the construction of the proposed facility.

### 3.3 REPAIR / RESTORATION

- A. Adjust existing covers, boxes, and vaults to grade.
- B. Replace broken or damaged covers, boxes, and vaults.
- C. Independently confirm size, location, and number of covers, boxes, and vaults which require adjustment.

### 3.4 FIELD QUALITY CONTROL

- A. Notify Architect 48 hours prior to performing excavation or fill work.
- B. If work has been interrupted by weather, scheduling, or other reason, notify Architect 24 hours minimum prior to intended resumption of grading or compacting.
- C. Owner reserves right to require additional testing to re-affirm suitability of completed work including compacted soils which have been exposed to adverse weather conditions.

END OF SECTION 310700

## **SECTION 311000 - SITE CLEARING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes the following:
  - 1. Removing concrete, asphalt and fencing as indicated on demolition plan.
  - 2. Removing above- and below-grade site improvements.
  - 3. Temporary erosion and sedimentation control measures.
- B. Related Sections include the following:
  - 1. Division 01 Section "Temporary Facilities and Controls" for temporary utilities, temporary construction and support facilities, temporary security, protection facilities, and temporary erosion and sedimentation control procedures.
  - 2. Division 02 Section "Structure Demolition" for demolition of structures, and site improvements.
  - 3. Division 31 Section "Earth Moving" for soil materials, excavating, backfilling, and site grading.

#### **1.3 MATERIAL OWNERSHIP**

- A. Except for stripped topsoil or other materials indicated to remain Owner's property, cleared materials shall become Contractor's property and shall be removed from Project site.

#### **1.4 SUBMITTALS**

- A. Photographs or videotape, sufficiently detailed, of existing conditions of trees and plantings, adjoining construction, and site improvements that might be misconstrued as damage caused by site clearing.
- B. Record drawings, according to Division 01 Section "Project Record Documents," identifying and accurately locating capped utilities and other subsurface structural, electrical, and mechanical conditions.

## 1.5 QUALITY ASSURANCE

- A. Pre-installation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

## 1.6 PROJECT CONDITIONS

- A. Traffic: Minimize interference with adjoining roads, streets, walks, and other adjacent occupied or used facilities during site-clearing operations.
  - 1. Do not close or obstruct streets, walks, or other adjacent occupied or used facilities without permission from Owner and authorities having jurisdiction.
  - 2. Provide alternate routes around closed or obstructed traffic ways if required by authorities having jurisdiction.
- B. Improvements on Adjoining Property: Authority for performing site clearing indicated on property adjoining Owner's property will be obtained by Owner before award of Contract.
  - 1. Do not proceed with work on adjoining property until directed by Architect.
- C. Salvable Improvements: Carefully remove items indicated to be salvaged and store on Owner's premises where indicated.
- D. Utility Locator Service: Contractor is to notify and pay for utility locator service for area where Project is located before site clearing.
- E. Do not commence site clearing operations until temporary erosion and sedimentation control measures are in place.

## PART 2 - PRODUCTS

### 2.1 SOIL MATERIALS

- A. Satisfactory Soil Materials: Requirements for satisfactory soil materials are specified in Division 31 Section "Earth Moving."
  - 1. Obtain approved borrow soil materials off-site when satisfactory soil materials are not available on-site.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Protect and maintain benchmarks and survey control points from disturbance during construction.

- B. Protect existing site improvements to remain from damage during construction.
  - 1. Restore damaged improvements to their original condition, as acceptable to Owner.

### 3.2 TEMPORARY EROSION AND SEDIMENTATION CONTROL

- A. Provide temporary erosion and sedimentation control measures to prevent soil erosion and discharge of soil-bearing water runoff or airborne dust to adjacent properties and walkways, according to requirements of authorities having jurisdiction, sediment and erosion control Drawings, a sediment and erosion control plan, specific to the site, that complies with EPA 832/R-92-005 or requirements of authorities having jurisdiction, whichever is more stringent.
- B. Inspect, repair, and maintain erosion and sedimentation control measures during construction until permanent vegetation has been established.
- C. Remove erosion and sedimentation controls and restore and stabilize areas disturbed during removal.

### 3.3 UTILITIES

- A. Owner will arrange for disconnecting and sealing indicated utilities that serve existing structures before site clearing, when requested by Contractor.
  - 1. Verify that utilities have been disconnected and capped before proceeding with site clearing.
- B. Locate, identify, disconnect, and seal or cap off utilities indicated to be removed.
  - 1. Arrange with utility companies to shut off indicated utilities.
  - 2. Owner will arrange to shut off indicated utilities when requested by Contractor.
- C. Existing Utilities: Do not interrupt utilities serving facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary utility services according to requirements indicated:
  - 1. Notify Architect not less than two days in advance of proposed utility interruptions.
  - 2. Do not proceed with utility interruptions without Architect's written permission.
- D. Excavate for and remove underground utilities indicated to be removed.
- E. Removal of underground utilities is included in Division 21, Division 22, Division 26, Division 27, and Division 28 Sections covering site utilities.

### 3.4 SITE IMPROVEMENTS

- A. Remove existing above-grade and below-grade improvements as indicated and as necessary to facilitate new construction. Refer to project plans for improvements to be abandoned in place.
- B. Remove slabs, paving, curbs, gutters, and aggregate base as indicated.
  - 1. Unless existing full-depth joints coincide with line of demolition, neatly saw-cut length of existing pavement to remain before removing existing pavement. Saw-cut faces vertically.
  - 2. Paint cut ends of steel reinforcement in concrete to remain to prevent corrosion.

### 3.5 DISPOSAL

- A. Disposal: Remove surplus soil material, unsuitable topsoil, obstructions, demolished materials, and waste materials including trash and debris, and legally dispose of them off Owner's property.
  - 1. Separate recyclable materials produced during site clearing from other non-recyclable materials. Store or stockpile without intermixing with other materials and transport them to recycling facilities.

END OF SECTION 311000

## **SECTION 312000 - EARTH MOVING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
- B. Refer to the Geotechnical Report Memorandum Job No. 0436-001-06 by GSH Geotechnical Consultants, Inc. dated December 12, 2006 for additional grading requirements.

#### **1.2 SUMMARY**

- A. This Section includes the following:
  - 1. Preparing sub-grades for retaining walls, stairs and landscaping.
  - 2. Excavating and backfilling trenches for buried electrical utilities and pits for buried utility structures.
- B. Related Sections include the following:
  - 1. Division 01 Section Construction Progress Documentation and Photographic Documentation for recording pre-excavation and earthwork progress.
  - 2. Division 01 Section "Temporary Facilities and Controls" for temporary controls, utilities, and support facilities.
  - 3. Divisions 26 and 27 Sections for installing underground electrical utilities and buried electrical structures.
  - 4. Division 31 Section "Site Clearing" for temporary erosion and sedimentation control measures, site stripping, grubbing, stripping and stockpiling topsoil, and removal of above-grade and below-grade improvements and utilities.
  - 5. Division 32 Section for finish grading, including placing retaining walls and concrete for stairs and mow strip.
  - 6. Division 33 Section for installing underground utilities.

#### **1.3 UNIT PRICES**

- A. Unit prices for earthwork are included in Division 01 Section "Unit Prices."
- B. Quantity allowances for earthwork are included in Division 01 Section "Allowances."

#### **1.4 DEFINITIONS**

- A. Backfill: Soil material or controlled low-strength material used to fill an excavation.



1. Initial Backfill: Backfill placed beside and over pipe in a trench, including haunches to support sides of pipe.
  2. Final Backfill: Backfill placed over initial backfill to fill a trench.
- B. Base Course: Course placed between the subbase course and hot-mix asphalt paving and post tension concrete tennis courts..
- C. Bedding Course: Course placed over the excavated subgrade in a trench before laying pipe.
- D. Borrow Soil: Satisfactory soil imported from off-site for use as fill or backfill.
- E. Drainage Course: 1-1/2-inch minus washed gravel or crushed stone course around perforated collector pipe.
- F. Drain Rock: Clean washed gravel, 3/4-inch minis placed on top of geofabric, PVC liner and compacted road base and under crusher course. This part of drainage layer that removes water from “future” artificial turf.
- G. Excavation: Removal of material encountered above subgrade elevations and to lines and dimensions indicated.
1. Authorized Additional Excavation: Excavation below subgrade elevations or beyond indicated lines and dimensions as directed by Architect. Authorized additional excavation and replacement material will be paid for according to Contract provisions for unit prices and changes in the work.
  2. Bulk Excavation: Excavation more than 10-feet in width and more than 30-feet in length.
  3. Unauthorized Excavation: Excavation below subgrade elevations or beyond indicated lines and dimensions without direction by Architect. Unauthorized excavation, as well as remedial work directed by Architect, shall be without additional compensation.
- H. Fill: Soil materials used to raise existing grades.
- I. Structures: Slabs, curbs, and electrical appurtenances, or other man-made stationary features constructed above or below the ground surface.
- J. Subbase Course: Course placed between the subgrade and base course for hot-mix asphalt pavement, or course placed between the subgrade and a cement concrete pavement or a cement concrete or hot-mix asphalt walk.
- K. Subgrade: Surface or elevation remaining after completing excavation, or top surface of a fill or backfill immediately below subbase, drainage fill, or topsoil materials.
- L. Utilities: On-site underground pipes, conduits, ducts, and cables, as well as underground services within buildings.
- 1.5 SUBMITTALS
- A. Product Data: For the following:

1. Each type of plastic warning tape.
  2. Controlled low-strength material, including design mixture.
- B. Material Test Reports: From a qualified testing agency indicating and interpreting test results for compliance of the following with requirements indicated:
1. Classification according to ASTM D 2487 of each on-site and borrow soil material proposed for fill and backfill.
  2. Laboratory compaction curve according to ASTM D698 or ASTM D1557 for each on-site and borrow soil material proposed for fill and backfill.
- C. Blasting Plan: Not Allowed
- D. Pre-excavation Photographs or Videotape: Show existing conditions of adjoining construction and site improvements, including finish surfaces, that might be misconstrued as damage caused by earthwork operations. Submit before earthwork begins.

## 1.6 QUALITY ASSURANCE

- A. Geotechnical Testing Agency Qualifications: An independent testing agency qualified according to ASTM E 329 to conduct soil materials and rock-definition testing, as documented according to ASTM D 3740 and ASTM E 548.
- B. Pre-excavation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

## 1.7 PROJECT CONDITIONS

- A. Existing Utilities: Do not interrupt utilities serving facilities occupied by Owner or others unless permitted in writing by Architect and then only after arranging to provide temporary utility services according to requirements indicated.
1. Notify Architect not less than two days in advance of proposed utility interruptions.
  2. Do not proceed with utility interruptions without Architect's written permission.
  3. Contact utility-locator service for area where Project is located before excavating.
- B. Demolish and completely remove from site existing underground utilities indicated to be removed. Coordinate with utility companies to shut off services if lines are active.

## PART 2 - PRODUCTS

### 2.1 SOIL MATERIALS

- A. General: Provide borrow soil materials when sufficient satisfactory soil materials are not available from excavations.

- B. Satisfactory Soils: ASTM D 2487 Soil Classification Groups GW, GP, GM, SW, SP, and SM or AASHTO M 145 Soil Classification Groups A-1, A-2-4, A-2-5, and A-3, or a combination of these groups; free of rock or gravel larger than 3-inches in any dimension, debris, waste, frozen materials, vegetation, and other deleterious matter. Native rock crushed to meet the above requirements and free from significant porosity may also be used as satisfactory soils.
- C. Unsatisfactory Soils: Soil Classification Groups GC, SC, CL, ML, OL, CH, MH, OH, and PT according to ASTM D 2487 or A-2-6, A-2-7, A-4, A-5, A-6, and A-7 according to AASHTO M 145, or a combination of these groups.
  - 1. Unsatisfactory soils also include satisfactory soils not maintained within 2 percent of optimum moisture content at time of compaction.
- D. Subbase Material: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, and natural or crushed sand; ASTM D 2940; with at least 90 percent passing a 1-1/2-inch sieve and not more than 12 percent passing a No. 200 sieve.
- E. Aggregate Base Course: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, crushed concrete and natural or crushed sand; ASTM D 2940; with at least 95 percent passing a 1-inch sieve and not more than 15 percent passing a No. 200 sieve. Sand Equivalent of no less than 35.
- F. Engineered Fill: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, and natural or crushed sand; ASTM D 2940; with at least 90 percent passing a 1-1/2-inch sieve and not more than 8 percent passing a No. 200 sieve. (Cannot be straight sand).
- G. Bedding Course: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, and natural or crushed sand; ASTM D 2940; except with 100 percent passing a 3/4-inch sieve and not more than 8 percent passing a No. 200 sieve.
- H. Drainage Course (around perforated pipe): Narrowly graded mixture of washed or crushed stone, or crushed or uncrushed gravel; ASTM D 448; coarse-aggregate grading Size 57; with 100 percent passing a 1-1/2-inch sieve and 0 to 5 percent passing a No. 8 sieve.

## 2.2 CONTROLLED LOW-STRENGTH MATERIAL

- A. Controlled Low-Strength Material: Low-density, self-compacting, flowable concrete material as follows:
  - 1. Portland Cement: ASTM C 150, Type II.
  - 2. Fly Ash: ASTM C 618, Class C or F.
  - 3. Normal-Weight Aggregate: ASTM C 33, 3/4-inch to 3/8-inch nominal maximum aggregate size.
  - 4. Foaming Agent: ASTM C 869.
  - 5. Water: ASTM C 94/C 94M.
  - 6. Air-Entraining Admixture: ASTM C 260.
- B. Produce low-density, controlled low-strength material with the following physical properties:

1. As-Cast Unit Weight: 30 to 36 lb/cu. ft. at point of placement, when tested according to ASTM C 138/C 138M.
2. Compressive Strength: 80 psi , when tested according to ASTM C 495.

## 2.3 ACCESSORIES

- A. Warning Tape: Acid- and alkali-resistant polyethylene film warning tape manufactured for marking and identifying underground utilities, 6 inches wide and 4 mils thick, continuously inscribed with a description of the utility; colored as follows:
- B. Detectable Warning Tape: Acid- and alkali-resistant polyethylene film warning tape manufactured for marking and identifying underground utilities, a minimum of 6 inches wide and 4 mils thick, continuously inscribed with a description of the utility, with metallic core encased in a protective jacket for corrosion protection, detectable by metal detector when tape is buried up to 30 inches deep; colored as follows when required by utility purveyor:
  1. Red: Electric.
  2. Yellow: Gas, oil, steam, and dangerous materials.
  3. Orange: Telephone and other communications.
  4. Blue: Water systems.
  5. Green: Sewer systems.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, undermining, washout, and other hazards created by earthwork operations.
- B. Preparation of subgrade for earthwork operations including removal of vegetation, topsoil, debris, obstructions, and deleterious materials from ground surface is specified in Division 31 Section "Site Clearing."
- C. Protect and maintain erosion and sedimentation controls, which are specified in Division 31 Section "Site Clearing," during earthwork operations.
- D. Provide protective insulating materials to protect subgrades and foundation soils against freezing temperatures or frost.

### 3.2 DEWATERING

- A. Prevent surface water and ground water from entering excavations, from ponding on prepared subgrades, and from flooding Project site and surrounding area.

- B. Protect subgrades from softening, undermining, washout, and damage by rain or water accumulation.
  - 1. Reroute surface water runoff away from excavated areas. Do not allow water to accumulate in excavations. Do not use excavated trenches as temporary drainage ditches.
  - 2. Install a dewatering system to keep subgrades dry and convey ground water away from excavations. Maintain until dewatering is no longer required.

### 3.3 EXPLOSIVES – Not Allowed

### 3.4 EXCAVATION, GENERAL

- A. Unclassified Excavation: Excavate to subgrade elevations regardless of the character of surface and subsurface conditions encountered. Unclassified excavated materials may include rock, soil materials, and obstructions. No changes in the Contract Sum or the Contract Time will be authorized for rock excavation or removal of obstructions.
  - 1. If excavated materials intended for fill and backfill include unsatisfactory soil materials and rock, replace with satisfactory soil materials.
  - 2. Remove rock to lines and grades indicated to permit installation of permanent construction without exceeding the following dimensions:
    - a. 24 inches outside of concrete forms other than at footings.
    - b. 12 inches outside of concrete forms at footings.
    - c. 6 inches outside of minimum required dimensions of concrete cast against grade.
    - d. Outside dimensions of concrete walls indicated to be cast against rock without forms or exterior waterproofing treatments.
    - e. 6 inches beneath bottom of concrete slabs on grade.
    - f. 6 inches beneath pipe in trenches, and the greater of 24 inches wider than pipe or 42 inches wide.

### 3.5 EXCAVATION FOR STRUCTURES

- A. Excavate to indicated elevations and dimensions within a tolerance of plus or minus 1 inch. If applicable, extend excavations a sufficient distance from structures for placing and removing concrete formwork, for installing services and other construction, and for inspections.
  - 1. Excavations for Footings and Foundations: Do not disturb bottom of excavation. Excavate by hand to final grade just before placing concrete reinforcement. Trim bottoms to required lines and grades to leave solid base to receive other work.
  - 2. Excavation for Underground Basins, Vaults or Electrical Utility Structures: Excavate to elevations and dimensions indicated within a tolerance of plus or minus 1 inch. Do not disturb bottom of excavations intended as bearing surfaces.

### 3.6 EXCAVATION FOR WALKS AND PAVEMENTS

- A. Excavate surfaces under walks and pavements to indicated lines, cross sections, elevations, and subgrades.

### 3.7 EXCAVATION FOR UTILITY TRENCHES

- A. Excavate trenches to indicated gradients, lines, depths, and elevations.
  - 1. Excavate trenches to allow installation of top of pipe below frost line.
- B. Excavate trenches to uniform widths to provide the following clearance on each side of pipe or conduit. Excavate trench walls vertically from trench bottom to 12 inches higher than top of pipe or conduit, unless otherwise indicated.
  - 1. Clearance: 12 inches each side of pipe or conduit.
- C. Trench Bottoms: Excavate and shape trench bottoms to provide uniform bearing and support of pipes and conduit. Shape subgrade to provide continuous support for bells, joints, and barrels of pipes and for joints, fittings, and bodies of conduits. Remove projecting stones and sharp objects along trench subgrade.
  - 1. For pipes and conduit less than 6 inches in nominal diameter and flat-bottomed, multiple-duct conduit units, hand-excavate trench bottoms and support pipe and conduit on an undisturbed subgrade.
  - 2. For pipes and conduit 6 inches or larger in nominal diameter, shape bottom of trench to support bottom 90 degrees of pipe circumference. Fill depressions with tamped sand backfill.
  - 3. Excavate trenches 6 inches deeper than elevation required in rock or other unyielding bearing material to allow for bedding course.

### 3.8 SUBGRADE INSPECTION

- A. Notify Architect when excavations have reached required subgrade.
- B. If Architect determines that unsatisfactory soil is present, continue excavation and replace with compacted backfill or fill material as directed.
- C. Proof-roll subgrade below the building slabs and pavements with heavy pneumatic-tired equipment to identify soft pockets and areas of excess yielding. Do not proof-roll wet or saturated subgrades.
  - 1. Completely proof-roll subgrade in one direction, repeating proof-rolling in direction perpendicular to first direction. Limit vehicle speed to 3 mph.
  - 2. Proof-roll with a loaded 10-wheel, tandem-axle dump truck weighing not less than 15 tons or vehicle with similar unit axle weight.
  - 3. Excavate soft spots, unsatisfactory soils, and areas of excessive pumping or rutting, as determined by Architect, and replace with compacted backfill or fill as directed.

- D. Authorized additional excavation and replacement material will be paid for according to Contract provisions for unit prices and changes in the Work.
- E. Reconstruct subgrades damaged by freezing temperatures, frost, rain, accumulated water, or construction activities, as directed by Architect, without additional compensation.

### 3.9 UNAUTHORIZED EXCAVATION

- A. Fill unauthorized excavation under foundations or wall footings by extending bottom elevation of concrete foundation or footing to excavation bottom, without altering top elevation. Lean concrete fill, with 28-day compressive strength of 2500 psi, may be used when approved by Architect.
  - 1. Fill unauthorized excavations under other construction or utility pipe as directed by Architect.

### 3.10 STORAGE OF SOIL MATERIALS

- A. Stockpile borrow soil materials and excavated satisfactory soil materials without intermixing. Place, grade, and shape stockpiles to drain surface water. Cover to prevent windblown dust.
  - 1. Stockpile soil materials away from edge of excavations.

### 3.11 BACKFILL

- A. Place and compact backfill in excavations promptly, but not before completing the following:
  - 1. Construction below finish grade including, where applicable subdrainage.
  - 2. Surveying locations of underground utilities for Record Documents.
  - 3. Testing and inspecting underground utilities.
  - 4. Removing concrete formwork.
  - 5. Removing trash and debris.
  - 6. Removing temporary shoring and bracing, and sheeting.
  - 7. Installing permanent or temporary horizontal bracing on horizontally supported walls.
- B. Place backfill on subgrades free of mud, frost, snow, or ice.

### 3.12 UTILITY TRENCH BACKFILL

- A. Place backfill on subgrades free of mud, frost, snow, or ice.
- B. Place and compact bedding course on trench bottoms and where indicated. Shape bedding course to provide continuous support for bells, joints, and barrels of pipes and for joints, fittings, and bodies of conduits.

- C. Backfill trenches excavated under footings and within 18 inches of bottom of footings with satisfactory soil; fill with concrete to elevation of bottom of footings. Concrete is specified in Division 03 Section "Cast-in-Place Concrete."
- D. Provide 4-inch- thick, concrete-base slab support for piping or conduit less than 12 inches below surface of roadways. After installing and testing, completely encase piping or conduit in a minimum of 4 inches of concrete before backfilling or placing roadway subbase.
- E. Place and compact initial backfill of subbase material or satisfactory soil, free of particles larger than 1 inch in any dimension, to a height of 12 inches over the utility pipe or conduit.
  - 1. Carefully compact initial backfill under pipe haunches and compact evenly up on both sides and along the full length of utility piping or conduit to avoid damage or displacement of piping or conduit. Coordinate backfilling with utilities testing.
- F. Controlled Low-Strength Material: Place initial backfill of controlled low-strength material to a height of 12 inches over the utility pipe or conduit.
- G. Backfill voids with satisfactory soil while installing and removing shoring and bracing.
- H. Place and compact final backfill of satisfactory soil to final subgrade elevation.
- I. Controlled Low-Strength Material: Place final backfill of controlled low-strength material to final subgrade elevation.
- J. Install warning tape directly above utilities, 12 inches below finished grade, except 6 inches below subgrade under pavements and slabs.

### 3.13 SOIL FILL

- A. Plow, scarify, bench, or break up sloped surfaces steeper than 1 vertical to 4 horizontal so fill material will bond with existing material.
- B. Place and compact fill material in layers to required elevations as follows:
  - 1. Under walks and pavements, use satisfactory soil material.
  - 2. Under steps and ramps, use engineered fill.
  - 3. Under footings and foundations, use engineered fill.
- C. Place soil fill on subgrades free of mud, frost, snow, or ice.

### 3.14 SOIL MOISTURE CONTROL

- A. Uniformly moisten or aerate subgrade and each subsequent fill or backfill soil layer before compaction to within 2 percent of optimum moisture content.
  - 1. Do not place backfill or fill soil material on surfaces that are muddy, frozen, or contain frost or ice.



2. Remove and replace, or scarify and air dry otherwise satisfactory soil material that exceeds optimum moisture content by 2 percent and is too wet to compact to specified dry unit weight.

### 3.15 COMPACTION OF SOIL BACKFILLS AND FILLS

- A. Place backfill and fill soil materials in layers not more than 12-inches in loose depth for material compacted by heavy compaction equipment, and not more than 4 inches in loose depth for material compacted by hand-operated tampers. Reduce loose depths as needed to achieve required compactions.
- B. Place backfill and fill soil materials evenly on all sides of structures to required elevations, and uniformly along the full length of each structure.
- C. Compact soil materials to not less than the following percentages of maximum dry unit weight according to ASTM D 698 or ASTM D 1557:
  1. Paved Areas: Compact top 12" of subgrade and each layer of backfill or fill material at 95% maximum dry density for cohesive material or 92% relative dry density for cohesionless material. Scarify and moisture condition to within 2% of optimum moisture and recompact subgrade.
  2. Under walkways, scarify and recompact top 6 inches below subgrade and compact each layer of backfill or fill soil material at 95 percent.
  3. For utility trenches, compact each layer of initial and final backfill soil material at 85 percent if in landscaping areas or 95 percent if under structures, pavements, or walks.

### 3.16 GRADING

- A. General: Uniformly laser grade areas within contract limits under this section, including adjacent transition areas, free of irregular surface changes. Smooth finished surface within specified tolerances, compact with uniform levels or slopes between points where elevations are indicated, or between such points and existing grades.
  1. Provide a smooth transition between adjacent existing grades and new grades.
  2. Cut out soft spots, fill low spots, and trim high spots to comply with required surface tolerances.
- B. Site Grading: Slope grades to direct water away from buildings and to prevent ponding. Finish subgrades to required elevations within the following tolerances:
  1. Walks: Plus or minus 1 inch
  2. Pavements: Plus or minus 1/2 inch
- C. Finish surfaces free from irregular surface changes, and as follows:
  1. Walks: Shape surface of areas under walks to line, grade and cross-section, with finish surface not more than 1/4" above or below required subgrade elevation.

2. Pavements: Shape surface of areas under pavement to line, grade and cross-section, with finish surface not more than 1/4" above or below required subgrade elevation. Provide final grades within a tolerance of 1/4" when tested with a 10' straightedge.
3. Compaction: After grading, compact subgrade surfaces to the depth and indicated percentage of maximum or relative density for each area classification.

### 3.17 SUBBASE AND BASE COURSES

- A. Place subbase and base course on subgrades free of mud, frost, snow, or ice.
- B. On prepared subgrade, place subbase and base course under pavements and walks as follows:
  1. Place base course material over subbase course under hot-mix asphalt pavement and post tension concrete..
  2. Shape subbase and base course to required crown elevations and cross-slope grades.
  3. Place subbase and base course 6 inches or less in compacted thickness in a single layer.
  4. Place subbase and base course that exceeds 6 inches in compacted thickness in layers of equal thickness, with no compacted layer more than 6 inches thick or less than 3 inches thick.
  5. Compact subbase and base course at optimum moisture content to required grades, lines, cross sections, and thickness to not less than 95 percent of maximum dry unit weight according to ASTM D 698 or ASTM D 1557.

### 3.18 FIELD QUALITY CONTROL

- A. Testing Agency: Owner will engage a qualified independent geotechnical engineering testing agency to perform field quality-control testing.
- B. Allow testing agency to inspect and test subgrades and each fill or backfill layer. Proceed with subsequent earthwork only after test results for previously completed work comply with requirements.
- C. Testing agency will test compaction of soils in place according to ASTM D 1556, ASTM D 2167, ASTM D 2922, and ASTM D 2937, as applicable. Tests will be performed at the following locations and frequencies:
  1. Paved Areas: At subgrade and at each compacted fill and backfill layer, at least 1 test for every 2000 sq. ft. or less of paved area or building slab, but in no case fewer than 3 tests.
  2. Trench Backfill: At each compacted initial and final backfill layer, at least 1 test for each 150 feet or less of trench length, but no fewer than 2 tests.
- D. When testing agency reports that subgrades, fills, or backfills have not achieved degree of compaction specified, scarify and moisten or aerate, or remove and replace soil to depth required; recompact and retest until specified compaction is obtained.

3.19 PROTECTION

- A. Protecting Graded Areas: Protect newly graded areas from traffic, freezing, and erosion. Keep free of trash and debris.
- B. Repair and reestablish grades to specified tolerances where completed or partially completed surfaces become eroded, rutted, settled, or where they lose compaction due to subsequent construction operations or weather conditions.
  - 1. Scarify or remove and replace soil material to depth as directed by Architect; reshape and recompact.
- C. Where settling occurs before Project correction period elapses, remove finished surfacing, backfill with additional soil material, compact, and reconstruct surfacing.
  - 1. Restore appearance, quality, and condition of finished surfacing to match adjacent work, and eliminate evidence of restoration to greatest extent possible.

3.20 DISPOSAL OF SURPLUS AND WASTE MATERIALS

- A. Disposal: Remove surplus satisfactory soil and waste material, including unsatisfactory soil, trash, and debris, and legally dispose of it off Owner's property.
- B. Disposal: Transport surplus satisfactory soil to designated storage areas on Owner's property. Stockpile or spread soil as directed by Architect.
  - 1. Remove waste material, including unsatisfactory soil, trash, and debris, and legally dispose of it off Owner's property.

END OF SECTION 312000

THIS PAGE LEFT INTENTIONALLY BLANK

## **SECTION 315000 - EXCAVATION SUPPORT AND PROTECTION**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section includes temporary excavation support and protection systems.
- B. Related Sections:
  - 1. Division 01 Section "Construction Progress Documentation and Photographic Documentation" for recording preexisting conditions and excavation support and protection system progress.
  - 2. Division 01 Section "Temporary Facilities and Controls" for temporary utilities and support facilities.
  - 3. Division 31 Section "Dewatering" for dewatering system for excavations.

#### **1.3 PERFORMANCE REQUIREMENTS**

- A. Design, furnish, install, monitor, and maintain excavation support and protection system capable of supporting excavation sidewalls and of resisting soil and hydrostatic pressure and superimposed and construction loads, as needed.
  - 1. Delegated Design: Design excavation support and protection system, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
  - 2. Prevent surface water from entering excavations by grading, dikes, or other means.
  - 3. Install excavation support and protection systems without damaging existing buildings, structures, and site improvements adjacent to excavation.
  - 4. Monitor vibrations, settlements, and movements.

#### **1.4 SUBMITTALS**

- A. Shop Drawings: For excavation support and protection system.
- B. Delegated-Design Submittal: For excavation support and protection system indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.

- C. Coordinate first paragraph below with qualification requirements in Division 01 Section "Quality Requirements" Qualification Data: For qualified professional engineer.
- D. Other Informational Submittals:
  - 1. Photographs or Videotape: Show existing conditions of adjacent construction and site improvements that might be misconstrued as damage caused by the absence of, the installation of, or the performance of excavation support and protection systems. Submit before Work begins.
  - 2. Record Drawings: Identifying and locating capped utilities and other subsurface structural, electrical, or mechanical conditions.
    - a. Note locations and capping depth of wells and well points.

## 1.5 QUALITY ASSURANCE

- A. Preinstallation Conference: Conduct conference at Project site.
  - 1. Review methods and procedures related to excavation support and protection system including, but not limited to, the following:
    - a. Existing utilities and subsurface conditions.
    - b. Proposed excavations.
    - c. Proposed equipment.
    - d. Monitoring of excavation support and protection system.
    - e. Working area location and stability.
    - f. Coordination with waterproofing.
    - g. Abandonment or removal of excavation support and protection system.

## 1.6 PROJECT CONDITIONS

- A. Interruption of Existing Utilities: Do not interrupt any utility serving facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary utility according to requirements indicated:
  - 1. Notify Architect no fewer than two days in advance of proposed interruption of utility.
  - 2. Do not proceed with interruption of utility without Architect's, Construction Manager's, and Owner's written permission.
- B. Survey Work: Engage a qualified land surveyor or professional engineer to survey adjacent existing buildings, structures, and site improvements; establish exact elevations at fixed points to act as benchmarks. Clearly identify benchmarks and record existing elevations.
  - 1. During installation of excavation support and protection systems, regularly resurvey benchmarks, maintaining an accurate log of surveyed elevations and positions for comparison with original elevations and positions. Promptly notify Architect if changes in elevations or positions occur or if cracks, sags, or other damage is evident in adjacent construction.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. General: Provide materials that are either new or in serviceable condition.
- B. Cast-in-Place Concrete: ACI 301, of compressive strength required for application.
- C. Reinforcing Bars: ASTM A 615/A 615M, Grade 60, deformed.
- D. Tiebacks: Steel bars, ASTM A 722/A 722M.
- E. Tiebacks: Steel strand, ASTM A 416/A 416M.

## PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, undermining, washout, and other hazards that could develop during excavation support and protection system operations.
  - 1. Shore, support, and protect utilities encountered.
- B. Install excavation support and protection systems to ensure minimum interference with roads, streets, walks, and other adjacent occupied and used facilities.
  - 1. Do not close or obstruct streets, walks, or other adjacent occupied or used facilities without permission from Owner and authorities having jurisdiction. Provide alternate routes around closed or obstructed traffic ways if required by authorities having jurisdiction.
- C. Locate excavation support and protection systems clear of permanent construction so that forming and finishing of concrete surfaces are not impeded.
- D. Monitor excavation support and protection systems daily during excavation progress and for as long as excavation remains open. Promptly correct bulges, breakage, or other evidence of movement to ensure that excavation support and protection systems remain stable.
- E. Promptly repair damages to adjacent facilities caused by installing excavation support and protection systems.

### 3.2 REMOVAL AND REPAIRS

- A. Remove excavation support and protection systems when construction has progressed sufficiently to support excavation and bear soil and hydrostatic pressures. Remove in stages to avoid disturbing underlying soils or damaging structures, pavements, facilities, and utilities.
  - 1. Remove excavation support and protection systems to a minimum depth of 48 inches below overlaying construction and abandon remainder.
  - 2. Fill voids immediately with approved backfill compacted to density specified in Division 31 Section "Earth Moving."
  - 3. Repair or replace, as approved by Architect, adjacent work damaged or displaced by removing excavation support and protection systems.
- B. Leave excavation support and protection systems permanently in place.

END OF SECTION 315000



THIS PAGE LEFT INTENTIONALLY BLANK

## **SECTION 321313 CONCRETE PAVING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes exterior cement concrete pavement for the following:
  - 1. Mow strips
  - 2. Walkways.
  - 3. Tactile Walkway surfaces
- B. Related Sections include the following:
  - 1. Division 03 Section "Cast-in-Place Concrete" for general building applications of concrete.
  - 2. Division 31 Section "Earth Moving" for subgrade preparation, grading, and subbase course.
  - 3. Division 32 Section "Concrete Paving Joint Sealants" for joint sealants of joints in concrete pavement and at isolation joints of concrete pavement with adjacent construction.

#### **1.3 DEFINITIONS**

- A. Cementitious Materials: Portland cement alone or in combination with one or more of blended hydraulic cement, fly ash and other pozzolans, and ground granulated blast-furnace slag.

#### **1.4 SUBMITTALS**

- A. Product Data: For each type of manufactured material and product indicated.
- B. Design Mixtures: For each concrete pavement mixture. Include alternate mixture designs when characteristics of materials, Project conditions, weather, test results, or other circumstances warrant adjustments.
- C. Samples: 10-lb sample of exposed aggregate.
- D. Qualification Data: For manufacturer and testing agency.

- E. Material Test Reports: From a qualified testing agency indicating and interpreting test results for compliance of the following with requirements indicated, based on comprehensive testing of current materials:
  - 1. Aggregates. Include service record data indicating absence of deleterious expansion of concrete due to alkali-aggregate reactivity.
- F. Material Certificates: Signed by manufacturers certifying that each of the following materials complies with requirements:
  - 1. Cementitious materials.
  - 2. Steel reinforcement and reinforcement accessories.
  - 3. Fiber reinforcement.
  - 4. Admixtures.
  - 5. Curing compounds.
  - 6. Applied finish materials.
  - 7. Bonding agent or epoxy adhesive.
  - 8. Joint fillers.
- G. Field quality-control test reports.
- H. Minutes of preinstallation conference.

#### 1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer of ready-mixed concrete products who complies with ASTM C 94/C 94M requirements for production facilities and equipment.
  - 1. Manufacturer certified according to NRMCA's "Certification of Ready Mixed Concrete Production Facilities."
- B. Testing Agency Qualifications: An independent agency qualified according to ASTM C 1077 and ASTM E 329 for testing indicated, as documented according to ASTM E 548.
  - 1. Personnel conducting field tests shall be qualified as ACI Concrete Field Testing Technician, Grade 1, according to ACI CP-01 or an equivalent certification program.
- C. ACI Publications: Comply with ACI 301, "Specification for Structural Concrete," unless modified by requirements in the Contract Documents.
- D. Concrete Testing Service: Engage a qualified independent testing agency to perform material evaluation tests and to design concrete mixtures.
- E. Preinstallation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."
  - 1. Before submitting design mixtures, review concrete pavement mixture design and examine procedures for ensuring quality of concrete materials and concrete

pavement construction practices. Require representatives, including the following, of each entity directly concerned with concrete pavement, to attend conference:

- a. Contractor's superintendent.
- b. Independent testing agency responsible for concrete design mixtures.
- c. Ready-mix concrete producer.
- d. Concrete pavement subcontractor.

## 1.6 PROJECT CONDITIONS

- A. Traffic Control: Maintain access for vehicular and pedestrian traffic as required for other construction activities.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products specified.
  2. Products: Subject to compliance with requirements, provide one of the products specified.
  3. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.
  4. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

### 2.2 FORMS

- A. Form Materials: Plywood, metal, metal-framed plywood, or other approved panel-type materials to provide full-depth, continuous, straight, smooth exposed surfaces.
  1. Use flexible or curved forms for curves with a radius 100 feet or less.
- B. Form-Release Agent: Commercially formulated form-release agent that will not bond with, stain, or adversely affect concrete surfaces and will not impair subsequent treatments of concrete surfaces.

## 2.3 STEEL REINFORCEMENT (NO REINFORCEMENT USED FOR FLATWORK)

- A. Plain-Steel Welded Wire Reinforcement: ASTM A 185, fabricated from as-drawn steel wire into flat sheets.
- B. Deformed-Steel Welded Wire Reinforcement: ASTM A 497, flat sheet.
- C. Reinforcing Bars: ASTM A 615/A 615M, Grade 60; deformed.
- D. Steel Bar Mats: ASTM A 184/A 184M; with ASTM A 615/A 615M, Grade 60, deformed bars; assembled with clips.
- E. Plain Steel Wire: ASTM A 82.
- F. Deformed-Steel Wire: ASTM A 496.
- G. Joint Dowel Bars: Plain steel bars, ASTM A 615/A 615M, Grade 60. Cut bars true to length with ends square and free of burrs.
- H. Tie Bars: ASTM A 615/A 615M, Grade 60, deformed.
- I. Hook Bolts: ASTM A 307, Grade A, internally and externally threaded. Design hook-bolt joint assembly to hold coupling against pavement form and in position during concreting operations, and to permit removal without damage to concrete or hook bolt.
- J. Bar Supports: Bolsters, chairs, spacers, and other devices for spacing, supporting, and fastening reinforcing bars, welded wire reinforcement, and dowels in place. Manufacture bar supports according to CRSI's "Manual of Standard Practice" from steel wire, plastic, or precast concrete of greater compressive strength than concrete, and as follows:
  - 1. Equip wire bar supports with sand plates or horizontal runners where base material will not support chair legs.
  - 2. For epoxy-coated reinforcement, use epoxy-coated or other dielectric-polymer-coated wire bar supports.

## 2.4 CONCRETE MATERIALS

- A. Cementitious Material: Use the following cementitious materials, of the same type, brand, and source throughout the Project:
  - 1. Portland Cement and as specified in Division 3 except that for exterior concrete, the minimum compressive strength is 5000 psi at 28 days.
- B. Normal-Weight Aggregates: ASTM C 33, coarse aggregate, uniformly graded. Provide aggregates from a single source with documented service record data of at least 10 years' satisfactory service in similar pavement applications and service conditions using similar aggregates and cementitious materials.
  - 1. Maximum Coarse-Aggregate Size: 1 inch nominal.

2. Fine Aggregate: Free of materials with deleterious reactivity to alkali in cement.
- C. Exposed Aggregate: Selected, hard, and durable; washed; free of materials with deleterious reactivity to cement or that cause staining; from a single source, with gap-graded coarse aggregate as follows:
1. Aggregate Sizes: 3/4 to 1 inch nominal.
  2. Aggregate Source, Shape, and Color and as required by the architect.
- D. Water: ASTM C 94/C 94M.
- E. Air-Entraining Admixture: ASTM C 260.
- F. Chemical Admixtures: Provide admixtures certified by manufacturer to be compatible with other admixtures and to contain not more than 0.1 percent water-soluble chloride ions by mass of cementitious material.
1. Water-Reducing Admixture: ASTM C 494/C 494M, Type A.
  2. Retarding Admixture: ASTM C 494/C 494M, Type B.
  3. Water-Reducing and Retarding Admixture: ASTM C 494/C 494M, Type D.
  4. High-Range, Water-Reducing Admixture: ASTM C 494/C 494M, Type F.
  5. High-Range, Water-Reducing and Retarding Admixture: ASTM C 494/C 494M, Type G.
  6. Plasticizing and Retarding Admixture: ASTM C 1017/C 1017M, Type II.

## 2.5 CURING MATERIALS

- A. Absorptive Cover: AASHTO M 182, Class 2, burlap cloth made from jute or kenaf, weighing approximately 9 oz./sq. yd. dry.
- B. Moisture-Retaining Cover: ASTM C 171, polyethylene film or white burlap-polyethylene sheet.
- C. Water: Potable.
- D. Evaporation Retarder: Waterborne, monomolecular film forming; manufactured for application to fresh concrete.
1. Products:
    - a. Axim Concrete Technologies; Cimfilm.
    - b. Burke by Edeco; BurkeFilm.
    - c. ChemMasters; Spray-Film.
    - d. Conspec Marketing & Manufacturing Co., Inc.; Aquafilm.
    - e. Dayton Superior Corporation; Sure Film.
    - f. Euclid Chemical Company (The); Eucobar.
    - g. Kaufman Products, Inc.; Vapor Aid.
    - h. Lambert Corporation; Lambco Skin.
    - i. L&M Construction Chemicals, Inc.; E-Con.

- j. MBT Protection and Repair, ChemRex Inc.; Confilm.
- k. Meadows, W. R., Inc.; Sealtight Evapre.
- l. Metalcrete Industries; Waterhold.
- m. Nox-Crete Products Group, Kinsman Corporation; Monofilm.
- n. Sika Corporation, Inc.; SikaFilm.
- o. Symons Corporation; Finishing Aid.
- p. Vexcon Chemicals, Inc.; Certi-Vex EnvioAssist.

E. Clear Waterborne Membrane-Forming Curing Compound: ASTM C 309, Type 1, Class B.

- 1. Products:
  - a. Anti-Hydro International, Inc.; AH Curing Compound #2 DR WB.
  - b. Burke by Edoko; Aqua Resin Cure.
  - c. ChemMasters; Safe-Cure Clear.
  - d. Conspec Marketing & Manufacturing Co., Inc.; W.B. Resin Cure.
  - e. Dayton Superior Corporation; Day Chem Rez Cure (J-11-W).
  - f. Euclid Chemical Company (The); Kurez DR VOX.
  - g. Kaufman Products, Inc.; Thinfilm 420.
  - h. Lambert Corporation; Aqua Kure-Clear.
  - i. L&M Construction Chemicals, Inc.; L&M Cure R.
  - j. Meadows, W. R., Inc.; 1100 Clear.
  - k. Nox-Crete Products Group, Kinsman Corporation; Resin Cure E.
  - l. Symons Corporation; Resi-Chem Clear.
  - m. Tamms Industries Inc.; Horncure WB 30.
  - n. Unitex; Hydro Cure 309.
  - o. Vexcon Chemicals, Inc.; Certi-Vex Enviocure 100.

F. White Waterborne Membrane-Forming Curing Compound: ASTM C 309, Type 2, Class B.

- 1. Products:
  - a. Anti-Hydro International, Inc.; AH Curing Compound #2 WP WB.
  - b. Burke by Edoco; Resin Emulsion White.
  - c. ChemMasters; Safe-Cure 2000.
  - d. Conspec Marketing & Manufacturing Co., Inc.; W.B. Resin Cure.
  - e. Dayton Superior Corporation; Day-Chem White Pigmented Cure (J-10-W).
  - f. Euclid Chemical Company (The); Kurez VOX White Pigmented.
  - g. Kaufman Products, Inc.; Thinfilm 450.
  - h. Lambert Corporation; Aqua Kure-White.
  - i. L&M Construction Chemicals, Inc.; L&M Cure R-2.
  - j. Meadows, W. R., Inc.; 1200-White.
  - k. Symons Corporation; Resi-Chem White.
  - l. Tamms Industries, Inc.; Horncure 200-W.
  - m. Unitex; Hydro White.
  - n. Vexcon Chemicals, Inc.; Certi-Vex Enviocure White 100.

## 2.6 RELATED MATERIALS

- A. Expansion- and Isolation-Joint-Filler Strips: ASTM D 1751, asphalt-saturated cellulosic fiber or ASTM D 1752, cork or self-expanding cork.
- B. Color stain: Match Architect's sample or as selected by Architect from manufacturer's full range of stains.
- C. Slip-Resistive Aggregate Finish: Factory-graded, packaged, rustproof, nonglazing, abrasive aggregate of fused aluminum-oxide granules or crushed emery with emery aggregate containing not less than 50 percent aluminum oxide and not less than 20 percent ferric oxide; unaffected by freezing, moisture, and cleaning materials.
- D. Bonding Agent: ASTM C 1059, Type II, non-redispersible, acrylic emulsion or styrene butadiene.
- E. Epoxy Bonding Adhesive: ASTM C 881, two-component epoxy resin, capable of humid curing and bonding to damp surfaces, of class suitable for application temperature and of grade to requirements, and as follows:
  - 1. Types I and II, non-load bearing and types IV and V, load bearing, for bonding hardened or freshly mixed concrete to hardened concrete.
- F. Chemical Surface Retarder: Water-soluble, liquid-set retarder with color dye, for horizontal concrete surface application, capable of temporarily delaying final hardening of concrete to a depth of 1/8 to 1/4 inch.
  - 1. Products:
    - a. Burke by Edeco; True Etch Surface Retarder.
    - b. ChemMasters; Exposee.
    - c. Conspec Marketing & Manufacturing Co., Inc.; Delay S.
    - d. Euclid Chemical Company (The); Surface Retarder S.
    - e. Kaufman Products, Inc.; Expose.
    - f. Metacrete Industries; Surfard.
    - g. Nox-Crete Products Group, Kinsman Corporation; Crete-Nox TA.
    - h. Scofield, L. M. Company; Lithotex.
    - i. Sika Corporation, Inc.; Rugasol-S.
    - j. Vexcon Chemicals, Inc.; Certi-Vex Envioset.
- G. Pigmented Mineral Dry-Shake Hardener: Factory-packaged dry combination of portland cement, graded quartz aggregate, color pigments, and plasticizing admixture. Use color pigments that are finely ground, nonfading mineral oxides interground with cement.
  - 1. Products:
    - a. Conspec Marketing & Manufacturing Co., Inc.; Conshake 600 Colortone.
    - b. Dayton Superior Corporation; Quartz Tuff.
    - c. Euclid Chemical Company (The); Surfex.
    - d. Lambert Corporation; Colorhard.



- e. L&M Construction Chemicals, Inc.; Quartz Plate FF.
  - f. MBT Protection and Repair, ChemRex Inc.; Mastercron.
  - g. Metalcrete Industries; Floor Quartz.
  - h. Scofield, L. M. Company; Lithochrome Color Hardener.
  - i. Symons Corporation; Hard Top.
2. Color: Match Architect's sample or as selected by Architect from manufacturer's full range.

## 2.7 PAVEMENT MARKINGS

- A. Pavement-Marking Paint: Alkyd-resin type, lead and chromate free, ready mixed, complying with FS TT-P-115, Type I or II or AASHTO M 248, Type N or F.
  1. Color: White, Yellow, Blue. See Section 321216 for color locations.
- B. Pavement-Marking Paint: Latex, waterborne emulsion, lead and chromate free, ready mixed, complying with FS TT-P-1952, with drying time of less than 45 minutes.
  1. Color: White, Yellow, Blue. See Section 321216 for color locations.
- C. Glass Beads: AASHTO M 247, Type 1.

## 2.8 DETECTABLE WARNING TILES

- A. Cast-in-Place Detectable Warning Tiles: Accessible truncated-dome detectable warning tiles configured for setting flush in new concrete walkway surfaces, with slip-resistant surface treatment on domes and field of tile.
- B. Manufacturers :  
  
Cast Iron Panels as manufactured by  
Duralast EJCo  
Neenah Foundry  
US Foundry
  1. Color: Natural.
  2. Shapes and Sizes:
    - a. Rectangular panel, **24 by 24 inches, 24 by 30 inches and 24 by 36 inches** . to suit conditions
  3. Dome Spacing and Configuration: **Manufacturer's standard compliant spacing**
  4. Mounting:
    - a. Permanently embedded detectable warning tile

## 2.9 CONCRETE MIXTURES

- A. Prepare design mixtures, proportioned according to ACI 301, for each type and strength of normal-weight concrete determined by either laboratory trial mixes or field experience.
  - 1. Use a qualified independent testing agency for preparing and reporting proposed concrete mixture designs for the trial batch method.
- B. Proportion mixtures to provide normal-weight concrete with the following properties:
  - 1. Compressive Strength (28 Days): 5000 psi
  - 2. Maximum Water-Cementitious Materials Ratio at Point of Placement: 0.45
  - 3. Select slump limit from options in subparagraph below or revise to suit Project.
  - 4. Slump Limit: 4 inches, plus or minus 1 inch.
- C. Add air-entraining admixture at manufacturer's prescribed rate to result in normal-weight concrete at point of placement having an air content as follows:
  - 1. Air Content: 5-8 percent nominal maximum aggregate size.
- D. Limit water-soluble, chloride-ion content in hardened concrete to 0.15 percent by weight of cement.
- E. Chemical Admixtures: Use admixtures according to manufacturer's written instructions.
  - 1. Use water-reducing admixture, high-range, water-reducing admixture, high-range, water-reducing and retarding admixture, plasticizing, and retarding admixture in concrete, as required, for placement and workability.
  - 2. Specify admixtures as part of submittal. Verify that admixtures proposed do not adversely effect stained concrete and will not modify colors of stain.
  - 3. Coordinate acceptability of admixtures with architect.
- F. Cementitious Materials: Limit percentage, by weight, of cementitious materials other than portland cement according to ACI 301 requirements as follows:
  - 1. Fly Ash or Pozzolan: 25 percent.
  - 2. Ground Granulated Blast-Furnace Slag: 50 percent.
  - 3. Combined Fly Ash or Pozzolan, and Ground Granulated Blast-Furnace Slag: 50 percent, with fly ash or pozzolan not exceeding 25 percent.
- G. Synthetic Fiber: Uniformly disperse in concrete mix at manufacturer's recommended rate, but not less than 1.0 lb/cu. yd. where specified and approved in mix submittal.
- H. Color Stain: Add stain to concrete per manufacturers recommendations and to meet color required by architect and owner on areas of stained concrete.

## 2.10 CONCRETE MIXING

- A. Ready-Mixed Concrete: Measure, batch, and mix concrete materials and concrete according to ASTM C 94/C 94M. Furnish batch certificates for each batch discharged and used in the Work.
  - 1. When air temperature is between 85 deg F and 90 deg F, reduce mixing and delivery time from 1-1/2 hours to 75 minutes; when air temperature is above 90 deg F, reduce mixing and delivery time to 60 minutes.
- B. Project-Site Mixing: Measure, batch, and mix concrete materials and concrete according to ASTM C 94/C 94M. Mix concrete materials in appropriate drum-type batch machine mixer.
  - 1. For concrete mixes of 1 cu. yd. or smaller, continue mixing at least 1-1/2 minutes, but not more than 5 minutes after ingredients are in mixer, before any part of batch is released.
  - 2. For concrete mixes larger than 1 cu. yd., increase mixing time by 15 seconds for each additional 1 cu. yd.
  - 3. Provide batch ticket for each batch discharged and used in the Work, indicating Project identification name and number, date, mixture type, mixing time, quantity, and amount of water added.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine exposed subgrades and subbase surfaces for compliance with requirements for dimensional, grading, and elevation tolerances.
- B. Proof-roll prepared subbase surface below concrete pavements with heavy pneumatic-tired equipment to identify soft pockets and areas of excess yielding.
  - 1. Completely proof-roll subbase in one direction. Limit vehicle speed to 3 mph.
  - 2. Proof-roll with a loaded 10-wheel tandem-axle dump truck weighing not less than 15 tons or similar axel weight vehicle.
  - 3. Subbase with soft spots and areas of pumping or rutting exceeding depth of 1/2 inch require correction according to requirements in Division 31 Section "Earth Moving."
- C. Proceed with concrete pavement operations only after nonconforming conditions have been corrected and subgrade is ready to receive pavement.

### 3.2 PREPARATION

- A. Remove loose material from compacted subbase surface immediately before placing concrete.

### 3.3 EDGE FORMS AND SCREED CONSTRUCTION

- A. Set, brace, and secure edge forms, bulkheads, and intermediate screed guides for pavement to required lines, grades, and elevations. Install forms to allow continuous progress of work and so forms can remain in place at least 24 hours after concrete placement.
- B. Clean forms after each use and coat with form-release agent to ensure separation from concrete without damage.

### 3.4 STEEL REINFORCEMENT

- A. General: Comply with CRSI's "Manual of Standard Practice" for fabricating, placing, and supporting reinforcement.
- B. Clean reinforcement of loose rust and mill scale, earth, ice, or other bond-reducing materials.
- C. Arrange, space, and securely tie bars and bar supports to hold reinforcement in position during concrete placement. Maintain minimum cover to reinforcement.
- D. Install welded wire reinforcement in lengths as long as practicable. Lap adjoining pieces at least one full mesh, and lace splices with wire. Offset laps of adjoining widths to prevent continuous laps in either direction.
- E. Install fabricated bar mats in lengths as long as practicable. Handle units to keep them flat and free of distortions. Straighten bends, kinks, and other irregularities, or replace units as required before placement. Set mats for a minimum 2-inch overlap of adjacent mats.

### 3.5 JOINTS

- A. General: Form construction, isolation, and contraction joints and tool edgings true to line with faces perpendicular to surface plane of concrete. Construct transverse joints at right angles to centerline, unless otherwise indicated.
  - 1. When joining existing pavement, place transverse joints to align with previously placed joints, unless otherwise indicated.
- B. Construction Joints: Set construction joints at side and end terminations of pavement and at locations where pavement operations are stopped for more than one-half hour unless pavement terminates at isolation joints.
  - 1. Continue steel reinforcement across construction joints, unless otherwise indicated. Do not continue reinforcement through sides of pavement strips, unless otherwise indicated.
  - 2. Provide tie bars at sides of pavement strips where indicated.
  - 3. Butt Joints: Use bonding agent at joint locations where fresh concrete is placed against hardened or partially hardened concrete surfaces.
  - 4. Keyed Joints: Provide preformed keyway-section forms or bulkhead forms with keys, unless otherwise indicated. Embed keys at least 1-1/2 inches into concrete.

5. Doweled Joints: Install dowel bars and support assemblies at joints where indicated. Lubricate or asphalt-coat one-half of dowel length to prevent concrete bonding to one side of joint.
- C. Isolation Joints: Form isolation joints of preformed joint-filler strips abutting concrete curbs, catch basins, manholes, inlets, structures, walks, other fixed objects, and where indicated.
1. Locate expansion joints at intervals of 50 feet, unless otherwise indicated.
  2. Extend joint fillers full width and depth of joint.
  3. Terminate joint filler not less than 1/2 inch or more than 1 inch below finished surface if joint sealant is indicated.
  4. Place top of joint filler flush with finished concrete surface if joint sealant is not indicated.
  5. Furnish joint fillers in one-piece lengths. Where more than one length is required, lace or clip joint-filler sections together.
  6. Protect top edge of joint filler during concrete placement with metal, plastic, or other temporary preformed cap. Remove protective cap after concrete has been placed on both sides of joint.
- D. Contraction Joints: Form weakened-plane contraction joints, sectioning concrete into areas as indicated. Construct contraction joints for a depth equal to at least one-fourth of the concrete thickness, as follows:
1. Grooved Joints: Form contraction joints after initial floating by grooving and finishing each edge of joint with grooving tool to a 1/4-inch radius. Repeat grooving of contraction joints after applying surface finishes. Eliminate groover marks on concrete surfaces.
  2. Sawed Joints: Form contraction joints with power saws equipped with shatterproof abrasive or diamond-rimmed blades. Cut 1/8-inch-wide joints into concrete when cutting action will not tear, abrade, or otherwise damage surface and before developing random contraction cracks.
  3. Doweled Contraction Joints: Install dowel bars and support assemblies at joints where indicated. Lubricate or asphalt coat one-half of dowel length to prevent concrete bonding to one side of joint.
- E. Edging: Tool edges of pavement, gutters, curbs, and joints in concrete after initial floating with an edging tool to a 1/4-inch radius. Repeat tooling of edges after applying surface finishes. Eliminate tool marks on concrete surfaces.

### 3.6 CONCRETE PLACEMENT

- A. Inspection: Before placing concrete, inspect and complete formwork installation, steel reinforcement, and items to be embedded or cast in. Notify other trades to permit installation of their work.
- B. Remove snow, ice, or frost from subbase surface and reinforcement before placing concrete. Do not place concrete on frozen surfaces.

- C. Moisten subbase to provide a uniform dampened condition at time concrete is placed. Do not place concrete around manholes or other structures until they are at required finish elevation and alignment.
- D. Comply with ACI 301 requirements for measuring, mixing, transporting, and placing concrete.
- E. Do not add water to concrete during delivery or at Project site.
- F. Do not add water to fresh concrete after testing.
- G. Deposit and spread concrete in a continuous operation between transverse joints. Do not push or drag concrete into place or use vibrators to move concrete into place.
- H. Consolidate concrete according to ACI 301 by mechanical vibrating equipment supplemented by hand spading, rodding, or tamping.
  - 1. Consolidate concrete along face of forms and adjacent to transverse joints with an internal vibrator. Keep vibrator away from joint assemblies, reinforcement, or side forms. Use only square-faced shovels for hand spreading and consolidation. Consolidate with care to prevent dislocating reinforcement, dowels, and joint devices.
- I. Place concrete in two operations; strike off initial pour for entire width of placement and to the required depth below finish surface. Lay welded wire fabric or fabricated bar mats immediately in final position. Place top layer of concrete, strike off, and screed.
  - 1. Remove and replace concrete that has been placed for more than 15 minutes without being covered by top layer, or use bonding agent if approved by Architect.
- J. Screed pavement surfaces with a straightedge and strike off.
- K. Commence initial floating using bull floats or darbies to impart an open textured and uniform surface plane before excess moisture or bleed water appears on the surface. Do not further disturb concrete surfaces before beginning finishing operations or spreading surface treatments.
- L. Curbs and Gutters: When automatic machine placement is used for curb and gutter placement, submit revised mix design and laboratory test results that meet or exceed requirements. Produce curbs and gutters to required cross section, lines, grades, finish, and jointing as specified for formed concrete. If results are not approved, remove and replace with formed concrete.
- M. Slip-Form Pavers: When automatic machine placement is used for pavement, submit revised mix design and laboratory test results that meet or exceed requirements. Produce pavement to required thickness, lines, grades, finish, and jointing as required for formed pavement.
  - 1. Compact subbase and prepare subgrade of sufficient width to prevent displacement of paver machine during operations.

- N. When adjoining pavement lanes are placed in separate pours, do not operate equipment on concrete until pavement has attained 85 percent of its 28-day compressive strength.
- O. Cold-Weather Placement: Comply with ACI 306.1 and as follows. Protect concrete work from physical damage or reduced strength that could be caused by frost, freezing actions, or low temperatures.
  - 1. When air temperature has fallen to or is expected to fall below 40 deg F, uniformly heat water and aggregates before mixing to obtain a concrete mixture temperature of not less than 50 deg F and not more than 80 deg F at point of placement.
  - 2. Do not use frozen materials or materials containing ice or snow.
  - 3. Do not use calcium chloride, salt, or other materials containing antifreeze agents or chemical accelerators unless otherwise specified and approved in mix designs.
- P. Hot-Weather Placement: Comply with ACI 301 and as follows when hot-weather conditions exist:
  - 1. Cool ingredients before mixing to maintain concrete temperature below 90 deg F at time of placement. Chilled mixing water or chopped ice may be used to control temperature, provided water equivalent of ice is calculated to total amount of mixing water. Using liquid nitrogen to cool concrete is Contractor's option.
  - 2. Cover steel reinforcement with water-soaked burlap so steel temperature will not exceed ambient air temperature immediately before embedding in concrete.
  - 3. Fog-spray forms, steel reinforcement, and subgrade just before placing concrete. Keep subgrade moisture uniform without standing water, soft spots, or dry areas.

### 3.7 FLOAT FINISHING

- A. General: Do not add water to concrete surfaces during finishing operations.
- B. Float Finish: Begin the second floating operation when bleed-water sheen has disappeared and concrete surface has stiffened sufficiently to permit operations. Float surface with power-driven floats, or by hand floating if area is small or inaccessible to power units. Finish surfaces to true planes. Cut down high spots and fill low spots. Refloat surface immediately to uniform granular texture.
  - 1. Burlap Finish: Drag a seamless strip of damp burlap across float-finished concrete, perpendicular to line of traffic, to provide a uniform, gritty texture.
  - 2. Medium-to-Fine-Textured Broom Finish: Draw a soft bristle broom across float-finished concrete surface perpendicular to line of traffic to provide a uniform, fine-line texture.
  - 3. Medium-to-Coarse-Textured Broom Finish: Provide a coarse finish by striating float-finished concrete surface 1/16 to 1/8 inch deep with a stiff-bristled broom, perpendicular to line of traffic.
  - 4. Coordinate with architect the locations of each type of finish.

### 3.8 SPECIAL FINISHES

- A. Pigmented Mineral Dry-Shake Hardener Finish: After initial floating, apply dry-shake materials to pavement surface according to manufacturer's written instructions and as follows:
  - 1. Uniformly spread dry-shake hardener at a rate of 100 lb/100 sq. ft. unless greater amount is recommended by manufacturer to match pavement color required.
  - 2. Uniformly distribute approximately two-thirds of dry-shake hardener over pavement surface with mechanical spreader, allow to absorb moisture, and embed by power floating. Follow power floating with a second dry-shake hardener application, uniformly distributing remainder of material at right angles to first application to ensure uniform color, and embed by power floating.
  - 3. After final floating, apply a hand-trowel finish followed by a broom finish to concrete.
  - 4. Cure concrete with curing compound recommended by dry-shake hardener manufacturer. Apply curing compound immediately after final finishing.

### 3.9 CONCRETE PROTECTION AND CURING

- A. General: Protect freshly placed concrete from premature drying and excessive cold or hot temperatures.
- B. Comply with ACI 306.1 for cold-weather protection.
- C. Evaporation Retarder: Apply evaporation retarder to concrete surfaces if hot, dry, or windy conditions cause moisture loss approaching 0.2 lb/sq. ft. x h before and during finishing operations. Apply according to manufacturer's written instructions after placing, screeding, and bull floating or darbying concrete, but before float finishing.
- D. Begin curing after finishing concrete but not before free water has disappeared from concrete surface.
- E. Curing Methods: Cure concrete by moisture curing, moisture-retaining-cover curing, curing compound, or a combination of these as follows:
  - 1. Moist Curing: Keep surfaces continuously moist for not less than seven days with the following materials:
    - a. Water.
    - b. Continuous water-fog spray.
    - c. Absorptive cover, water saturated and kept continuously wet. Cover concrete surfaces and edges with 12-inch lap over adjacent absorptive covers.
  - 2. Moisture-Retaining-Cover Curing: Cover concrete surfaces with moisture-retaining cover for curing concrete, placed in widest practicable width, with sides and ends lapped at least 12 inches, and sealed by waterproof tape or adhesive. Immediately repair any holes or tears during curing period using cover material and waterproof tape.



3. Curing Compound: Apply uniformly in continuous operation by power spray or roller according to manufacturer's written instructions. Recoat areas subjected to heavy rainfall within three hours after initial application. Maintain continuity of coating and repair damage during curing period.

### 3.10 PAVEMENT TOLERANCES

A. Comply with tolerances of ACI 117 and as follows:

1. Elevation: 1/4 inch.
2. Thickness: Plus 3/8 inch, minus 1/4 inch.
3. Surface: Gap below 10-foot-long, unlevelled straightedge not to exceed 1/4 inch.
4. Lateral Alignment and Spacing of Tie Bars and Dowels: 1 inch.
5. Vertical Alignment of Tie Bars and Dowels: 1/4 inch.
6. Alignment of Tie-Bar End Relative to Line Perpendicular to Pavement Edge: 1/2 inch.
7. Alignment of Dowel-Bar End Relative to Line Perpendicular to Pavement Edge: Length of dowel 1/4 inch per 12 inches.
8. Joint Spacing: 3 inches.
9. Contraction Joint Depth: Plus 1/4 inch, no minus.
10. Joint Width: Plus 1/8 inch, no minus.

### 3.11 PAVEMENT MARKING

- A. Do not apply pavement-marking paint until layout, colors, and placement have been verified with Architect.
- B. Allow concrete pavement to cure for 14 days and be dry before starting pavement marking.
- C. Sweep and clean surface to eliminate loose material and dust.
- D. Apply paint with mechanical equipment to produce pavement markings of dimensions indicated with uniform, straight edges. Apply at manufacturer's recommended rates to provide a minimum wet film thickness of 15 mils.
  1. Spread glass beads uniformly into wet pavement markings at a rate of 6 lb/gal.

### 3.12 FIELD QUALITY CONTROL

- A. Testing Agency: Owner will engage a qualified independent testing and inspecting agency to perform field tests and inspections and prepare test reports.
- B. Testing Services: Testing of composite samples of fresh concrete obtained according to ASTM C 172 shall be performed according to the following requirements:
  1. Testing Frequency: Obtain at least 1 composite sample for each 100 cu. yd. or 5000 sq. ft. or fraction thereof of each concrete mix placed each day.

- a. When frequency of testing will provide fewer than five compressive-strength tests for each concrete mixture, testing shall be conducted from at least five randomly selected batches or from each batch if fewer than five are used.
  2. Slump: ASTM C 143/C 143M; one test at point of placement for each composite sample, but not less than one test for each day's pour of each concrete mix. Perform additional tests when concrete consistency appears to change.
  3. Air Content: ASTM C 231, pressure method; one test for each composite sample, but not less than one test for each day's pour of each concrete mix.
  4. Concrete Temperature: ASTM C 1064; one test hourly when air temperature is 40 deg F and below and when 80 deg F and above, and one test for each composite sample.
  5. Compression Test Specimens: ASTM C 31/C 31M; cast and laboratory cure one set of three standard cylinder specimens for each composite sample.
  6. Compressive-Strength Tests: ASTM C 39/C 39M; test 1 specimen at 7 days and 2 specimens at 28 days.
    - a. A compressive-strength test shall be the average compressive strength from 2 specimens obtained from same composite sample and tested at 28 days.
- C. Strength of each concrete mix will be satisfactory if average of any 3 consecutive compressive-strength tests equals or exceeds specified compressive strength and no compressive-strength test value falls below specified compressive strength by more than 500 psi.
- D. Test results shall be reported in writing to Architect, concrete manufacturer, and Contractor within 48 hours of testing. Reports of compressive-strength tests shall contain Project identification name and number, date of concrete placement, name of concrete testing and inspecting agency, location of concrete batch in Work, design compressive strength at 28 days, concrete mixture proportions and materials, compressive breaking strength, and type of break for both 7- and 28-day tests.
- E. Nondestructive Testing: Impact hammer, sonoscope, or other nondestructive device may be permitted by Architect but will not be used as sole basis for approval or rejection of concrete.
- F. Additional Tests: Testing and inspecting agency shall make additional tests of concrete when test results indicate that slump, air entrainment, compressive strengths, or other requirements have not been met, as directed by Architect.
- G. Remove and replace concrete pavement where test results indicate that it does not comply with specified requirements.
- H. Additional testing and inspecting, at Contractor's expense, will be performed to determine compliance of replaced or additional work with specified requirements.

### 3.13 REPAIRS AND PROTECTION

- A. Remove and replace concrete pavement that is broken, damaged, or defective or that does not comply with requirements in this Section.

- B. Drill test cores, where directed by Architect, when necessary to determine magnitude of cracks or defective areas. Fill drilled core holes in satisfactory pavement areas with portland cement concrete bonded to pavement with epoxy adhesive.
- C. Protect concrete from damage. Exclude traffic from pavement for at least 14 days after placement. When construction traffic is permitted, maintain pavement as clean as possible by removing surface stains and spillage of materials as they occur.
- D. Maintain concrete pavement free of stains, discoloration, dirt, and other foreign material. Sweep concrete pavement not more than two days before date scheduled for Substantial Completion inspections.

END OF SECTION 321313

## **SECTION 321373 CONCRETE PAVING JOINT SEALANTS**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes the following:
  - 1. Expansion and contraction joints within cement concrete pavement.
  - 2. Joints between cement concrete and asphalt pavement.
- B. Related Sections include the following:
  - 1. Division 07 Section "Joint Sealants" for sealing nontraffic and traffic joints in locations not specified in this Section.
  - 2. Division 32 Section "Asphalt Paving" for constructing joints between concrete and asphalt pavement.
  - 3. Division 32 Section "Concrete Paving" for constructing joints in concrete pavement.

#### **1.3 SUBMITTALS**

- A. Product Data: For each joint-sealant product indicated.
- B. Samples for Verification: For each type and color of joint sealant required. Install joint-sealant samples in 1/2-inch wide joints formed between two 6-inch long strips of material matching the appearance of exposed surfaces adjacent to joint sealants.
- C. Product Certificates: For each type of joint sealant and accessory, signed by product manufacturer.
- D. Qualification Data: For installer and testing agency.
- E. Compatibility and Adhesion Test Reports: From sealant manufacturer, indicating the following:
  - 1. Materials forming joint substrates and joint-sealant backings have been tested for compatibility and adhesion with joint sealants.
  - 2. Interpretation of test results and written recommendations for primers and substrate preparation needed for adhesion.
- F. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for sealants.

#### 1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An employer of workers trained and approved by manufacturer.
- B. Source Limitations: Obtain each type of joint sealant through one source from a single manufacturer.
- C. Preconstruction Compatibility and Adhesion Testing: Submit to joint-sealant manufacturers, for testing indicated below, samples of materials that will contact or affect joint sealants.
  - 1. Use ASTM C 1087 to determine whether priming and other specific joint preparation techniques are required to obtain rapid, optimum adhesion of joint sealants to joint substrates.
  - 2. Submit not fewer than six (6) pieces of each type of material, including joint substrates, shims, joint-sealant backings, secondary seals, and miscellaneous materials.
  - 3. Schedule sufficient time for testing and analyzing results to prevent delaying the Work.
  - 4. For materials failing tests, obtain joint-sealant manufacturer's written instructions for corrective measures including use of specially formulated primers.
  - 5. Testing will not be required if joint-sealant manufacturers submit joint preparation data that are based on previous testing of current sealant products for adhesion to, and compatibility with, joint substrates and other materials matching those submitted.
- D. Product Testing: Obtain test results for "Product Test Reports" Paragraph in "Submittals" Article from a qualified testing agency based on testing of current sealant products within a 36-month period preceding the commencement of the Work.
  - 1. Testing Agency Qualifications: An independent testing agency qualified according to ASTM C 1021 for testing indicated, as documented according to ASTM E 548.

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials to Project site in original unopened containers or bundles with labels indicating manufacturer, product name and designation, color, expiration date, pot life, curing time, and mixing instructions for multi-component materials.
- B. Store and handle materials to comply with manufacturer's written instructions to prevent their deterioration or damage due to moisture, high or low temperatures, contaminants, or other causes.

#### 1.6 PROJECT CONDITIONS

- A. Do not proceed with installation of joint sealants under the following conditions:
  - 1. When ambient and substrate temperature conditions are outside limits permitted by joint-sealant manufacturer.
  - 2. When ambient and substrate temperature conditions are outside limits permitted by joint-sealant manufacturer or are below 40 deg F.
  - 3. When joint substrates are wet or covered with frost.

4. Where joint widths are less than those allowed by joint-sealant manufacturer for applications indicated.
5. Where contaminants capable of interfering with adhesion have not yet been removed from joint substrates.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, products listed in other Part 2 articles.
- B. Products: Subject to compliance with requirements, provide one of the products listed in other Part 2 articles.

### 2.2 MATERIALS, GENERAL

- A. Compatibility: Provide joint sealants, backing materials, and other related materials that are compatible with one another and with joint substrates under conditions of service and application, as demonstrated by joint-sealant manufacturer based on testing and field experience.
- B. Colors of Exposed Joint Sealants: As selected by Architect from manufacturer's full range.

### 2.3 COLD-APPLIED JOINT SEALANTS

- A. Multi-component Jet-Fuel-Resistant Sealant for Concrete: Pourable, chemically curing elastomeric formulation complying with the following requirements for formulation and with ASTM C 920 for type, grade, class, and uses indicated:
  1. Urethane Formulation: Type M; Grade P; Class 12-1/2; Uses T, M, and, as applicable to joint substrates indicated, O.
    - a. Available Products:
      - 1) Pecora Corporation; Urexpan NR-300.
      - 2) Engineer approved equal.
  2. Coal-Tar-Modified Polymer Formulation: Type M; Grade P; Class 25; Uses T and, as applicable to joint substrates indicated, O.
    - a. Available Products:
      - 1) Meadows, W. R., Inc.; Sealtight Gardox.
      - 2) Engineer Approved Equal.

3. Bitumen-Modified Urethane Formulation: Type M; Grade P; Class 25; Uses T, M, and, as applicable to joint substrates indicated, O.
    - a. Available Products:
      - 1) Tremco Sealant/Waterproofing Division; Vulkem 202.
      - 2) Engineer approved Equal.
  - B. Single-Component Jet-Fuel-Resistant Urethane Sealant for Concrete: Single-component, pourable, coal-tar-modified, urethane formulation complying with ASTM C 920 for Type S; Grade P; Class 25; Uses T, M, and, as applicable to joint substrates indicated, O.
    1. Available Products:
      - a. Sonneborn, Div. of ChemRex, Inc.; Sonomeric 1.
      - b. Engineer Approved Equal.
  - C. Type NS Silicone Sealant for Concrete: Single-component, low-modulus, neutral-curing, nonsag silicone sealant complying with ASTM D 5893 for Type NS.
    1. Available Products:
      - a. Crafcro Inc.; RoadSaver Silicone.
      - b. Dow Corning Corporation; 888.
      - c. Engineer Approved Equal.
  - D. Type SL Silicone Sealant for Concrete and Asphalt: Single-component, low-modulus, neutral-curing, self-leveling silicone sealant complying with ASTM D 5893 for Type SL.
    1. Available Products:
      - a. Crafcro Inc.; RoadSaver Silicone SL.
      - b. Dow Corning Corporation; 890-SL.
      - c. Engineer Approved Equal.
  - E. Multi-component Low-Modulus Sealant for Concrete and Asphalt: Proprietary formulation consisting of reactive petropolymer and activator components producing a pourable, self-leveling sealant.
    1. Available Products:
      - a. Meadows, W. R., Inc.; Sof-Seal.
      - b. Engineer Approved Equal.
- 2.4 HOT-APPLIED JOINT SEALANTS
- A. Jet-Fuel-Resistant Elastomeric Sealant for Concrete: Single-component formulation complying with ASTM D 3569.
    1. Available Products:

- a. Crafcro Inc.; Superseal 444/777.
  - b. Meadows, W. R., Inc.; Poly-Jet 3569.
  - c. Engineer Approved Equal.
- B. Jet-Fuel-Resistant Sealant for Concrete and Tar Concrete: Single-component formulation complying with ASTM D 3581.
  - 1. Available Products:
    - a. Crafcro Inc.; Superseal 1614A.
    - b. Meadows, W. R., Inc.; Poly-Jet 1614.
    - c. Meadows, W. R., Inc.; Poly-Jet 3406.
    - d. Meadows, W. R., Inc.; Poly-Jet 3569.
    - e. Engineer Approved Equal.
- C. Elastomeric Sealant for Concrete: Single-component formulation complying with ASTM D 3406.
  - 1. Available Products:
    - a. Crafcro Inc.; Superseal 444/777.
    - b. Meadows, W. R., Inc.; Poly-Jet 3406.
    - c. Engineer Approved Equal.
- D. Sealant for Concrete and Asphalt: Single-component formulation complying with ASTM D 3405.
  - 1. Available Products:
    - a. Koch Materials Company; Product No. 9005.
    - b. Koch Materials Company; Product No. 9030.
    - c. Meadows, W. R., Inc.; Sealtight Hi-Spec.
    - d. Engineer Approved Equal.

## 2.5 JOINT-SEALANT BACKER MATERIALS

- A. General: Provide joint-sealant backer materials that are nonstaining; are compatible with joint substrates, sealants, primers, and other joint fillers; and are approved for applications indicated by joint-sealant manufacturer based on field experience and laboratory testing.
- B. Round Backer Rods for Cold- and Hot-Applied Sealants: ASTM D 5249, Type 1, of diameter and density required to control sealant depth and prevent bottom-side adhesion of sealant.
- C. Backer Strips for Cold- and Hot-Applied Sealants: ASTM D 5249; Type 2; of thickness and width required to control sealant depth, prevent bottom-side adhesion of sealant, and fill remainder of joint opening under sealant.
- D. Round Backer Rods for Cold-Applied Sealants: ASTM D 5249, Type 3, of diameter and density required to control sealant depth and prevent bottom-side adhesion of sealant.



## 2.6 PRIMERS

- A. Primers: Product recommended by joint-sealant manufacturer where required for adhesion of sealant to joint substrates indicated, as determined from preconstruction joint-sealant-substrate tests and field tests.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine joints indicated to receive joint sealants, with Installer present, for compliance with requirements for joint configuration, installation tolerances, and other conditions affecting joint-sealant performance.
  - 1. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Surface Cleaning of Joints: Clean out joints immediately before installing joint sealants to comply with joint-sealant manufacturer's written instructions.
- B. Joint Priming: Prime joint substrates where indicated or where recommended in writing by joint-sealant manufacturer, based on preconstruction joint-sealant-substrate tests or prior experience. Apply primer to comply with joint-sealant manufacturer's written instructions. Confine primers to areas of joint-sealant bond; do not allow spillage or migration onto adjoining surfaces.

### 3.3 INSTALLATION OF JOINT SEALANTS

- A. General: Comply with joint-sealant manufacturer's written installation instructions for products and applications indicated, unless more stringent requirements apply.
- B. Sealant Installation Standard: Comply with recommendations in ASTM C 1193 for use of joint sealants as applicable to materials, applications, and conditions indicated.
- C. Install backer materials of type indicated to support sealants during application and at position required to produce cross-sectional shapes and depths of installed sealants relative to joint widths that allow optimum sealant movement capability.
  - 1. Do not leave gaps between ends of backer materials.
  - 2. Do not stretch, twist, puncture, or tear backer materials.
  - 3. Remove absorbent backer materials that have become wet before sealant application and replace them with dry materials.
- D. Install sealants using proven techniques that comply with the following and at the same time backings are installed:
  - 1. Place sealants so they directly contact and fully wet joint substrates.

2. Completely fill recesses provided for each joint configuration.
  3. Produce uniform, cross-sectional shapes and depths relative to joint widths that allow optimum sealant movement capability.
- E. Tooling of Nonsag Sealants: Immediately after sealant application and before skinning or curing begins, tool sealants according to requirements specified below to form smooth, uniform beads of configuration indicated; to eliminate air pockets; and to ensure contact and adhesion of sealant with sides of joint.
1. Remove excess sealants from surfaces adjacent to joint.
  2. Use tooling agents that are approved in writing by joint-sealant manufacturer and that do not discolor sealants or adjacent surfaces.
- F. Provide joint configuration to comply with joint-sealant manufacturer's written instructions, unless otherwise indicated.
- G. Provide recessed joint configuration for silicone sealants of recess depth and at locations indicated.

#### 3.4 CLEANING

- A. Clean off excess sealants or sealant smears adjacent to joints as the Work progresses by methods and with cleaning materials approved by manufacturers of joint sealants and of products in which joints occur.

#### 3.5 PROTECTION

- A. Protect joint sealants during and after curing period from contact with contaminating substances and from damage resulting from construction operations or other causes so sealants are without deterioration or damage at time of Substantial Completion. If, despite such protection, damage or deterioration occurs, cut out and remove damaged or deteriorated joint sealants immediately and replace with joint sealant so installations with repaired areas are indistinguishable from the original work.

END OF SECTION 321373

THIS PAGE LEFT INTENTIONALLY BLANK

## **SECTION 328400 – IRRIGATION SYSTEMS**

### **PART I – GENERAL**

#### **1.1 SUMMARY**

##### **A. SECTION INCLUDES**

1. Install new heads and lateral lines. Patch and repair an existing irrigation system due to construction activities. Project may include adjusting the elevation of valves, replacing valve boxes, repairing broken pipe, adding new valves, and running new wire.

##### **B. RELATED SECTIONS**

1. Section 31 2000 – Earth Moving
2. Section 32 9300 - Landscape Planting

#### **1.2 REFERENCES**

##### **A. American Society of Testing Materials (ASTM):**

1. D1784 Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds
2. D2241 Poly (Vinyl Chloride) (PVC) Pressure-Rated Pipe (SDR Series)
3. D2466 Poly (Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 40

#### **1.3 SYSTEM REQUIREMENTS**

- ##### **A. Irrigation repair to be furnished and installed a subcontract to section 32 9300 –Landscape planting.**

##### **B. IRRIGATION HEAD LAYOUT**

1. Contractor to measure and mark location of the new heads.

#### **1.4 SUBMITTALS**

- ##### **A. Product data including pressure loss, pressure rating, rated capacity, and electrical data of the following equipment to be used on the project:**

1. Manual and automatic control valves
2. Valve boxes and vaults
3. Spray Heads
4. Rotor heads
5. Wire and wire connectors
6. Controller
7. Pipe and fittings

- ##### **B. Maintenance data for inclusion in “Operating and Maintenance Manual”**

1. Automatic control valves
2. Sprinklers
3. Controllers and remote-control equipment

C. Record Drawings

1. Record Drawings shall be furnished to the Landscape Architect at the time of Substantial Completion Inspection before a letter of Substantial Completion for the irrigation sprinkler system will be issued.
2. Provide name and phone number of the servicing water purveyor, include the name of the installer and the date irrigation work was completed.
3. Indicate locations, sizes and kinds of equipment installed.

1.5 QUALITY ASSURANCE

- A. Comply with requirements of water utility service
- B. Comply with all applicable codes, laws and ordinances that apply to irrigation systems.
- C. Installer Qualifications: Irrigation contractor must have a minimum of 5 years of experience and has completed 5 irrigation systems of similar size using similar materials. Irrigation contractor shall be able to supply proof of a successful performance record.

1.6 PROJECT CONDITIONS

- A. Verify existing utility locations and verify that irrigation system piping may be installed in compliance with original design and referenced standards.
- B. Installation of the irrigation system may begin after the grading of the subgrade has been approved and the site is free of construction debris. Report to the Landscape Architect any unsatisfactory conditions.
- C. Reports on subsurface condition investigations made during design of the project are available for informational purposes only; data in reports are not intended as representations or warranties of accuracy or continuity of conditions (between soil borings). Owner assumes no responsibility for interpretations or conclusions drawn from this information.

1.7 SEQUENCING AND SCHEDULING

- A. Maintain uninterrupted water service to adjacent users during normal irrigation hours. Arrange for temporary water shutoff with Owner and neighbors.
- B. Coordinate work with landscape work specified in Section 32 9300 -Landscape Planting and with work specified in Section 33 0000 – Utilities

1.8 EXTRA MATERIALS

- A. Extra materials shall be delivered to the Owner. Extra materials shall be identical to the equipment installed on the project. Materials shall be packaged in the original shipping boxes if available and packaged to prevent damage. Boxes shall be taped closed and the contents of the box shall be clearly marked on the outside.

1. Quick Couplers: Furnish one quick coupler for every 15 installed on the project with a minimum of one.
2. Quick Coupler Hose Swivels: Furnish two.
3. Quick Coupler Operating Keys: Furnish two.
4. Sprinklers: Furnish one sprinkler head of each type for every 20 installed with a minimum of 5.

#### 1.9 WARRANTY/GUARANTEE

- A. Contractor will guarantee all workmanship and materials of the irrigation system for the period of one year after the final acceptance of the irrigation system. Contractor shall repair or replace any defect in workmanship or material within seven days after receiving written notice from the owner or the owner's representative. Contractor shall make warranty repairs at his own expense. If the contractor fails to make repairs within seven days, the owner shall make the repairs at the contractor's expense. In case of emergency, where the Owner determines that a delay presents a hazard or could result in serious loss or damage, the Owner may make repairs at the contractor's expense after a verbal communication with the contractor, without written notice.
- B. The guarantee shall be in the form of a letter from the Contractor addressed to the Owner. The letter shall incorporate the language stated above and be signed by an authorized officer/agent or Owner of the Contractor.
- C. During the guarantee period, the Contractor will drain the system in the fall and put the system back into operation in the spring. This work shall be done in the presence of the Owner's representative and maintenance personnel.

#### 1.10 PRODUCT DELIVERY, STORAGE AND HANDLING

- A. Deliver irrigation system components in manufacturer's original undamaged and unopened containers with labels intact and legible.
- B. Deliver plastic piping in bundles, packaged to provide adequate protection of pipe ends, both threaded or plain.
- C. Store and handle materials to prevent damage and deterioration.
- D. Provide secure, locked storage for valves, sprinkler heads, and similar components that cannot be immediately replaced, to prevent installation delays.

### PART II – PRODUCTS

#### 2.1 PIPES, TUBES, AND FITTINGS

##### A. MANUFACTURES

1. J-M Manufacturing Company, Inc.
2. Pacific Western Extruded Plastics Co.
3. Eagle Pacific Industries, Inc.
4. The Harrington Corporation (HARCO)
5. Sigma
6. Leemco

7. Spears
8. Lasco
9. Nibco

B. Irrigation Mainline Pipe

1. 4" and larger:
  - a. Pipe: ASTM D 2241, PVC Class-200, SDR-21, 260 psig.
  - b. Joint: ASTM D 2241, PVC Class-200 bell end.
  - c. Fitting: ASTM A 3139, ASTM A-536, Deep socket cast iron.
  - d. Joint Restraints: UNI-B-13-94, grip ring pipe restraints.
  - e. Flanges: ASME B16.24, Class 150, cast bronze.
2. 3" and smaller:
  - a. Pipe: ASTM D 1785, PVC 1120, Schedule 40, 160 psig.
  - b. Joints: ASTM D2241 Schedule 40 bell end
  - c. Fittings: ASTM D 2466 Schedule 40 Socket type

C. Irrigation Lateral Pipe

1. Pipe: ASTM D 1785, PVC 1120, Schedule 40, 160 psig.
2. Joints: ASTM D2241 bell end
3. Fittings: ASTM D 2466 Schedule 40 Sockets

D. Manifold pipe

1. Pipe: ASTM D 1785, PVC 1120 compound, Schedule 80.
2. Socket Fittings: ASTM D 2467, Schedule 80 Socket
3. Threaded Fittings: ASTM D 2464. Schedule 80:

2.2 JOINING MATERIALS

- A. Solvent Cement: ASTM F656 primer and ASTM D2564 solvent cement in color other than orange.
- B. Gaskets for Plastic Flanged Joints: Materials recommended by plastic pipe and fittings manufacturer.
- C. Gaskets for Plastic Joints: Trans gaskets as recommended the fittings manufacturer.

2.3 VALVES

A. Gate Valves

1. 3" and larger: AWWA C509, resilient seated; bronze stem, cast-iron, or ductile iron body and bonnet, stem nut, 200 psig (1380 kPa) working pressure; and ends that fit NPS dimension, PVC pipe. Include elastomeric gaskets.
2. 2-1/2" and smaller: Bronze, Nonrising Stem Gate Valves MSS SP-80, Type 1, solid wedge; nonrising, copper-silicon-alloy stem; Class 125, body and screw bonnet of ASTM B 62 cast

bronze, with threaded or solder-joint ends. Include polytetrafluoroethylene (PTFE) impregnated packing, brass packing gland, and malleable-iron handwheel.

3. Manufacturers:
  - a. Nibco, Inc.
  - b. Clow Valve Co. Div., McWane, Inc
  - c. Stockham Valves & Fittings, Inc.
  - d. Waterous Co.

B. Curb Stops

1. 2" inches and Smaller: Bronze body, ground key plug or ball, 150 psig (1035 kPa) minimum pressure rating, wide tee head, with inlet and outlet to match service piping material.
2. Manufacturers:
  - a. Ford Meter Box Co., Inc.
  - b. Hays Div., Romac Industries
  - c. A.Y McDonald Mfg. Co.
  - d. Mueller Co., Grinnel Corp.

C. Plastic Ball Valves: Polyvinyl Chloride (PVC) Plastic, with 150 psig (1035 kPa) minimum pressure rating, ends compatible to piping where valve is to be installed, and tee handle.

1. Manufacturers:
  - a. Spears Manufacturing
  - b. Nibco, Inc.
  - c. Matco-Norca

D. Ball Valves: Ball valves shall be solid bronze meeting Federal Specification WW-V-35C, TYPE II, COMPOSITION: BZ, STYLE: 3. Size shall be the same size as the main line on which it is installed. Valves shall be installed on the up-stream side of the electric remote control valve manifold and in the same valve box. NOTE: Only one (1) ball valve required per manifold.

1. Manufacturers:
  - a. Nibco, Inc.
  - b. Stockham Valves & Fittings, Inc.
  - c. Waterous Co.

E. Drain Valves: All drain valves shall be 3/4" brass full turn ball cocks and installed as per details on the Drawings. Valves shall be tested for 150 psi working pressure. This valve is to be installed on mainlines only.

1. Manufacturers:
  - a. Ford Meter Box Co., Inc.
  - b. Hays Div., Romac Industries
  - c. Mueller Co., Grinnel Corp.

F. Automatic Control Valves: Diaphragm-type, normally closed, with manual flow adjustment, and operated by 24-volt-a.c. solenoid.



1. Manufactures:
  - a. Rain Bird
- G. Quick-Couplers: Factory-fabricated, 2-piece assembly. Include coupler water-seal valve; removable upper body with spring-loaded or weighted, rubber-covered cap; hose swivel with ASME B1.20.7, 3/4-11.5NH Threads for garden hose on outlet; and operating key.
  1. Manufactures:
    - a. Rain Bird
- B. Valve Boxes: Polyethylene (PE), acrylonitrile-butadiene-styrene (ABS), fiberglass, polymer concrete, or precast concrete box and cover. Size as required for application.
  1. Drainage Backfill: Cleaned gravel or crushed stone, graded from 3-inches (75 mm) maximum to 3/4-inch (19 mm) minimum.
  2. Valve boxes shall be of sufficient size to house one (1) electric remote control valves with unions, and still allow room for maintenance without having to excavate or perform similar operations. Boxes shall have lock down lids and shall meet ASTM D638 for tensile strength of 4,300 pounds per square inch.
  3. Manufactures:
    - a. Ametek by Plymouth Products Div., AMTETK
    - b. Brooks Products, Inc. Polyplastics Div.
    - c. Carson Industries, Inc.
    - d. DFW/HPI by Hefco Plastics, Inc.
    - e. Rain Bird Sprinkler Mfg. Corp.

## 2.2 SPRINKLERS

- A. Description: Manufacturer's standard sprinklers designed to provide uniform coverage over entire area of spray shown on Drawings at available water pressure, as follows:
  1. Housings: plastic, except where material is specified.
- B. Pop-up, Spray: Fixed pattern, with screw-type flow adjustment and stainless steel retraction spring.
- C. Manufactures:
  1. Rain Bird

## 2.3 WIRING

- A. 14 AGW Single conductor solid copper wire with 0.045" thick polyethylene insulation (PE) coating over wire. White for common wire, orange for hot wires, and blue for spare wires.
- B. Wire Connectors: 3M DBRY-6 Waterproof Splice Kit.

## 2.4 AUTOMATIC CONTROL SYSTEM

- A. Description: Low-voltage controller system made for control of irrigation system automatic control valves. Controller operates on 120 volts a.c. building power system, provides 24 volts a.c. power to control valves.
- B. Manufactures:
  - 1. Rain Bird
- C. Lightning Protection: Provide grounding rod and grounding plate lightning protection on each controller Coordinate with electrical.

## 2.5 THRUST BLOCKS

- A. All main lines 3" and larger shall have a thrust block of poured concrete installed at each change of direction. The thrust block shall be of sufficient size for the pipe involved and rest on undisturbed ground.

## Part III – EXECUTION

### 3.1 SITE CONDITIONS

- A. Verify water supply location, size and pressure.
- B. Inspect site to ensure that it is free of large rocks, plant material, and construction debris.
- C. Verify that the site has been rough graded to the proper subgrade elevations.

### 3.2 PREPARATION

- A. Set stakes or flags to identify proposed sprinkler locations. Obtain Landscape Architect's approval before excavation.

### 3.3 PIPING APPLICATIONS

- A. Refer to Part 2 of this Section for detailed specifications for pipe and fittings products listed below. Use pipe, tube, fittings, and joining methods according to the following applications. Piping in pits and aboveground may be joined with flanges instead of joints indicated.
- B. Pressure Piping Underground: Use the following:
  - 1. 3-inches and smaller: Schedule 40 PVC plastic pipe, and schedule 40, PVC plastic socket-type pipe fittings and solvent-cemented joints.
  - 2. 4-inches and larger: Class 200 PVC plastic pipe with flanged or deep socket cast iron fittings with joint restraints.
- C. Circuit Piping: Use the following:
  - 1. All Sizes: Schedule 40 PVC plastic pipe, and schedule 40, PVC plastic socket-type pipe fittings and solvent-cemented joints.
- D. Branches and Offsets at Sprinkler and Devices: Schedule 80 PVC plastic pipe with threaded ends and schedule 80 PVC plastic threaded fittings and threaded joints.

- E. Drain Piping: Schedule 40 PVC plastic pipe, and schedule 40, PVC plastic socket-type pipe fittings and solvent-cemented joints.
- F. Sleeves: Schedule 40 PVC plastic pipe, and schedule 40, PVC plastic socket-type pipe fittings and solvent-cemented joints.

### 3.4 JOINT CONSTRUCTION

- A. Flanged Joints: Align flanges and install gaskets. Assemble joints by sequencing bolt tightening. Use lubricant on bolt threads.
- B. Threaded Joints: Thread pipes with tapered pipe threads according to ASME B1.20.1, apply tape or joint compound, and apply wrench to valve ends into which pipes are being threaded.
- C. PVC Piping Gasketed Joints: Construct joints between underground AWWA-type, cast-iron valves and NPS PVC pipe; with elastomeric seals that fit pipe diameter and valve ends; and lubricant, according to ASTM D 3139.
- D. PVC Piping Solvent-Cemented Joints: Construction joints according to ASTM D 2672 and ASTM D 2855.
  - 1. Handling of Solvent Cements, Primers, and Cleaners: Comply with procedures in ASTM F 402 for safe handling when joining plastic pipe and fittings with solvent cements.

### 3.5 PIPING SYSTEMS – COMMON REQUIREMENTS

- A. General Locations and Arrangements: Drawings indicated general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, and in other design considerations. Install piping as indicated, except where deviations to layout are approved on coordination drawings.
- B. Install piping at a uniform slope of 6-inches per 100-feet (1:200) minimum, down to drain points.
- C. Install components having pressure rating equal to or greater than system operating pressure.
- D. Install piping free of sags and bends.
- E. Locate groups of pipes parallel to each other, spaced to permit valve servicing.
- F. Install fittings for changes in direction and branch connections.
- G. Piping Connections: Except as otherwise indicated make piping connections as specified below.
  - 1. Install unions, in piping 2-inches (DN 50) and smaller, adjacent to each valve and at final connection to each piece of equipment having 2-inch (DN 50) or smaller threaded pipe connection.
  - 2. Install flanges, in piping 2½-inches (DN 65) and larger, adjacent to flanged valves and at final connection to each piece of equipment having flanged pipe connection.
  - 3. Install dielectric fittings to connect piping of dissimilar metals.

### 3.6 TRENCHES:

- A. Trenches shall be dug as wide and deep as necessary to properly place the sprinkling system according to the requirements herein. Any rock uncovered in this excavation shall not be left in the backfill. All excess rock shall be removed from the site by this Contractor and legally disposed of off the property. All trenches shall be backfilled and compacted to insure no settling of the surface, after the lawn is planted.
- B. If backfill soil is rocky or lumpy, protect the pipe and the pipe conduit with 8" of sand or loose, rock free, soil under, over and on sides of pipe. Avoid putting large rocks against pipe during backfilling operation.
- C. All trenches must be compacted to 90% in 6" lifts and watered in. Lines from control valves shall be installed after topsoil is in place and properly graded.
- D. This Contractor, in placing the sprinkling lines, etc., may uncover material not suitable for finished grading. This material shall be removed from the site by this Contractor. After the installation of the lines, the finished grading shall be smoothed over and restored to its original condition, using additional topsoil at this Contractor's expense, if this is necessary. The upper 6" of topsoil removed in the excavation of trenches for pipeline shall be conserved and kept separate from subsoil and reinstalled without mixing with other soil.
- E. Trenches where more than one pipe is to be installed, a distance of 6" is to be maintained between each pipe.
- F. All trenches are to be 12" away from all curbs, buildings and sidewalks.

### 3.7 PIPING INSTALLATION

- A. Install underground polyvinyl chloride (PVC) plastic pipe according to ASTM D 2774.
- B. Lay piping on solid sub-base, uniformly sloped without humps or depressions.
  - 1. Slope circuit piping down toward drain valve minimum of ½-inch in 10-feet (1:240).
  - 2. Install polyvinyl chloride (PVC) plastic pipe in dry weather when temperature is above 40 deg. F (4 deg. C). Allow joints to cure at least 24-hours at temperature above 40 deg. F (4 deg. C) before testing, unless otherwise recommended by manufacturer.
- C. Drain Pockets: Excavate to sizes indicated. Backfill with cleaned gravel and crushed stone, graded from 3-inches (75 mm) to ¾-inch (19mm) minimum, drain material to 12-inches (300 mm) below grade. Cover drain material with sheet of ASTM D 226, Type II, asphalt-saturated felt and backfill remainder with excavated material. Drain pocket to be minimum 6 cubic feet.
- D. Minimum Cover: Provide following minimum cover over top of buried piping:
  - 1. Pressure Piping: Greater depth of minimum of 24-inches (600 mm) below finished grade.
  - 2. Circuit Piping: 15-inches (380 mm).
  - 3. Drain Piping: 24 inches (380 mm).
  - 4. Sleeves: 24-inches (600 mm).

5. Install piping under sidewalks and paving in sleeves.

### 3.8 MANUAL FLUSH VALVES:

- A. These valves serve to provide flushing during installation and in case of major breaks or contaminations in the system. They shall be installed one for every auto line flush valve, at grade and directly adjacent to the auto flush valves in a separate box.

### 3.9 VALVE APPLICATIONS

- A. Drawings indicate valve types to be used. Where specific valve types are not indicated, following requirements apply:
  1. Buried Valves 3-inches (DN 80) and Larger: AWWA, gate valves, non-rising stem, with stem nut and valve box.
  2. Buried Valves 2-inches (DN 50) and Smaller: Bronze-body, curb stop, with tee head, service box and shutoff rod.

### 3.10 VALVE INSTALLATION

- A. Valves: Install underground valves in valve boxes.
  1. Install valves and polyvinyl chloride (PVC) pipe with restrained, gasketed joints.
- B. Curb Stops: Install underground curb stops in service boxes.
- C. Control and Ball Valves: Install in valve control valve boxes, arranged for easy adjustment and removal. Install unions with one (1) on upstream side at each valve manifold.

### 3.11 SPRINKLER INSTALLATION

- A. Sprinklers: Flush circuit piping with full head of water and install sprinklers after hydrostatic test is complete.
  1. Install lawn sprinklers at manufacturer's recommended heights.

### 3.12 FIELD QUALITY CONTROL

- A. Testing: Perform hydrostatic test of piping and valves before backfilling trenches. Piping may be tested in sections to expedite work.
  1. Cap and subject the piping system to a static water pressure of 50 psig (345 kPa) above the operating pressure without exceeding pressure rating of piping system materials. Isolate test source and allow to stand for 4-hours. Leaks and loss in test pressure constitute defects that must be repaired.
  2. Repair leaks and defects with new materials and retest system or portion thereof until satisfactory results are obtained.
  3. Notify Architect 24 hour in advance of pressure testing so test may be observed.

### 3.13 CLEANING AND ADJUSTING

- A. Flush dirt and debris from piping before installing sprinklers and other devices.
- B. Adjust automatic control valves to provide flow rate of rated operating pressure required for each sprinkler circuit.
- C. Carefully adjust lawn sprinklers so they will be flush with, or not more than ½-inch (13 mm) above, finish grade after completion of landscape work.
- D. Adjust settings of controllers and automatic control valves.

### 3.14 COMMISSIONING

- A. Starting Procedures: Follow manufacturer's written procedures. If no procedures are prescribed by manufacturers, proceed as follows:
  - 1. Verify that specialty vales and their accessories have been installed correctly and operate correctly.
  - 2. Verify that specified test of piping are complete.
  - 3. Check that sprinklers and devices are correct type.
  - 4. Check that damaged sprinklers and devices have been replaced with new materials.
  - 5. Check that potable water supplies have correct type backflow preventers.
  - 6. Energize circuits to electrical equipment and devices.
  - 7. Adjust operating controls.
- B. Operational Testing: Perform operational testing after hydrostatic testing is completed, backfill is in place, and sprinklers are adjusted to final position.
- C. Provide irrigation system layout and diagram with water zones clearly identified. Layout to be color coded with a maximum of 5 colors for easy legibility. Record water budget for each irrigation control zone and current settings. Provide laminated copy and mount near controller. Verify location with Architect.

### 3.15 DEMONSTRATION

- A. Demonstrate to Architect that system meets coverage requirements and that automatic controls function properly.
- B. Demonstrate to Owner's maintenance personnel operation of equipment, sprinklers, specialties, and accessories. Review operating and maintenance information.
- C. Provide 7-days' written notice in advance of demonstration.

END OF SECTION 32840

## SECTION 329000 – LANDSCAPE PLANTING

### PART I – GENERAL

#### 1.1 SUMMARY

- A. The extent of the landscaping development work is shown on the drawings and in schedules. This work includes:
  - 1. Obtaining and paying for permit fees, inspections and tests required for the installation of landscape planting.
  - 2. Providing and placement of all plant material, topsoil, sod, and miscellaneous materials and maintenance of landscape planting and associated guarantees.
  - 3. Attendance at Pre-Construction Conference

#### 1.2 RELATED WORK

- A. Section 328400 - Irrigation Systems
- B. Section 329300 – Fine Grading

#### 1.3 QUALITY ASSURANCE

- A. Sod shall be subject to the Landscape Architect's inspection and approval at place of growth or upon delivery for conformity to specification requirements. Such approval shall neither preclude right of rejection upon delivery at the site or during progress of work, nor right of rejection at the site due to damage suffered in handling or transportation. Inspection of sod by the Landscape Architect before planting shall be at the option and expense of the Owner.
  - 1. All sod will be inspected again at time of final inspection and once again at the end of the warranty period.
  - 2. Any sod found to be unacceptable at any inspection shall be immediately removed and replaced.
- B. Contractor will provide and pay for materials testing. Testing agency shall be acceptable to the Landscape Architect.
  - 1. Test representative samples of materials proposed for use. Materials used in the work shall be the same materials as tested. Do not use proposed material in the work until test reports have been reviewed by the Landscape Architect and approval obtained to proceed with plant excavations.
- C. Test reports: Provide the following test results of the imported topsoil and the final mixed topsoil:
  - 1. Topsoil:
    - a. Mechanical analysis.
    - b. Percentage of organic content.
    - c. Recommendations on the type and quantity of soil nutrient additives required to bring nutrients to a satisfactory level for specified plants.
    - d. Recommendations on the type and quantity of soil additives required to bring the pH of soil to a value of 5.5-7.0 (unless otherwise noted).
    - e. SAR
    - f. Soluble Salts

- D. Landscape work shall be done by a single firm specializing in landscape construction work with minimum 5 years experience completing 5 projects of similar size and complexity.
  - 1. Contractor to provide list of past projects completed during last 3 years at time of first bid proposal.
  - 2. All landscape work shall meet the construction and post construction monitoring of the DFCM landscape guidelines. This contractor shall be required to complete all forms required to satisfy DFCM requirements.

#### 1.4 SUBMITTALS

- A. Submit imported topsoil material test reports.
- B. Submit topsoil material test reports of final mixed topsoil prior to planting.
- C. Submit a label from the manufacturer's container certifying fertilizer content.
- D. Certification of sod:
  - 1. Sod: Botanical and common name, percentage of each species and variety in sod mix.
- E. Submit complete written maintenance instruction at least 10 days prior to end of maintenance period. Include all requirements for proper care, development and maintenance of planting.
- F. Submit within 20 days of award of the bid to general contractor a planting schedule stating sources from which said Contractor can provide the plant materials in the quantity indicated on the Drawings.
- G. Submit contractor's Guarantee Form for Landscape Architect's review.
- H. Submit anticipated planting schedule.

#### 1.5 VERIFICATION OF DIMENSIONS AND QUANTITIES

- A. All scaled dimensions are approximate. Before proceeding with any work, the Contractor shall carefully check and verify all dimensions and quantities, and shall immediately inform the Landscape Architect of any discrepancy between the information on the Drawings and actual conditions, refraining from doing any work on said areas until given approval to do so by the Landscape Architect.

#### 1.6 PRODUCT DELIVERY, STORAGE AND HANDLING

- A. Prepare, transport and handle sod to ensure protection against injury. Cover all sod while transporting to the site.
- B. Harvest, deliver and install sod within 24 hours. Sod may not be stored on the site.
- C. Packaged materials shall be delivered in factory labeled containers showing weight, content and manufacturer. Protect all materials from damage and deterioration during delivery and storage at site.



## 1.7 GRADING

- A. Examine the subgrade, verify the elevations of topsoil, planting mix or mulch. Observe the conditions under which work is to be performed, and notify the Landscape Architect of unsatisfactory conditions. Do not begin landscape work until unsatisfactory conditions have been improved.

## 1.8 EXCAVATION

- A. When conditions detrimental to plant growth are encountered, such as rubble fill, adverse drainage conditions, or obstructions, notify the Landscape Architect before planting.

## 1.9 EXISTING UTILITIES

- A. Determine location of underground utilities and irrigation and perform work in a manner which will avoid possible damage. Hand excavate, as required, to minimize possibility of damage to underground utilities. The Contractor shall have the area "Blue Staked" prior to digging. It is the responsibility of the Contractor to repair or replace any damage caused by its workers at no expense to the Owner.

## 1.10 PLANTING SCHEDULE

- A. Before bidding each bidder shall investigate sources of supply and determine availability of the quantity of sod specified on the planting plan. Failure to take this precaution will not relieve the successful bidder from responsibility as a contractor to furnish and install all sod in strict accordance with the contract without additional expense to the Owner.
- B. Prepare a proposed planting schedule for approval by the Landscape Architect. Schedule the dates for each type of landscape work during the normal seasons for such work in the area of the site. Correlate with specified maintenance periods to provide maintenance throughout the specified time period. Once accepted, revise dates only as approved in writing, after documentation of reasons for delays.
- C. Proceed with and complete the landscape work as rapidly as portions of the site become available, working within the seasonal limitations for each kind of landscape work required.

## 1.11 ESTABLISHMENT, MAINTENANCE, REPLACEMENT, AND GUARANTEE

- A. The establishment period shall begin at the time that the planting phase of the work is completed, inspection and written notice is given and shall continue until substantial line. See Total Site Maintenance section 3.13.
- B. Maintenance shall include but not be limited to watering, weeding, spraying, and lawn maintenance as described herein.
- C. Mow lawn as soon as the sod is tall enough to cut. Do not remove more than 40% of grass-leaf growth in initial or subsequent mowings. Do not mow when grass is wet. Mow grass at 2-3" high.

- D. Apply fertilizer after initial mowing and when grass is dry. Apply a 20-0-0 fertilizer at label rate.
- E. Guarantee a close knit stand of grass by watering, mowing, regrading and resodding eroded areas and otherwise maintaining lawn area to the satisfaction of the Landscape Architect, until final acceptance. Any areas, which fail to show a thick, vigorous, healthy grass stand, shall be resoded at Contractor's expense with the same sod originally specified. Resod as required until all affected areas are accepted by the Landscape Architect.
- F. Guarantee all planting for one year following signature of Owner on the final contract payment application.
- G. The Contractor will not be responsible for plants destroyed or lost due to occupancy of the project, or vandalism on the parts of others or if the failure of any plant material can be proven to the Landscape Architect to be beyond the control of the Contractor.

## PART 2 – MATERIALS

- A. Topsoil for planting operations shall be harvested from the portions of the site used for agriculture. Do not use surface material from the area of the site once occupied by homes. Topsoil shall be stockpiled, screened and amended with fertilizer and compost.
  - 1. Topsoil shall be free from debris such as rocks, roots, sticks and clods.
  - 2. Topsoil shall be tested for soil characteristics and nutritional content. Soil testing report and fertilization recommendations shall be submitted to the Landscape Architect. Acceptable test results are in the ranges below.

a. Soluble Salts	<4
b. PH	5.5-8.2
c. Sand	<70%
d. Silt	<70%
e. Clay	<30%
f. Texture Class	L, SiL, SCL, SL, CL, SiCL
g. Organic Matter	≥1%
h. Coarse Fragments > 2mm dia.	≤5%
i. SAR	3-7 for SiL, SiCL CL, 3-10 for SCL, SL, L
j. Topsoil shall not contain rocks larger than 1 ½" in diameter.	
k. Topsoil report shall also contain fertilizer recommendations.	
  - 3. Amend topsoil with fertilizer as recommended by the topsoil test.
  - 4. Amend topsoil with 3 cubic yards of compost for every 1000 square feet of spread topsoil. Topsoil and compost shall be tilled together.
- B. Topsoil shall not be used for planting operations while in a frozen or muddy condition.

### 2.2 PEAT MOSS

- A. Peat moss used in planting soil preparation: High quality pure Canadian sphagnum peat with a pH value not less than 3.5 nor greater than 6.0 at 25 degrees C. The ash content shall be not more than 10% and water holding capacity shall be not less than 800%.

## 2.3 COMPOST

A. Organic compost shall meet the following guidelines, submit test results:

- |                                 |        |
|---------------------------------|--------|
| a. Soluble Salts                | ≤5     |
| b. PH                           | 6-8    |
| c. Carbon:Nitrogen Ratio (C:N)  | ≤20:1  |
| d. Moisture                     | 25-35% |
| e. ≥98% Coarse Material Passing | 3/8"   |

## 2.4 BACKFILL

A. Backfill soil mixture shall be the following materials well mixed in the specified proportions, which are by volume: 1 part Peat moss, 4 parts topsoil.

## 2.5 COMMERCIAL FERTILIZER – LAWNS

A. Fertilizer for lawns shall be commercial fertilizer, uniform in composition, dry and free flowing. It shall contain the following percentage by weight: 20% of nitrogen, 0% of phosphoric acid, 0% of potash. Fertilizer shall be delivered mixed as specified in standard-sized bags, showing weight, analysis of content, and name of manufacturer as required by state regulations. If soil tests recommend variance from these percentages obtain Landscape Architect's approval prior to applications.

## 2.6 COMMERCIAL FERTILIZER – TREES AND SHRUBS

A. Fertilizer for trees, shrubs and ground cover planting areas shall be slow release type, Osmocote 18-6-12 used according to manufacturer's printed instructions.

## 2.7 TURFGRASS SOD

- A. Certified Number 1 Quality/Premium sod complying with TPI's "Specifications for Turfgrass Sod Materials".
- B. Turfgrass sod shall be machine cut at a uniform soil thickness of 0.60 inch. Standard size sections of turfgrass sod shall be strong enough that it can be picked up and handled without damage.
- C. Turfgrass sod shall be harvested, delivered, and installed within 24 hours.

## 2.8 PLANT MATERIAL

- A. All plants are subject to approval regarding size, health, quantity, character, etc. by the Landscape Architect.
- B. The Contractor shall furnish and plant all plants shown on the Drawings, as specified and in quantities as shown. Quantities if shown, are included for the convenience of the Contractor only and the Contractor shall be required to furnish all individual plants in quantities actually located on the Drawings. Each bidder shall investigate the sources of supply and satisfy himself that he can supply all of the plants mentioned in the planting lists in size, variety and quality noted and specified before submitting his bid. Failure to take this precaution will not relieve the successful

bidder from his responsibility as Contractor for the furnishing and installing of all the plant material in strict accordance with the contract requirements without additional expense to the Owner.

- C. All plants shall have been grown in nurseries which have been inspected or do not require inspection by the State Department of Agriculture and have complied with all the regulations thereof, in accordance with good horticulture practice.
- D. Plant names used in the Plant Material Key conform to "Standardized Plant Names" by the American Joint Committee of Horticulture Nomenclature, except in cases not covered therein. In these instances, the custom of the nursery trade is followed.
- E. Plant materials shall conform to the Plant Material Key shown on plans and to the requirements of the "Horticultural Standards" of the American Association of Nurserymen as to kind, size, age, etc. and shall be typical first-class representatives of their species or variety, and shall have a normal habit of growth, unless specified otherwise. They shall be sound, healthy and vigorous with a well-developed root system.
- F. All plants shall have been grown under climatic condition similar to those in the locality of the project for at least two (2) years and shall have been transplanted or root pruned at least once in the last two (2) years.
- G. All plants shall be number one quantity specimens and shall have a uniform matching caliper, size and canopy, be symmetrical with standard height, spread and branching patterns. No park grade plant material is acceptable.
  - 1. Trees shall have straight single leaders with symmetrical primary branching and considerable well spaced secondary branching filling out the head with no gaps.
- H. Plants shall be marked for identification. Each bundle of plants and at least 25% of each species and variety of separate plants in any one (1) shipment shall have legible labels securely attached before delivery to the site.
- I. All trees shall be measured when their branches are in their normal position. Height and spread dimensions specified refer to the main body of the plant and not from branch or root tip to tip. No trees which have had their leaders cut, or so damaged that cutting is necessary, will be accepted. Measure caliper of all trees 4" and larger 12" above the surface of the ground. Measure all trees less than 4" in caliper 6" above finish grade.
- J. All plants shall be symmetrical and shall conform to the size, age and condition as specified on the plant list shown on the Drawings. Exceptions are as follows:
  - 1. Plants larger than specified in the plant list may be used if approved by the Architect; but use of such plant shall not increase the contract price. If the use of larger plants is approved, the spread of roots and ball earth shall be increased in proportion to the size of the plant. Bare root plants furnished in size greater than specified shall be balled and burlapped when required by the Landscape Architect.
  - 2. Where caliper or other dimensions of any plant materials are omitted from the Plant Material Key, it shall be understood that these plant materials shall be normal stock for type listed and at a minimum, the average size of all the material listed.

- K. Plants shall not be pruned prior to delivery except as authorized by the Landscape Architect. In no case shall trees be topped before delivery.
- L. No plants shall be dug or delivered to the site until the required inspections have been made and the plants or samples approved.
- M. Dig balled and burlapped (BB) plants with firm, natural balls of earth, of diameter not less than specified and of sufficient depth to include all fibrous and feeding roots. No plant moved with a ball will be accepted if the ball is cracked or broken before or during planting operations, except on special approval of the Architect.
- N. Roots or balls or all plants shall be adequately protected at all times from sun and/or drying winds.
  - 1. All balled and burlapped plants which cannot be planted immediately upon delivery shall be set on the ground and shall be well protected with soil, wet moss, or other acceptable material.
  - 2. No plant shall be bound with wire or rope at any time so as to damage the bark or break branches.
- O. Plants marked “cans”, “pots” or “other container” on the plant list shall have been grown in the containers for a minimum of six (6) months and a maximum of two years. Roots shall fill the containers but show no evidence of being or having been root bound. Plants shall not be picked up or moved by stem or branches, but shall be lifted and handled from the sides of the containers.
- P. Trees shall have straight trunks and all old abrasions and cuts shall be completely callused over.

## 2.9 ANTI-TRANSPIRANT

- A. Anti-TRANSPIRANT solution for horticultural spray application. Use Bio-Plex, by Bioplex Organics, Inc. (800-441-3573).

## 2.10 WATER

- A. Potable water

## 2.11 TREE WRAP

- A. Tree wrap shall be kraft paper tree wrap, 3” wide. Wrap shall be resistant to weather degradation and require no maintenance and must stretch as the girth of the trunk increases over time.

## 2.12 MULCHES

- A. Natural shredded tree bark from pine and fir. Shredded wood products are not acceptable.

## 2.13 WEED BARRIER FABRIC

- A. Fabric shall be UV resistant, woven spunbond needle punch, polypropylene, wt. 5 oz, per square yard, color black. Use Dewitt Pro 5 Weed Barrier.

## PART 3 – EXECUTION

### 3.1 COORDINATION

- A. The contractor shall coordinate his work with the owner, and shall cooperate to the fullest extent to see that the work is completed in a timely and workmanship like manner.

### 3.2 INSTALLATION OF TOPSOIL

- A. Prior to the installation of any topsoil, Contractor shall inspect the existing subgrade for compliance to the specifications regarding elevation, slope, grade and cleanliness. Any deficiency shall be reported to the Landscape Architect. Work begun in any area will acknowledge acceptance of area for Landscape planting.
- B. When contract operations have been completed to a point where planting areas will not be disturbed, subgrade shall be cleaned free of waste material of all kinds. In all planted areas dig out all weeds by their roots and remove from site. Scarify and pulverize the subgrade to a depth of not less than 6" inches. Scarification shall be completed in all areas that are to be planted, or sodded.
- C. Do not place topsoil over subgrade that is frozen or damp.
- D. Preparation of the topsoil:
  - 1. Spread the stockpiled topsoil over the entire turf area. This topsoil layer will be approximately 4" deep.
  - 2. Spread compost over the entire turf area at a rate of 3 cubic yards per 1000 sf. (approximately 1" deep)
  - 3. Spread the imported topsoil over the entire turf area so that the total depth of all topsoil and amendments is equal to 6" deep.
  - 4. Calculate the fertilizer requirements of the entire topsoil profile and spread the required fertilizer over the entire turf area.
  - 5. Till the topsoil, and amendments to a depth of 6"
  - 6. Take two representative samples of the topsoil and have them tested at two separate soil testing agencies.
- E. Large turf areas shall be graded by passing a land plane in three different directions over the entire area to be planted. The soccer field is to be graded using machine control guidance technology. Grade to edges, walks and existing lawn areas so all transitions are straight, smooth, and meet existing grades as required.
- F. Surface drainage shall be insured, and if shown, shall be directed in the manner indicated on the drawings by molding the surface to facilitate the run-off water. Fill low spots and pockets with topsoil and grade to drain properly.

- 3.3 The Landscape Architect shall approve the finish grading and topsoil prior to application of sod material. Make minor adjustments to finish grades at the direction of the Landscape Architect.

### 3.4 SODDING

- A. Place sod after fine grading has been completed. The topsoil shall be moist and firm. Apply one (1) application of commercial fertilizer 16-16-8 at the rate of 3 lbs. per 1,000 sq. ft. just prior to the laying of the sod.
- B. Sod may be placed at any time when the ground is not frozen. Sod shall be cut and laid on site within a 24 hour period following harvest. Install butting the edges and ends together tightly. Do not leave gaps or stretch sod. Stagger joints.
- C. The joints shall be closely laid and filled with a mixture of grass seed and screened topsoil at the rate of two (2) pounds of seed to each cubic yard of topsoil. It shall be thoroughly tamped to a true and even surface at the required finished grade.
- D. Roll firmly but lightly, tamp with suitable wooden or metal tamper, all new sod sufficiently to set or press sod into underlying soil.
- E. Protection of the newly laid sod shall be the complete responsibility of the Contractor. Provide acceptable visual barriers by means of barricades set at appropriate distances and strings or tapes between the barriers as an indication of new work. Restore any damaged areas caused by others, erosion or vehicular traffic until such a time as the lawn is accepted by the Owner.
- F. Saturate sod with fine water spray within one hour of planting. During first week, water daily or more frequently as necessary to maintain moist soil to a minimum depth of 1-1/2 inches (38 mm) below sod.

### 3.5 CLEAN UP AND PROTECTION

- A. During landscape work store materials and equipment where directed. Keep pavement clean and work area in an orderly condition.
- B. Protect landscape areas, work and materials from damage due to operations by other contractors and trades, trespassers. Maintain protection during installation and maintenance periods. Treat, repair or replace damaged landscape work as directed.
- C. Keep the site free from accumulation of waste material. At the time of completion, all areas must be swept and washed clean and all rubbish removed to the satisfaction of the Landscape Architect.
- D. Temporary occupancy of the project shall not relieve the contractor of any of the obligations enumerated in the Contract Documents.

### 3.6 TOTAL SITE MAINTENANCE

- 1. As part of this Contract, this Contractor shall be responsible for the continuous maintenance of all landscape areas, i.e., weeding, watering, mowing, fertilization, etc. from the time of planting until the Project Date of Substantial Completion. If any planting area is deemed not to be substantially complete by the Project Date of Substantial Completion, penalties will apply and the contractor shall be required to provide all required maintenance after the project substantial completion date until final acceptance.

- B. The Contractor shall instruct the Owner as to the watering requirements and shall monitor such operations at all times. The Contractor shall be held responsible for failure to monitor the watering requirements and shall be held responsible to replace any or all plants that are lost due to improper application of water.
- C. Lawns shall be maintained for as much time as necessary to establish over the entire lawn a close stand of grass of the varieties specified, free of weeds and undesirable coarse, native grasses, but in no case less than two growing months after planting. Lawns shall be mowed once per week throughout this period.
- D. All lawns shall be fertilized every three (3) weeks with two (2) pounds of 16-16-8 commercial fertilizer per 1000 sq ft until the end of the maintenance period required. It shall be the responsibility of this Contractor to notify the Landscape Architect and Owner in writing 48 hours prior to fertilizing to provide visual verification of work.
- E. Maintenance shall include, in addition to the above, cleaning, edging and repair to erosion and all other necessary work of maintenance. Sidewalks and other paved areas shall be kept clean when planting and maintenance are in progress.
- F. Any and all sprinkler lines broken or disrupted during the construction and maintenance period shall be replaced to proper working order and be acceptable to the Owner.

### 3.7 FINAL INSPECTION AND ACCEPTANCE

- A. Inspection will be made of the entire site periodically and at the conclusion of the maintenance period required.
- B. The landscape work may be inspected for acceptance in parts agreeable to the Landscape Architect, provided the work offered for inspection is complete, including maintenance and that the area comprises one unit or area of substantial size.
- C. Written notice requesting final inspection shall be submitted to the Landscape Architect at least ten (10) days prior to the anticipated inspection date.
- D. Where inspected landscape work does not comply with the requirement, replace rejected work and continue specified maintenance until re-inspected by the Landscape Architect and found to be acceptable. Remove rejected plant materials promptly from the project site.
- E. Final Acceptance: The work under this contract will be accepted upon written approval by the Landscape Architect and the Owner, on the satisfactory completion of all work, including maintenance.
- F. All work done under this contract shall be left in good order to the satisfaction of the Owner and the Landscape Architect and the Contractor shall without additional expense, replace plant material that develop defects or die within one year of the substantial completion.
  - 1. A written guarantee that covers the above provisions shall be signed by the Contractor and delivered to the Landscape Architect upon acceptance of the work.
  - 2. The guarantee shall not be binding upon the Contractor if any failure should be proved to the satisfaction of the Landscape Architect to result from circumstances or negligence of parties over whom the Contractor has no control.



3.8 RECORD DRAWINGS

- A. Record Drawings shall be furnished to the Landscape Architect at the time of the substantial completion inspection before a letter documenting Substantial Completion for the landscape planting will be issued.

END OF SECTION 329000

## **SECTION 330500 - COMMON WORK RESULTS FOR UTILITIES**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes the following:
  - 1. Piping joining materials.
  - 2. Transition fittings.
  - 3. Sleeves.
  - 4. Identification devices.
  - 5. Grout.
  - 6. Flowable fill.
  - 7. Piped utility demolition.
  - 8. Piping system common requirements.
  - 9. Equipment installation common requirements.
  - 10. Painting.
  - 11. Concrete bases.
  - 12. Metal supports and anchorages.

#### **1.3 DEFINITIONS**

- A. Exposed Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions.
- B. Concealed Installations: Concealed from view and protected from weather conditions and physical contact by building occupants but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.
- C. PVC: Polyvinyl chloride plastic.
- D. DI: Ductile Iron pipe

#### **1.4 SUBMITTALS**

- A. Product Data: For the following:

1. Identification devices.

B. Welding certificates.

#### 1.5 QUALITY ASSURANCE

A. Comply with ASME A13.1 for lettering size, length of color field, colors, and viewing angles of identification devices.

#### 1.6 DELIVERY, STORAGE, AND HANDLING

A. Deliver pipes and tubes with factory-applied end caps. Maintain end caps through shipping, storage, and handling to prevent pipe end damage and to prevent entrance of dirt, debris, and moisture.

B. Store plastic pipes protected from direct sunlight. Support to prevent sagging and bending.

#### 1.7 COORDINATION

A. Coordinate installation of required supporting devices and set sleeves in poured-in-place concrete and other structural components as they are constructed.

B. Coordinate installation of identifying devices after completing covering and painting if devices are applied to surfaces.

C. Coordinate size and location of concrete bases. Formwork, reinforcement, and concrete requirements are specified in Division 03.

### PART 2 - PRODUCTS

#### 2.1 PIPING JOINING MATERIALS

A. Pipe-Flange Gasket Materials: Suitable for chemical and thermal conditions of piping system contents.

1. ASME B16.21, nonmetallic, flat, asbestos free, 1/8-inch maximum thickness, unless otherwise indicated.

a. Full-Face Type: For flat-face, Class 125, cast-iron and cast-bronze flanges.

b. Narrow-Face Type: For raised-face, Class 250, cast-iron and steel flanges.

2. AWWA C110, rubber, flat face, 1/8 inch thick, unless otherwise indicated; and full-face or ring type, unless otherwise indicated.

B. Flange Bolts and Nuts: ASME B18.2.1, carbon steel, unless otherwise indicated.

- C. Plastic, Pipe-Flange Gasket, Bolts, and Nuts: Type and material recommended by piping system manufacturer, unless otherwise indicated.
- D. Welding Filler Metals: Comply with AWS D10.12/D10.12M for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.
- E. Solvent Cements for Joining Plastic Piping:
  - 1. PVC Piping: ASTM D 2564. Include primer according to ASTM F 656.
- F. Fiberglass Pipe Adhesive: As furnished or recommended by pipe manufacturer.

## 2.2 TRANSITION FITTINGS

- A. Transition Fittings, General: Same size as, and with pressure rating at least equal to and with ends compatible with, piping to be joined.
- B. Transition Couplings NPS 1-1/2 and Smaller:
  - 1. Underground Piping: Manufactured piping coupling or specified piping system fitting.
  - 2. Aboveground Piping: Specified piping system fitting.
- C. AWWA Transition Couplings NPS 2 and Larger:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Cascade Waterworks Mfg. Co.
    - b. Dresser, Inc.; DMD Div.
    - c. Ford Meter Box Company, Inc. (The); Pipe Products Div.
    - d. JCM Industries.
    - e. Smith-Blair, Inc.
    - f. Viking Johnson.
  - 3. Description: AWWA C219, metal sleeve-type coupling for underground pressure piping.
- D. Plastic-to-Metal Transition Fittings:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Spears Manufacturing Co.

3. Description: PVC one-piece fitting with manufacturer's Schedule 80 equivalent dimensions.

E. Plastic-to-Metal Transition Unions:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Colonial Engineering, Inc.
  - b. NIBCO INC.
  - c. Spears Manufacturing Co.

F. Flexible Transition Couplings for Underground Nonpressure Drainage Piping:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Cascade Waterworks Mfg. Co.
  - b. Fernco, Inc.
  - c. Mission Rubber Company.
  - d. Plastic Oddities.

- G. Description: ASTM C 1173 with elastomeric sleeve, ends same size as piping to be joined, and corrosion-resistant metal band on each end.

## 2.3 SLEEVES

- A. Mechanical sleeve seals for pipe penetrations are specified in Division 22 Section "Common Work Results for Plumbing."
- B. Galvanized-Steel Sheet Sleeves: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.
- C. Steel Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, galvanized, plain ends.
- D. Cast-Iron Sleeves: Cast or fabricated "wall pipe" equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop, unless otherwise indicated.
- E. Molded PVC Sleeves: Permanent, with nailing flange for attaching to wooden forms.
- F. PVC Pipe Sleeves: ASTM D 1785, Schedule 40.

- G. Molded PE Sleeves: Reusable, PE, tapered-cup shaped, and smooth outer surface with nailing flange for attaching to wooden forms.

## 2.4 IDENTIFICATION DEVICES

- A. General: Products specified are for applications referenced in other Division 33 Sections. If more than single type is specified for listed applications, selection is Installer's option.
- B. Equipment Nameplates: Metal permanently fastened to equipment with data engraved or stamped.
  - 1. Data: Manufacturer, product name, model number, serial number, capacity, operating and power characteristics, labels of tested compliances, and essential data.
  - 2. Location: Accessible and visible.

## 2.5 GROUT

- A. Description: ASTM C 1107, Grade B, nonshrink and nonmetallic, dry hydraulic-cement grout.
  - 1. Characteristics: Post hardening, volume adjusting, nonstaining, noncorrosive, nongaseous, and recommended for interior and exterior applications.
  - 2. Design Mix: 5000-psi, 28-day compressive strength.
  - 3. Packaging: Premixed and factory packaged.

## 2.6 FLOWABLE FILL

- A. Description: Low-strength-concrete, flowable-slurry mix.
  - 1. Cement: ASTM C 150, Type I, portland.
  - 2. Density: 115- to 145-lb/cu. ft.
  - 3. Aggregates: ASTM C 33, natural sand, fine and crushed gravel or stone, coarse.
  - 4. Aggregates: ASTM C 33, natural sand, fine.
  - 5. Admixture: ASTM C 618, fly-ash mineral.
  - 6. Water: Comply with ASTM C 94/C 94M.
  - 7. Strength: 100 to 200 psig at 28 days.

## PART 3 - EXECUTION

### 3.1 PIPED UTILITY DEMOLITION

- A. Refer to Division 01 Section "Cutting and Patching" and Division 02 Section "Selective Structure Demolition" for general demolition requirements and procedures.
- B. Disconnect, demolish, and remove piped utility systems, equipment, and components indicated to be removed.

1. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
  2. Piping to Be Abandoned in Place: Drain piping. Fill abandoned piping with flowable fill, and cap or plug piping with same or compatible piping material.
  3. Equipment to Be Removed: Disconnect and cap services and remove equipment.
  4. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make operational.
  5. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
- C. If pipe, insulation, or equipment to remain is damaged in appearance or is unserviceable, remove damaged or unserviceable portions and replace with new products of equal capacity and quality.

### 3.2 PIPING INSTALLATION

- A. Install piping according to the following requirements and Division 33 Sections specifying piping systems.
- B. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on the Coordination Drawings.
- C. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- D. Install piping to permit valve servicing.
- E. Install piping at indicated slopes.
- F. Install piping free of sags and bends.
- G. Install fittings for changes in direction and branch connections.
- H. Select system components with pressure rating equal to or greater than system operating pressure.
- I. Sleeves are not required for core-drilled holes.
- J. Permanent sleeves are not required for holes formed by removable PE sleeves.
- K. Install sleeves for pipes passing through concrete and masonry walls and concrete floor and roof slabs.
  1. Cut sleeves to length for mounting flush with both surfaces.
  2. Install sleeves in new walls and slabs as new walls and slabs are constructed.

- a. PVC or Steel Pipe Sleeves: For pipes smaller than NPS 6.
- L. Verify final equipment locations for roughing-in.
- M. Refer to equipment specifications in other Sections for roughing-in requirements.

### 3.3 PIPING JOINT CONSTRUCTION

- A. Join pipe and fittings according to the following requirements and Division 33 Sections specifying piping systems.
- B. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- C. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- D. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
  - 1. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
  - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- E. Welded Joints: Construct joints according to AWS D10.12/D10.12M, using qualified processes and welding operators according to Part 1 "Quality Assurance" Article.
- F. Flanged Joints: Select appropriate gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Use suitable lubricants on bolt threads.
- G. Grooved Joints: Assemble joints with grooved-end pipe coupling with coupling housing, gasket, lubricant, and bolts according to coupling and fitting manufacturer's written instructions.
- H. Soldered Joints: Apply ASTM B 813 water-flushable flux, unless otherwise indicated, to tube end. Construct joints according to ASTM B 828 or CDA's "Copper Tube Handbook," using lead-free solder alloy (0.20 percent maximum lead content) complying with ASTM B 32.
- I. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," "Pipe and Tube" Chapter, using copper-phosphorus brazing filler metal complying with AWS A5.8.
- J. Pressure-Sealed Joints: Assemble joints for plain-end copper tube and mechanical pressure seal fitting with proprietary crimping tool to according to fitting manufacturer's written instructions.
- K. Plastic Piping Solvent-Cemented Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
  - 1. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements.



2. ABS Piping: Join according to ASTM D 2235 and ASTM D 2661 appendixes.
3. CPVC Piping: Join according to ASTM D 2846/D 2846M Appendix.
4. PVC Pressure Piping: Join schedule number ASTM D 1785, PVC pipe and PVC socket fittings according to ASTM D 2672. Join other-than-schedule-number PVC pipe and socket fittings according to ASTM D 2855.
5. PVC Nonpressure Piping: Join according to ASTM D 2855.
6. PVC to ABS Nonpressure Transition Fittings: Join according to ASTM D 3138 Appendix.

L. Plastic Pressure Piping Gasketed Joints: Join according to ASTM D 3139.

M. Plastic Nonpressure Piping Gasketed Joints: Join according to ASTM D 3212.

N. Plastic Piping Heat-Fusion Joints: Clean and dry joining surfaces by wiping with clean cloth or paper towels. Join according to ASTM D 2657.

1. Plain-End PE Pipe and Fittings: Use butt fusion.
2. Plain-End PE Pipe and Socket Fittings: Use socket fusion.

O. Bonded Joints: Prepare pipe ends and fittings, apply adhesive, and join according to pipe manufacturer's written instructions.

### 3.4 PIPING CONNECTIONS

A. Make connections according to the following, unless otherwise indicated:

1. Install unions, in piping NPS 2 and smaller, adjacent to each valve and at final connection to each piece of equipment.
2. Install flanges, in piping NPS 2-1/2 and larger, adjacent to flanged valves and at final connection to each piece of equipment.
3. Install dielectric fittings at connections of dissimilar metal pipes.

### 3.5 EQUIPMENT INSTALLATION

A. Install equipment level and plumb, unless otherwise indicated.

B. Install equipment to facilitate service, maintenance, and repair or replacement of components. Connect equipment for ease of disconnecting, with minimum interference with other installations. Extend grease fittings to an accessible location.

C. Install equipment to allow right of way to piping systems installed at required slope.

### 3.6 PAINTING

A. Painting of piped utility systems, equipment, and components is specified in Division 09 painting Sections.

- B. Damage and Touchup: Repair marred and damaged factory-painted finishes with materials and procedures to match original factory finish.

### 3.7 IDENTIFICATION

- A. Piping Systems: Install pipe markers on each system. Include arrows showing normal direction of flow.
  - 1. Plastic markers, with application systems. Install on insulation segment if required for hot noninsulated piping. Place direct bury marker 12-18 inches above top of pipe but not less than 12-inches below finish grade.

### 3.8 GROUTING

- A. Mix and install grout for equipment base bearing surfaces, pump and other equipment base plates, and anchors.
- B. Clean surfaces that will come into contact with grout.
- C. Provide forms as required for placement of grout.
- D. Avoid air entrapment during placement of grout.
- E. Place grout, completely filling equipment bases.
- F. Place grout on concrete bases and provide smooth bearing surface for equipment.
- G. Place grout around anchors.
- H. Cure placed grout.

END OF SECTION 330500

THIS PAGE LEFT INTENTIONALLY BLANK

## **SECTION 334100 - STORM UTILITY DRAINAGE PIPING**

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. This Section includes gravity-flow, nonpressure storm drainage outside the building, with the following components:
  - 1. Special fittings for expansion and deflection.
  - 2. Cleanouts.
  - 3. Drains.
  - 4. Precast and cast in place inlet boxes and catch basins.

#### **1.3 DEFINITIONS**

- A. PVC: Polyvinyl chloride plastic.
- B. CP: Non-reinforced concrete pipe.
- C. RCP: Reinforced concrete pipe.

#### **1.4 PERFORMANCE REQUIREMENTS**

- A. Gravity-Flow, Nonpressure, Drainage-Piping Pressure Rating: 10-foot head of water. Pipe joints shall be at least silttight, unless otherwise indicated.

#### **1.5 SUBMITTALS**

- A. Product Data: For the following:
  - 1. Special pipe fittings.
  - 2. Drains.
  - 3. Storage.
  - 4. Pipes.
- B. Shop Drawings: For the following:

1. Design calculations, and concrete design-mix report for cast-in-place manholes.]
  2. Catch Basins and Stormwater Inlets. Include plans, elevations, sections, details, and frames, covers, and grates.
  3. Stormwater Detention Structures: Include plans, elevations, sections, details, frames and covers, design calculations, and concrete design-mix report.
- C. Coordination Drawings: Show pipe sizes, locations, and elevations. Show other piping in same trench and clearances from storm drainage system piping. Indicate interface and spatial relationship between manholes, piping, and proximate structures.
- D. Profile Drawings: Show system piping in elevation. Draw profiles at horizontal scale of not less than 1 inch equals 50 feet and vertical scale of not less than 1 inch equals 5 feet. Indicate manholes and piping. Show types, sizes, materials, and elevations of other utilities crossing system piping.
- E. Field quality-control test reports.

#### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Do not store plastic manholes, pipe, and fittings in direct sunlight.
- B. Protect pipe, pipe fittings, and seals from dirt and damage.
- C. Handle manholes according to manufacturer's written rigging instructions.
- D. Handle catch basins and stormwater inlets according to manufacturer's written rigging instructions.

#### 1.7 PROJECT CONDITIONS

- A. Interruption of Existing Storm Drainage Service: Do not interrupt service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary service according to requirements indicated:
  1. Notify Architect, Construction Manager, and Owner no fewer than two days in advance of proposed interruption of service. Coordinate interruptions during weekly meetings and at pre-construction meeting.
  2. Do not proceed with interruption of service without Architect's, Construction Manager's, and Owner's written permission.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include local pre-cast manufacturers but are subject to approval of the engineer and architect.

## 2.2 PIPING MATERIALS

- A. Refer to Part 3 "Piping Applications" Article for applications of pipe, fitting, and joining materials.

## 2.3 PVC PIPE AND FITTINGS

- A. PVC Pressure Pipe: AWWA C900, Class 150 for gasketed joints and using ASTM F 477, elastomeric seals.
  1. Fittings NPS 4 to NPS 8: PVC pressure fittings complying with AWWA C907, for gasketed joints and using ASTM F 477, elastomeric seals.
  2. Fittings NPS 10 and Larger: Ductile-iron, compact fittings complying with AWWA C153, for push-on joints and using AWWA C111, rubber gaskets.
- B. PVC Water-Service Pipe and Fittings: ASTM D 1785, Schedule 80 pipe, with plain ends for solvent-cemented joints with ASTM D 2467, Schedule 80, socket-type fittings.
- C. PVC Cellular-Core Pipe and Fittings: ASTM F 891, Sewer and Drain Series, PS 50 minimum stiffness pipe with ASTM D 3034, SDR 35, socket-type fittings for solvent-cemented joints.
- D. PVC Sewer Pipe and Fittings, NPS 15 and Smaller: ASTM D 3034, SDR 35, with bell-and-spigot ends for gasketed joints with ASTM F 477, elastomeric seals.
- E. PVC Sewer Pipe and Fittings, NPS 18 and Larger: ASTM F 679, T 2 wall thickness, with bell-and-spigot ends for gasketed joints with ASTM F 477, elastomeric seals.
- F. PVC Profile Gravity Sewer Pipe and Fittings: ASTM F 794 pipe, with bell-and-spigot ends; ASTM D 3034 fittings, with bell ends; and ASTM F 477, elastomeric seals.

## 2.4 CONCRETE PIPE AND FITTINGS

- A. Nonreinforced-Concrete Sewer Pipe and Fittings: ASTM C 14, Class I, II or III, with bell-and-spigot ends and gasketed joints with ASTM C 443, rubber gaskets.
- B. Piping in paragraph below is available in 5 classes and 3 wall thicknesses, and in NPS 12 to NPS 144. Not all classes and wall thicknesses are available. Joints are gasket type. Contractor, at his option, may use non-reinforced pipe for sizes up to 21-inches if structural requirements based on load on pipe are not exceeded for that pipe. If reinforced pipe is selected, choose the pipe class and wall thickness to suit availability and structural requirements based on loads and cover.

- C. Reinforced-Concrete Sewer Pipe and Fittings: ASTM C 76, with bell-and-spigot ends and gasketed joints with ASTM C 443, rubber gaskets.
  - 1. Class I
  - 2. Class II
  - 3. Class III

## 2.5 NONPRESSURE-TYPE PIPE COUPLINGS

- A. Comply with ASTM C 1173, elastomeric, sleeve-type, reducing or transition coupling, for joining underground nonpressure piping. Include ends of same sizes as piping to be joined, and corrosion-resistant-metal tension band and tightening mechanism on each end.
- B. Sleeve Materials:
  - 1. For Concrete Pipes: ASTM C 443, rubber.
  - 2. For Cast-Iron Soil Pipes: ASTM C 564, rubber.
  - 3. For Plastic Pipes: ASTM F 477, elastomeric seal or ASTM D 5926, PVC.
  - 4. For Dissimilar Pipes: ASTM D 5926, PVC or other material compatible with pipe materials being joined.
- C. Unshielded Flexible Couplings: Elastomeric sleeve with stainless-steel shear ring and corrosion-resistant-metal tension band and tightening mechanism on each end.
  - 1. Manufacturers:
    - a. Dallas Specialty & Mfg. Co.
    - b. Fernco Inc.
    - c. Logan Clay Products Company (The).
    - d. Mission Rubber Company; a division of MCP Industries, Inc.
    - e. NDS Inc.
    - f. Plastic Oddities, Inc.
- D. Shielded Flexible Couplings: ASTM C 1460, elastomeric or rubber sleeve with full-length, corrosion-resistant outer shield and corrosion-resistant-metal tension band and tightening mechanism on each end.
  - 1. Manufacturers:
    - a. Cascade Waterworks Mfg.
    - b. Dallas Specialty & Mfg. Co.
    - c. Mission Rubber Company; a division of MCP Industries, Inc.
- E. Ring-Type Flexible Couplings: Elastomeric compression seal with dimensions to fit inside bell of larger pipe and for spigot of smaller pipe to fit inside ring.
  - 1. Manufacturers:
    - a. Fernco Inc.

- b. Logan Clay Products Company (The).
- c. Mission Rubber Company; a division of MCP Industries, Inc.

## 2.6 PRESSURE-TYPE PIPE COUPLINGS

- A. Reducing or transition, metal, bolted, sleeve-type, reducing or transition coupling, for joining underground pressure piping. Include 150-psig minimum pressure rating and ends of same sizes as piping to be joined.
- B. Tubular-Sleeve Couplings: AWWA C219, with center sleeve, gaskets, end rings, and bolt fasteners.
  - 1. Manufacturers:
    - a. Cascade Waterworks Mfg.
    - b. Dresser, Inc.; DMD Div.
    - c. Ford Meter Box Company, Inc. (The); Pipe Products Div.
    - d. JCM Industries.
    - e. Romac Industries, Inc.
    - f. Smith-Blair, Inc.
    - g. Viking Johnson.
  - 2. Center-Sleeve Material: Manufacturer's standard.
  - 3. Gasket Material: Natural or synthetic rubber.
  - 4. Metal Component Finish: Corrosion-resistant coating or material.
- C. Split-Sleeve Couplings: With split sleeve with sealing pad and closure plates, O-ring gaskets, and bolt fasteners.
  - 1. Manufacturers:
    - a. Brico Industries.
  - 2. Sleeve Material: Manufacturer's standard.
  - 3. Sleeve Dimensions: Of thickness and width required to provide pressure rating.
  - 4. Gasket Material: O-rings made of EPDM rubber, unless otherwise indicated.
  - 5. Metal Component Finish: Corrosion-resistant coating or material.

## 2.7 SPECIAL PIPE FITTINGS

- A. Ductile-Iron Flexible Expansion Joints: Compound fitting with combination of flanged and mechanical-joint ends complying with AWWA C110 or AWWA C153. Include 2 gasketed ball-joint sections and 1 or more gasketed sleeve sections, rated for 250-psig minimum working pressure and for offset and expansion indicated.
  - 1. Manufacturers:
    - a. EBAA Iron Sales, Inc.



- b. Romac Industries, Inc.
  - c. Star Pipe Products.
- B. Ductile-Iron Deflection Fittings: Compound coupling fitting with ball joint, flexing section, gaskets, and restrained-joint ends complying with AWWA C110 or AWWA C153. Include rating for 250-psig minimum working pressure and for up to 15 degrees of deflection.
  - 1. Manufacturers:
    - a. EBAA Iron Sales, Inc.
- C. Ductile-Iron Expansion Joints: Three-piece assembly of telescoping sleeve with gaskets and restrained-type, ductile-iron, bell-and-spigot end sections complying with AWWA C110 or AWWA C153. Include rating for 250-psig minimum working pressure and for expansion indicated.
  - 1. Manufacturers:
    - a. Dresser, Inc.; DMD Div.
    - b. EBAA Iron Sales, Inc.
    - c. JCM Industries.
    - d. Smith-Blair, Inc.

## 2.8 CLEANOUTS

- A. Gray-Iron Cleanouts: ASME A112.36.2M, round, gray-iron housing with clamping device and round, secured, scoriated, gray-iron cover. Include gray-iron ferrule with inside calk or spigot connection and countersunk, tapered-thread, brass closure plug.
  - 1. Manufacturers:
    - a. Josam Company.
    - b. MIFAB Manufacturing, Inc.
    - c. Smith, Jay R. Mfg. Co.
    - d. Wade Div.; Tyler Pipe.
    - e. Watts Industries, Inc.
    - f. Watts Industries, Inc.; Enpoco, Inc. Div.
    - g. Zurn Industries, Inc.; Zurn Specification Drainage Operation.
  - 2. Top-Loading Classification(s): Light, Medium, Heavy, and Extra-heavy duty depending on location and expected driving load on cleanout.
  - 3. Sewer Pipe Fitting and Riser to Cleanout: ASTM A 74, Service class, cast-iron soil pipe and fittings.
- B. PVC Cleanouts: PVC body with PVC threaded plug. Include PVC sewer pipe fitting and riser to cleanout of same material as sewer piping. Place in grey iron housing with clamping device and round, secured, scoriated, gray-iron cover.
  - 1. Manufacturers:

- a. Canplas Inc.
- b. IPS Corporation.
- c. NDS Inc.
- d. Plastic Oddities, Inc.
- e. Sioux Chief Manufacturing Company, Inc.
- f. Zurn Industries, Inc.; Zurn Light Commercial Specialty Plumbing Products.

## 2.9 DRAINS

- A. Gray-Iron Area Drains: ASME A112.21.1M, round body with anchor flange and round secured grate. Include bottom outlet with inside calk or spigot connection, of sizes indicated.

1. Manufacturers:

- a. Josam Company.
- b. MIFAB Manufacturing, Inc.
- c. Smith, Jay R. Mfg. Co.
- d. Wade Div.; Tyler Pipe.
- e. Watts Industries, Inc.
- f. Watts Industries, Inc.; Enpoco, Inc. Div.
- g. Zurn Industries, Inc.; Zurn Specification Drainage Operation.

2. Top-Loading Classification(s): Medium and heavy duty depending on location and expected driving load.

- B. Gray-Iron Trench Drains: ASME A112.21.1M, 6-inch to 12-inch-wide top surface, rectangular body with anchor flange or other anchoring device, and rectangular secured grate. Include units of total length indicated and number of bottom outlets with inside calk or spigot connections, of sizes indicated.

1. Manufacturers:

- a. Josam Company.
- b. Smith, Jay R. Mfg. Co.
- c. Wade Div.; Tyler Pipe.
- d. Watts Industries, Inc.
- e. Watts Industries, Inc.; Enpoco, Inc. Div.
- f. Zurn Industries, Inc.; Zurn Specification Drainage Operation.
- g. Poly Drain, ABT

2. Top-Loading Classification(s): Medium, heavy, and extra-heavy duty.

## 2.10 MANHOLES (Not Used)

## 2.11 CONCRETE

- A. General: Cast-in-place concrete according to ACI 318/318R, ACI 350R, and the following:

1. Cement: ASTM C 150, Type II.
  2. Fine Aggregate: ASTM C 33, sand.
  3. Coarse Aggregate: ASTM C 33, crushed gravel.
  4. Water: Potable.
- B. Portland Cement Design Mix: 4000 psi minimum, with 0.45 maximum water-cementitious materials ratio.
1. Reinforcement Fabric: ASTM A 185, steel, welded wire fabric, plain.
  2. Reinforcement Bars: ASTM A 615/A 615M, Grade 60, deformed steel.
- C. Ballast and Pipe Supports: Portland cement design mix, 3000 psi minimum, with 0.58 maximum water-cementitious materials ratio.
1. Reinforcement Fabric: ASTM A 185, steel, welded wire fabric, plain.
  2. Reinforcement Bars: ASTM A 615/A 615M, Grade 60, deformed steel.
- 2.12 POLYMER-CONCRETE, CHANNEL DRAINAGE SYSTEMS (Not Used)
- 2.13 CATCH BASINS
- A. Standard Precast Concrete Catch Basins: ASTM C 478, precast, reinforced concrete, of depth indicated, with provision for sealant joints.
1. Base Section: 6-inch minimum thickness for floor slab and 4-inch minimum thickness for walls and base riser section, and having separate base slab or base section with integral floor.
  2. Riser Sections: 4-inch minimum thickness, and lengths to provide depth indicated.
  3. Top Section: Flat-slab-top type with hole for frame and grate is indicated.
  4. Joint Sealant: ASTM C 990, bitumen or butyl rubber.
  5. Adjusting Rings: Interlocking rings with level or sloped edge in thickness and shape matching catch basin frame and grate. Include sealant recommended by ring manufacturer.
  6. Grade Rings: Include 2 or 3 reinforced-concrete rings, of 6- to 9-inch total thickness, that match frame and grate.
  7. Steps: Not Used.
  8. Pipe Connectors: ASTM C 923, resilient, of size required, for each pipe connecting to base section. Size sections and box or manhole to fit pipes without necessary.
  9. Catch basins shall be provided by the contractor in an appropriate size to accommodate the pipe size, material, flow lines and arrangement as shown on the plans.
- B. Cast-in-Place Concrete, Catch Basins: Construct of reinforced concrete; designed according to ASTM C 890 for structural loading; of depth, shape, dimensions, and appurtenances indicated.
1. Bottom, Walls, and Top: Reinforced concrete.
  2. Channels and Benches: Concrete.
  3. Steps: Not used.

- C. Frames and Grates: ASTM A 536, Grade 60-40-18, ductile iron designed for H-20, structural loading. Include flat grate with small square or short-slotted drainage openings. All grates shall be bicycle proof. Grates installed in pedestrian areas shall be heel proof as determined by the manufacturer.
  - 1. Size: 24 by 24 inches minimum, unless otherwise indicated.
  - 2. Grate Free Area: Approximately 50 percent, unless otherwise indicated.

#### 2.14 STORMWATER INLETS

- A. Gutter Inlets: Horizontal gutter opening, of materials and dimensions indicated. Include heavy-duty frames and grates. All grates to be bicycle safe.
- B. Combination Inlets: Vertical curb and horizontal gutter openings, of materials and dimensions indicated. Include heavy-duty frames and grates.

#### 2.15 PIPE OUTLETS

- A. Head Walls: Cast-in-place reinforced concrete, with apron and tapered sides.
- B. Riprap Basins: Broken, irregular size and shape, graded stone according to NSSGA's "Quarried Stone for Erosion and Sediment Control."
- C. Filter Stone: According to NSSGA's "Quarried Stone for Erosion and Sediment Control," No. FS-2, No. 4 screen opening, average-size, graded stone.
- D. Energy Dissipaters: According to NSSGA's "Quarried Stone for Erosion and Sediment Control," No. A-1, 3-ton average weight armor stone, unless otherwise indicated.

#### 2.16 DRY WELLS

- A. Description: ASTM C 913, precast, reinforced, perforated concrete manholes with ring and cover, frame and grate, or lid as indicated and include the following:
  - 1. Floor: Cast-in-place concrete support ring.
  - 2. Cover: Liftoff-type concrete cover with cast-in lift rings.
  - 3. Wall Thickness: 4 inches minimum with 1-inch diameter or 1-by-3-inch maximum slotted perforations arranged in rows parallel to axis of ring.
    - a. Total Free Area of Perforations: Approximately 15 percent of ring interior surface.
    - b. Ring Construction: Designed to be self-aligning.
  - 4. Filtering Material: ASTM D 448, Size No. 24, 3/4- to 2-1/2-inch washed, crushed stone or gravel. The % of material passing the # 200 sieve shall not exceed 5%.

### PART 3 - EXECUTION

#### 3.1 EARTHWORK

- A. Excavation, trenching, and backfilling are specified in Division 31 Section "Earth Moving."

#### 3.2 PIPING APPLICATIONS

- A. Pipe couplings and special pipe fittings with pressure ratings at least equal to piping rating may be used in applications below, unless otherwise indicated.
  - 1. Use nonpressure-type flexible couplings where required to join gravity-flow, nonpressure sewer piping, unless otherwise indicated.
    - a. Flexible or rigid couplings for same or minor difference OD pipes.
    - b. Unshielded, increaser/reducer-pattern, flexible or rigid couplings for pipes with different OD.
    - c. Ring-type flexible couplings for piping of different sizes where annular space between smaller piping's OD and larger piping's ID permits installation.
  - 2. Use pressure-type pipe couplings for force-main joints.
- B. Special Pipe Fittings: Use for pipe expansion and deflection. Pipe couplings and special pipe fittings with pressure ratings at least equal to piping rating may be used in applications below, unless otherwise indicated.
- C. Gravity-Flow, Nonpressure Sewer Piping: Use any of the following pipe materials for each size range:
  - 1. PVC water-service pipe; PVC Schedule 40, water-service-pipe fittings; and solvent-cemented joints.
  - 2. PVC sewer pipe and fittings; gaskets; and gasketed joints.
  - 3. Class [1] [2] [3], nonreinforced-concrete sewer pipe and fittings, gaskets, and gasketed joints.
  - 4. Ductile-iron culvert pipe, ductile-iron standard or compact fittings, gaskets, and gasketed joints.
  - 5. Reinforced-concrete sewer pipe and fittings, gaskets, and gasketed joints.
  - 6. Corrugated steel pipe and fittings, standard and special-joint bands, and banded joints.
  - 7. Corrugated aluminum pipe and fittings, standard and special-joint bands, and banded joints.
  - 8. Corrugated PE pipe and fittings, silttight couplings, and coupled joints.

#### 3.3 PIPING INSTALLATION

- A. General Locations and Arrangements: Drawing plans and details indicate general location and arrangement of underground storm drainage piping. Location and arrangement of piping layout take design considerations into account. Install piping as indicated, to extent practical. Where specific installation is not indicated, follow piping manufacturer's written instructions.

- B. Install piping beginning at low point, true to grades and alignment indicated with unbroken continuity of invert. Place bell ends of piping facing upstream. Install gaskets, seals, sleeves, and couplings according to manufacturer's written instructions for use of lubricants, cements, and other installation requirements.
- C. Install manholes for changes in direction unless fittings are indicated. Use fittings for branch connections unless direct tap into existing sewer is indicated.
- D. Install proper size increasers, reducers, and couplings where different sizes or materials of pipes and fittings are connected. Reducing size of piping in direction of flow is prohibited.
- E. Tunneling: Install pipe under streets or other obstructions that cannot be disturbed by tunneling, jacking, or a combination of both.
- F. Install gravity-flow, nonpressure drainage piping according to the following:
  - 1. Install piping pitched down in direction of flow, at slope indicated.
  - 2. Install piping with restrained joints at tee fittings and at changes in direction for pressure pipe. Use corrosion-resistant rods, pipe or fitting manufacturer's proprietary restraint system, or cast-in-place concrete supports or anchors.
  - 3. Install piping with cover indicated.
  - 4. Notify engineer of clearance problems that would result in changes to grade and alignment.
  - 5. Install PVC cellular-core piping according to ASTM D 2321 and ASTM F 1668.
  - 6. Install PVC sewer piping according to ASTM D 2321 and ASTM F 1668.
  - 7. Install PVC profile gravity sewer piping according to ASTM D 2321 and ASTM F 1668.
  - 8. Install nonreinforced-concrete sewer piping according to ASTM C 1479 and ACPA's "Concrete Pipe Installation Manual."
  - 9. Install reinforced-concrete sewer piping according to ASTM C 1479 and ACPA's "Concrete Pipe Installation Manual."
- G. Install force-main pressure piping according to the following:
  - 1. Install piping with restrained joints at tee fittings and at horizontal and vertical changes in direction. Use corrosion-resistant rods, pipe or fitting manufacturer's proprietary restraint system, or cast-in-place concrete supports or anchors.
  - 2. Install piping with line and grade as indicated or below frost line if not indicated.
  - 3. Install PVC pressure piping according to AWWA M23 or ASTM D 2774 and ASTM F 1668.
  - 4. Install PVC water-service piping according to ASTM D 2774 and ASTM F 1668.

### 3.4 PIPE JOINT CONSTRUCTION

- A. Basic pipe joint construction is specified in Division 33 Section "Common Work Results for Utilities." Where specific joint construction is not indicated, follow piping manufacturer's written instructions.
- B. Join gravity-flow, nonpressure drainage piping according to the following:

1. Join PVC cellular-core piping according to ASTM D 2321 and ASTM F 891 for solvent-cement joints.
  2. Join PVC sewer piping according to ASTM D 2321 and ASTM D 3034 for elastomeric-seal joints or ASTM D 3034 for elastomeric gasket joints.
  3. Join PVC profile gravity sewer piping according to ASTM D 2321 for elastomeric-seal joints or ASTM F 794 for gasketed joints.
  4. Join nonreinforced-concrete sewer piping according to ASTM C 14 and ACPA's "Concrete Pipe Installation Manual" for rubber-gasket joints.
  5. Join reinforced-concrete sewer piping according to ACPA's "Concrete Pipe Installation Manual" for rubber-gasket joints.
  6. Join dissimilar pipe materials with nonpressure-type flexible or rigid couplings.
- C. Join dissimilar pipe materials with pressure-type couplings.

### 3.5 CLEANOUT INSTALLATION

- A. Install cleanouts and riser extension from sewer pipe to cleanout at grade. Use same pipe type as sewer line that the cleanout is connected to. Install piping so cleanouts open in direction of flow in sewer pipe.
1. Use light-duty, top-loading classification cleanouts in earth or unpaved foot-traffic areas.
  2. Use medium-duty, top-loading classification cleanouts in paved foot-traffic areas.
  3. Use heavy-duty, top-loading classification cleanouts in vehicle-traffic service areas.
  4. Use extra-heavy-duty, top-loading classification cleanouts in roads areas.
- B. Set cleanout frames and covers in earth in cast-in-place concrete block, 12 inches around outside of cover. At contractors option, a square block can be used that is at least 12-inches wider than the cover. Set with tops 1 inch above surrounding earth grade.
- C. Set cleanout frames and covers in concrete pavement with tops flush with pavement surface.

### 3.6 DRAIN INSTALLATION

- A. Install type of drains in locations indicated.
1. Use heavy-duty, top-loading classification drains in vehicle-traffic service areas, earth or unpaved foot-traffic areas and paved foot-traffic areas.
  2. Use extra-heavy-duty, top-loading classification drains in roads areas.
- B. Embed drains in 4-inch minimum depth of concrete around bottom and sides.
- C. Fasten grates to drains if indicated.
- D. Set drain frames and covers with tops flush with pavement surface.
- E. Assemble trench sections with flanged joints.
- F. Embed trench sections in 4-inch minimum concrete around bottom and sides.

3.7 MANHOLE INSTALLATION (Not Used)

3.8 CATCH BASIN INSTALLATION

- A. Construct catch basins in an appropriate size to accommodate the pipe size, material, flow lines and arrangement as shown on the plans.
- B. Set frames and grates to elevations indicated.
- C. Align boxes so that frame and grates are square to adjacent sidewalks, curbs or roadways.

3.9 STORMWATER INLET AND OUTLET INSTALLATION (Not Used)

3.10 DRAINAGE SYSTEM INSTALLATION (Not Used)

3.11 CONNECTIONS

- A. Connect nonpressure, gravity-flow drainage piping in building's storm building drains specified in Division 22 Section "Facility Storm Drainage Piping."
- B. Connect force-main pressure piping to building's storm drainage force mains specified in Division 22 Section "Facility Storm Drainage Piping." Terminate piping where indicated.
  - 1. Use commercially manufactured wye fittings for piping branch connections. Remove section of existing pipe; install wye fitting into existing piping; and encase entire wye fitting, plus 6-inch overlap, with not less than 6 inches of concrete with 28-day compressive strength of 3000 psi.
  - 2. Protect existing piping, manholes, and structures to prevent concrete or debris from entering while making tap connections. Remove debris or other extraneous material that may accumulate.
- C. Connect to sediment interceptors specified in Division 22 Section "Sanitary Waste Interceptors."

3.12 CLOSING ABANDONED STORM DRAINAGE SYSTEMS

- A. Abandoned Piping: Close open ends of abandoned underground piping indicated to remain in place. Include closures strong enough to withstand hydrostatic and earth pressures that may result after ends of abandoned piping have been closed. Use either procedure below:
  - 1. Close open ends of piping with at least 8-inch-thick, brick masonry bulkheads.
  - 2. Close open ends of piping with threaded metal caps, plastic plugs, or other acceptable methods suitable for size and type of material being closed. Do not use wood plugs.



- B. Abandoned Manholes and Structures: Excavate around manholes and structures as required and use one procedure below:
  - 1. Remove manhole or structure and close open ends of remaining piping.
  - 2. Remove top of manhole or structure down to at least 36 inches below final grade. Fill to within 12 inches of top with stone, rubble, gravel, or compacted dirt. Fill to top with concrete.
- C. Backfill to grade according to Division 31 Section "Earth Moving."

### 3.13 IDENTIFICATION

- A. Materials and their installation are specified in Division 31 Section "Earth Moving." Arrange for installation of green warning tape directly over piping and at outside edge of underground structures.
  - 1. Use warning tape or detectable warning tape over ferrous piping.
  - 2. Use detectable warning tape over nonferrous piping and over edges of underground structures.

### 3.14 FIELD QUALITY CONTROL

- A. Inspect interior of piping to determine whether line displacement or other damage has occurred. Inspect after approximately 24 inches of backfill is in place, and again at completion of Project.
  - 1. Submit separate reports for each system inspection.
    - a. Reports shall include a video log of storm drain showing all lineal footage of the system in DVD format. Log shall be submitted to the owner once a month. A final log shall be submitted with the as built drawing for the use of the owner and Architect.
  - 2. Defects requiring correction include the following:
    - a. Alignment: Less than full diameter of inside of pipe is visible between structures.
    - b. Deflection: Flexible piping with deflection that prevents passage of ball or cylinder of size not less than 92.5 percent of piping diameter.
    - c. Crushed, broken, cracked, or otherwise damaged piping.
    - d. Infiltration: Water leakage into piping.
    - e. Exfiltration: Water leakage from or around piping.
  - 3. Replace defective piping using new materials, and repeat inspections until defects are within allowances specified.
  - 4. Reinspect and repeat procedure until results are satisfactory.
- B. Test new piping systems, and parts of existing systems that have been altered, extended, or repaired, for leaks and defects.
  - 1. Do not enclose, cover, or put into service before inspection and approval.

2. Test completed piping systems according to authorities having jurisdiction.
  3. Schedule tests and inspections by authorities having jurisdiction with at least 24 hours' advance notice.
  4. Submit separate report for each test.
  5. Gravity-Flow Storm Drainage Piping: Test according to requirements of authorities having jurisdiction, UNI-B-6, and the following:
    - a. Exception: Piping with soiltight joints unless required by authorities having jurisdiction.
    - b. Option: Test plastic piping according to ASTM F 1417.
    - c. Option: Test concrete piping according to ASTM C 924.
- C. Leaks and loss in test pressure constitute defects that must be repaired.
- D. Replace leaking piping using new materials, and repeat testing until leakage is within allowances specified.

### 3.15 CLEANING

- A. Clean interior of piping of dirt and superfluous materials.

END OF SECTION 334100

THIS PAGE LEFT INTENTIONALLY BLANK